

THRIFTY OIL CO.

April 1, 1993

Alameda Environmental Health Department
Hazardous Materials Division
470 27th St. #322
Oakland, CA 94612

Re: THRIFTY OIL CO. #63
6125 Telegraph Avenue
Oakland, CA 94609

Dear Sir/Madam;

Enclosed please find our test results for the following;

- Tank Integrity
- Hydrostatic Line Test
- Leak Detector (Mechanical)
- Electronic Monitoring
- Meter Calibration

If you have any further questions or concerns, please contact me at Ext. 377. Thank you.

Yours truly,



Lori Freshour
Environmental Specialist



Champion's Precision
Tank Testing
License #73848

P.O. Box 13059
Sacramento, Calif. 95813
(916) 927-1557
(800) 660-9443 CA.
(800) 949-9443 NV.
Fax: (916) 927-7345

Thrifty Oil Company
% Lori Freshour
10000 Lakewood
Downey, Calif. 90240

Re: Leak Detector Testing For: Thrifty Oil #63
Location: 6125 Telegraph Avenue
Oakland, Calif.
Test Date: 1-29-93
Job#: 93CC2201

Dear

This acknowledgement is to confirm that we have completed the leak detector testing at the above location. If you should require more than (1) set of testing data then please inform the office ahead of schedule and we will be glad to assist you.

If you should need any further assistance pertaining to the testing results then please call the office for assistance.

Sincerely,



Chet Champion
CC/pg



Champion

Precision Tank Testing
License No. 73848

RED
JACKET
LEAK
DETECTOR TEST

P.O. Box 13059
Sacramento, CA 95813-3059
800-660-9443
(916) 927-1557
Fax: (916) 927-3855

DATE: 1-27-93
OPERATOR: THIRTY # 63
LOCATION: 6125 TELEGRAPH AVE, OAKLAND CA.

UNLEADED Plus

REGULAR: RUNNING PRESSURE 27 P.S.I. SHUT OFF PRESSURE 16 P.S.I. AMOUNT OF PRODUCT RELEASED THRU BIBCOCK TO ZERO. 6.5 OZ. WITH VALVE OPEN START STP. LIST PRESSURE 7 P.S.I. REDUCE FLOW RATE TO 7 OZ. PER MIN. LIST PRESSURE AT THIS FLOW RATE 9 P.S.I. TURN STP. OFF LET PRESSURE DROP TO ZERO THRU LEAK JUST CREATED LIST TIME FOR GUAGE TO REACH ZERO. MIN. 2 SEC. TURN STP. ON KEEP LEAK RATE AT BIBCOCK LIST PRESSURE 9 P.S.I. STOP LEAK WITH STP. STILL ON DOES LEAK DETECTOR RESET? YES NO IF YES: HOW LONG TO RESET? MIN. 1 SEC. TURN THE STP. OFF LIST PRESSURE 16 P.S.I. TURN STP. ON LIST TIME TO REACH PRESSURE RISE. MIN. 1 SEC. LIST PRESSURE 28 P.S.I. SATISFACTORY LEAK DETECTOR YES NO MODEL# 116-017
DATE CODE & SERIAL#: 21187-5862 SUBMERISBLE PUMP RED JACKET

UNLEADED: RUNNING PRESSURE 26 P.S.I. SHUT OFF PRESSURE 16 P.S.I. AMOUNT OF PRODUCT RELEASED THRU BIBCOCK TO ZERO. 1.5 OZ. WITH VALVE OPEN START STP. LIST PRESSURE 8 P.S.I. REDUCE FLOW RATE TO 7 OZ. PER MIN. LIST PRESSURE AT THIS FLOW RATE 8 P.S.I. TURN STP. OFF LET PRESSURE DROP TO ZERO THRU LEAK JUST CREATED LIST TIME FOR GUAGE TO REACH ZERO. MIN. 2 SEC. TURN STP. ON KEEP LEAK RATE AT BIBCOCK LIST PRESSURE 8 P.S.I. STOP LEAK WITH STP. STILL ON DOES LEAK DETECTOR RESET? YES NO IF YES: HOW LONG TO RESET? MIN. 2 SEC. TURN THE STP. OFF LIST PRESSURE 16 P.S.I. TURN STP. ON LIST TIME TO REACH PRESSURE RISE. MIN. 1 SEC. LIST PRESSURE 26 P.S.I. SATISFACTORY LEAK DETECTOR YES NO MODEL# 116-017
DATE CODE & SERIAL#: 30190-011 SUBMERISBLE PUMP RED JACKET

SUPER

PREMIUM: RUNNING PRESSURE 28 P.S.I. SHUT OFF PRESSURE 16 P.S.I. AMOUNT OF PRODUCT RELEASED THRU BIBCOCK TO ZERO. 1.5 OZ. WITH VALVE OPEN START STP. LIST PRESSURE 8 P.S.I. REDUCE FLOW RATE TO 7 OZ. PER MIN. LIST PRESSURE AT THIS FLOW RATE 9 P.S.I. TURN STP. OFF LET PRESSURE DROP TO ZERO THRU LEAK JUST CREATED LIST TIME FOR GUAGE TO REACH ZERO. MIN. 2 SEC. TURN STP. ON KEEP LEAK RATE AT BIBCOCK LIST PRESSURE 9 P.S.I. STOP LEAK WITH STP. STILL ON DOES LEAK DETECTOR RESET? YES NO IF YES: HOW LONG TO RESET? MIN. 2 SEC. TURN THE STP. OFF LIST PRESSURE 16 P.S.I. TURN STP. ON LIST TIME TO REACH PRESSURE RISE. MIN. 1 SEC. LIST PRESSURE 28 P.S.I. SATISFACTORY LEAK DETECTOR YES NO MODEL# 116-017
DATE CODE & SERIAL#: 21187-1003 SUBMERISBLE PUMP RED JACKET

DIESEL: RUNNING PRESSURE _____ P.S.I. SHUT OFF PRESSURE _____ P.S.I. AMOUNT OF PRODUCT RELEASED THRU BIBCOCK TO ZERO. _____ OZ. WITH VALVE OPEN START STP. LIST PRESSURE _____ P.S.I. REDUCE FLOW RATE TO 7 OZ. PER MIN. LIST PRESSURE AT THIS FLOW RATE _____ P.S.I. TURN STP. OFF LET PRESSURE DROP TO ZERO THRU LEAK JUST CREATED LIST TIME FOR GUAGE TO REACH ZERO. MIN. _____ SEC. TURN STP. ON KEEP LEAK RATE AT BIBCOCK LIST PRESSURE _____ P.S.I. STOP LEAK WITH STP. STILL ON DOES LEAK DETECTOR RESET? YES NO IF YES: HOW LONG TO RESET? MIN _____ SEC. TURN THE STP. OFF LIST PRESSURE _____ P.S.I. TURN STP. ON LIST TIME TO REACH PRESSURE RISE. MIN. _____ SEC. LIST PRESSURE _____ P.S.I. SATISFACTORY LEAK DETECTOR YES NO MODEL# _____
DATE CODE & SERIAL#: _____ SUBMERISBLE PUMP _____

CALIFORNIA STATE LICENSED TANK TESTERS:
William Campbell 92-1234 Alvin Milburn 92-1409 David Reeves 93-1125

TECHNICIAN: ALVIN L. MILBURN ASSISTANT: _____
Alvin L. Milburn
#92-1409