

THRIFTY OIL CO.

January 31, 1995

Alameda County Health Agency
80 Swan Way Room 200
Oakland, CA 94621
Attn: Div. Of Hazardous Materials
Dept. Of Environmental Health

Re: **THRIFTY OIL CO. #063**
6125 Telegraph Ave.
Oakland, CA 94609

Dear Sir/Madam;

Enclosed please find our 06/09/94 test results for the following;

- Tank Integrity
- Hydrostatic Line Test
- Leak Detector (Mechanical)
- Electronic Monitoring
- Meter Calibration

If you have any further questions or concerns, please contact me at (310)923-5196.
Thank you.

Yours truly,



Lori Freshour
Environmental Compliance Department



Champion Precision
Tank Testing
License #73848

P.O. Box 13059
Sacramento, Ca. 95813-3059
(916) 927-1557
(800) 660-9443 Ca.
(800) 949-9443 Nv.
(916) 927-7345 FAX

Alameda Cuntly Haz. Materials
Attn: Kevin Tinsley
80 Swan Way Room #200
Oakland, Calif. 94621

Date: 6-28-94

Company: Thrifty Oil # 63
Storage Tank Location: 6125 Telegraph
Oakland, Calif.
Test Date: 6-9-94
Inv#: 4316

Dear Mr. Tinsley,

Enclosed with this letter are the completed Tank Testing results for the Location above.

Should you have any questions or concerns, then please call the office for assistance.

Sincerely Yours,

Chet Champion

Chet Champion
CC:pg



Champion
Precision Tank Testing
License No. 73848

P.O. Box 13059
Sacramento, CA 95813-3059
CA 800-660-9443
NEV 800-949-9443
(916) 927-1557
Fax: (916) 927-7345

DATE: 6-9-94
OPERATOR: THRIFTY DL
LOCATION: 6125 TELEGRAPH
OAKLAND CA

PRECISION LEAK DETECTOR TEST: F.T.A.

XLD P/N 116036-5
DLD P/N 116017-5

XLP P/N 116035-5
PLD P/N 116030-5

BFLD (XL MODEL) P/N 116039-5
BFLD P/N 116012-5

DIRECTION: _____

PRODUCT	SERIAL NUMBER	RESILIENCY	OPENING TIME	TEST LEAK RATE	FUNCTIONAL ELEMENT HOLDING P.S.I.	METERING P.S.I.	PASS	FAIL
UNLEADED:	116-035	350	5		17			✓
	10394-2615							
MID GRADE:	116-017	75	2	105%	14	5	✓	
	21001-3102							
PREMIUM:	116-017	75	2	103%	14	9	✓	
	21000-0111							
DIESEL:								

COMMENT'S: TESTED WITH ON ...
BY DIESEL ...
ONLY DIE ...

TECHNICIAN: [Signature]

CERTIFICATION #: 92-1009



Champion
Precision Tank Testing
License No. 73848

P.O. Box 13059

Sacramento, CA 95813-3059

CA 800-660-9443

NEV 800-949-9443

(916) 927-1557

Fax: (916) 927-7345

DATE: 6-22-94
OPERATOR: THIRTY OIL #63
LOCATION: 6125 TELESLAPP AVE
OAKLAND CA
PHONE #: _____

SERVICE INFORMATION FORM:

REQUESTED BY: THIRTY OIL #63 WORK ORDER #: _____

PROBLEM REPORTED: Replace + Test leak Detector on unlead Tank

MATERIALS USED ON JOB SITE: _____

CORRECTIVE ACTION PERFORMED: Checked unlead leak Detector AND TESTED IT, LEAK DETECTOR WAS ALREADY REPLACED

ODOMETER BEGINING: 40759
ODOMETER ENDING: 40763
TOTAL MILEAGE: 4

DEPARTURE TIME: 1400
ARRIVE AT JOB SITE: 1410
DEPART FROM JOB SITE: 1430
RETURN TIME TO OFFICE: _____
TOTAL TIME: 1/2

TECHNICIAN: [Signature]
DATE: 6-22-94

ACKNOWLEDGED BY: [Signature]
DATE: 6-22-94



Champion
Precision Tank Testing
License No. 73848

P.O. Box 13059
Sacramento, CA 95813-3059
CA 800-660-9443
NEV 800-949-9443
(916) 927-1557
Fax: (916) 927-7345

DATE: 6-22-94
OPERATOR: THURTY OIL # 63
LOCATION: 6125 TELEGRAPH PK
OAKLAND CA

PRECISION LEAK DETECTOR TEST: F.T.A.

XLD P/N 116036-5
DLD P/N 116017-5

XLP P/N 116035-5
PLD P/N 116030-5

BFLD (XL MODEL) P/N 116039-5
BFLD P/N 116012-5

DIRECTION: _____

PRODUCT	SERIAL NUMBER	RESILIENCY	OPENING TIME	TEST LEAK RATE	FUNCTIONAL ELEMENT HOLDING P.S.I.	METERING P.S.I.	PASS	FAIL
UNLEADED:	<u>10394 8613</u>	<u>OK</u>	<u>2.5 sec</u>	<u>36PPH</u>		<u>30</u>	<u>P</u>	
MID GRADE:								
PREMIUM:								
DIESEL:								

COMMENT'S: _____

TECHNICIAN: [Signature]

CERTIFICATION #: 01569