

THRIFTY OIL CO.

August 25, 1994

Alameda County Health Agency
80 Swan Way Room 200
Oakland, CA 94621
Attn: Div. of Hazardous Materials
Dept. of Environmental Health

Re: **THRIFTY OIL CO. #063**
6125 Telegraph Ave.
Oakland, CA 94609


Dear Sir/Madam;

Enclosed please find our test results for the following;

- Tank Integrity
- Hydrostatic Line Test
- Leak Detector (Mechanical)
- Electronic Monitoring
- Meter Calibration

If you have any further questions or concerns, please contact me at
(310)923-5196. Thank you.

Yours truly,



Lori Freshour
Environmental Compliance Department



Champion Precision
Tank Testing
License #73848

P.O. Box 13059
Sacramento, Ca. 95813-3059
(916) 927-1557
(800) 660-9443 Ca.
(800) 949-9443 Nv.
(916) 927-7345 FAX

Alameda Cuntly Haz. Materials
Attn: Kevin Tinsley
80 Swan Way Room #200
Oakland, Calif. 94621

Date: 6-28-94

Company: Thrifty Oil # 63
Storage Tank Location: 6125 Telegraph
Oakland, Calif.
Test Date: 6-9-94
Inv#: 4316

Dear Mr. Tinsley,

Enclosed with this letter are the completed Tank Testing results for the Location above.

Should you have any questions or concerns, then please call the office for assistance.

Sincerely Yours,



Chet Champion
CC:pg



Champion
Precision Tank Testing
License No. 73848

P.O. Box 13059
Sacramento, CA 95813-3059
CA 800-660-9443
NEV 800-949-9443
(916) 927-1557
Fax: (916) 927-7345

DATE: 6-9-94
OPERATOR: THRIFTY FAL
LOCATION: 6125 TELEGRAPH
OAKLAND CA.

PRECISION LEAK DETECTOR TEST: F.T.A.

XLD P/N 116036-5
DLD P/N 116017-5

XLP P/N 116035-5
PLD P/N 116030-5

BFLD (XL MODEL) P/N 116039-5
BFLD P/N 116012-5

DIRECTION: _____

PRODUCT	SERIAL NUMBER	RESILIENCY	OPENING TIME	TEST LEAK RATE	FUNCTIONAL ELEMENT HOLDING P.S.I.	METERING P.S.I.	PASS	FAIL
UNLEADED:	116-035	350	5		17			✓
	10394-2615							
MID GRADE:	116-017	75	2	100%	14	5	✓	
	21102-2502							
PREMIUM:	116-017	75	2	100%	14	9	✓	
	30190-0111							
DIESEL:								

COMMENTS: TURNED OFF ON 11/10/94
BY ITSELF FIRST TIME
ON/OFF 3000 BY PRESS

TECHNICIAN: [Signature]

CERTIFICATION #: 92-1509



Champion
Precision Tank Testing
License No. 73848

P.O. Box 13059

Sacramento, CA 95813-3059

CA 800-660-9443

NEV 800-949-9443

(916) 927-1557

Fax: (916) 927-7345

DATE: 6-22-94
OPERATOR: THIETZ oil #63
LOCATION: 6125 Telegraph Ave
OAKLAND CA
PHONE #: _____

SERVICE INFORMATION FORM:

REQUESTED BY: THIETZ oil #63 WORK ORDER #: _____

PROBLEM REPORTED: Replace + Test Leak Detector on unlead Tank

MATERIALS USED ON JOB SITE: _____

CORRECTIVE ACTION PERFORMED: Checked unlead leak detector tank
Tested IT, Leak Detector was Already Replaced

ODOMETER BEGINING: 40759
ODOMETER ENDING: 40763
TOTAL MILEAGE: 4

DEPARTURE TIME: 1400
ARRIVE AT JOB SITE: 1410
DEPART FROM JOB SITE: 1430
RETURN TIME TO OFFICE: _____
TOTAL TIME: 1/2

TECHNICIAN: [Signature]
DATE: 6-22-94

ACKNOWLEDGED BY: [Signature]
DATE: 6-22-94



Champion
 Precision Tank Testing
 License No. 73848

P.O. Box 13059
 Sacramento, CA 95813-3059
 CA 800-660-9443
 NEV 800-949-9443
 (916) 927-1557
 Fax: (916) 927-7345

DATE: 6-22-94
 OPERATOR: THIERRY O'NEILL # 63
 LOCATION: 6125 TELEGRAPH AV
OAKLAND CA

PRECISION LEAK DETECTOR TEST: F.T.A.

XLD P/N 116036-5 XLP P/N 116035-5 BFLD (XL MODEL) P/N 116039-5
 DLD P/N 116017-5 PLD P/N 116030-5 BFLD P/N 116012-5

DIRECTION: _____

PRODUCT	SERIAL NUMBER	RESILIENCY	OPENING TIME	TEST LEAK RATE	FUNCTIONAL ELEMENT HOLDING P.S.I.	METERING P.S.I.	PASS	FAIL
UNLEADED:	10394 8615	OK	2.9ec	36PPH		30	<input checked="" type="checkbox"/>	<input type="checkbox"/>
MID GRADE:							<input type="checkbox"/>	<input type="checkbox"/>
PREMIUM:							<input type="checkbox"/>	<input type="checkbox"/>
DIESEL:							<input type="checkbox"/>	<input type="checkbox"/>

COMMENT'S: _____

TECHNICIAN: *Thierry O'Neill*

CERTIFICATION #: 01509