

Detterman, Mark, Env. Health

From: Detterman, Mark, Env. Health
Sent: Wednesday, July 11, 2012 10:32 AM
To: Plunkett, Steven, Env. Health; Hugo, Susan, Env. Health
Cc: Weston, Robert, Env. Health; Drogos, Donna, Env. Health
Subject: Free-Phase Memo for Chevron 9-0504 (15900 Hesperian Blvd, San Lorenzo, RO 7)
Attachments: RO7_Memo_2012-07-11.pdf

For your files regarding the recent discovery of the first discovery of free-phase at this site. This appears to be a new release. We'll be requesting recovery actions and thought it appropriate to notify CUPA for any appropriate tank system inspections or testing warranted at the site.

Mark Detterman
Senior Hazardous Materials Specialist, PG, CEG
Alameda County Environmental Health
1131 Harbor Bay Parkway
Alameda, CA 94502
Direct: 510.567.6876
Fax: 510.337.9335
Email: mark.detterman@acgov.org

PDF copies of case files can be downloaded at:

<http://www.acgov.org/aceh/lop/ust.htm>

ALAMEDA COUNTY ENVIRONMENTAL HEALTH DEPARTMENT
LOCAL OVERSIGHT PROGRAM

MEMORANDUM

DATE: July 11, 2012


TO: Susan Hugo, CUPA Program Manager
Steven Plunkett, Hazardous Materials Specialist, Alameda County CUPA

CC: Robert Weston, CUPA, Senior Hazardous Materials Specialist
Donna Drogos, Division Chief

FROM: Mark Detterman, Senior Hazardous Materials Specialist

SUBJECT: Report of Separate-Phase Hydrocarbons
Groundwater Monitoring Well C-2
Chevron Station #9-0504; 15900 Hesperian Blvd, San Lorenzo, CA

NOTES: The May 15, 2012 document entitled *2012 Groundwater Annual Groundwater Monitoring Report* reports the presence of 0.30 feet of separate-phase hydrocarbons in well C-2 at this site. Although groundwater has previously been contaminated, free-phase has not been present previously at the site. Consequently this appears to be a new release and it appears appropriate to conduct tank system tightness tests. Please refer to the attached site plan / potentiometric map for the location of the well (immediately downgradient of the UST basin). It is reported to be light brown in color. Please also provide ACEH LOP with copies of the resulting UST system inspection tests / reports for our files. Should you have questions, please let me know.



SOURCE: DELTA ENVIRONMENTAL CONSULTANTS, INC.

611641-2011(007)GN-EM002 APR 26/2012

ALAMEDA COUNTY ENVIRONMENTAL HEALTH DEPARTMENT
LOCAL OVERSIGHT PROGRAM

MEMORANDUM

DATE: July 11, 2012


TO: Susan Hugo, CUPA Program Manager
Steven Plunkett, Hazardous Materials Specialist, Alameda County CUPA

CC: Robert Weston, CUPA, Senior Hazardous Materials Specialist
Donna Drogos, Division Chief

FROM: Mark Detterman, Senior Hazardous Materials Specialist

SUBJECT: Report of Separate-Phase Hydrocarbons
Groundwater Monitoring Well C-2
Chevron Station #9-0504; 15900 Hesperian Blvd, San Lorenzo, CA

NOTES: The May 15, 2012 document entitled *2012 Groundwater Annual Groundwater Monitoring Report* reports the presence of 0.30 feet of separate-phase hydrocarbons in well C-2 at this site. Although groundwater has previously been contaminated, free-phase has not been present previously at the site. Consequently this appears to be a new release and it appears appropriate to conduct tank system tightness tests. Please refer to the attached site plan / potentiometric map for the location of the well (immediately downgradient of the UST basin). It is reported to be light brown in color. Please also provide ACEH LOP with copies of the resulting UST system inspection tests / reports for our files. Should you have questions, please let me know.



SOURCE: DELTA ENVIRONMENTAL CONSULTANTS, INC.