

REMARKS	
Date	By
2-2	JE
	Sp w/ J. Amdur.
	They have 2 gasoline USTs in another area onsite. They may be up for removal soon.
2-21	
	Sp w/ Borrego. Tank report being written.
	No Only 1 round gw sample bec MW's are planned.
2-14-94	JE
	Reviewed Jan 94 "UST Removal + Soil Ex" report by Uribe. Don't have ULR, tank manifest. SP status?
2-15-	JE
	Met w/ J. Amdur. The remaining 2 USTs will be removed or temp. closed at some pt. They're ~1000 gal. MW inst. report up to me this week.

REMARKS	
Date	By
	They propose 1 MW bec. gradient at adj. Maersk site is well doc. as towards the Bay. Sounds ok. Paul has Maersk reports.
3-10	JE
	Reviewed Feb 94 wpt by Uribe for only 1 MW.
3-14	JE
	Reviewed Mobil file for gradient. NW on 12-7-93, W on 8-31-93. Previous ORs are missing. Ashland was SW on 12-10-92, + May + July 89.

FILE OR ENVELOPE
 PER NO. Demand No. of Ben
 OWNER Transbay Co.
 Address 707 Ferry St
 Phone 94667
 Contractor Kameon
 Address PO Box 1026
 Sacramento Phone 916-372-7535
 OTHER (Specify) Uribe 832-2233
 Address Jon Andrus 572-1184
 Phone
 CONTACT FOR INVESTIGATION
 XR Susa Gates 272-1118

PLANS
 Rec'd. By Date
 Plans Rec'd.
 Rejected
 Applicant Notified
 Plans Returned 35
 Permit Issue 6-24-96
 CONSTRUCTION PROGRESS ACCEPTANCE
 Pre-Plaster/drywall JE
 Pre-Final
 Final

By Date
 Pre-Concrete/Gunite
 Pre-Plaster
 Final
 EXCAVATION
 Septic Tank
 Absorption Field
 House Sewer
 FINAL
 Septic Tank
 Absorption Field
 Absorption Bed
 OTHER
 U.G. TANKS
 Pre-covering
 Final

LOSD
RO33
A →
10,000-gal diesel UST

Date	By	REMARKS
12-3	JE	tank removal.
12-15		Sp w/J. Borrego. Asked for results. Up to 50,000 ppb TPHd in water. Soil below dispenser had 4200 ppm kerosene, then 18 ppm diesel.
		Wrote NOR
12-20	JE	Reviewed lab results. Mostly a gw problem. Sp w/J. Andrus, then Bobbie tank inst. at Kameon. Ready for
10-7-93	JE	Is this aka Maersk Terminal? no. but there's a bldg on 1 side + a Transstainer run made of concrete on 2 sides of UST. Reviewed plan. Spoke w/Bobbie re map + insurance cert.
10-15	JE	Rec'd map + insurance cert. (exp 10-1-93). Mail app. to her.

LOCATION
 Vicinity Map
 STID 3982
 704521
 \$483⁰⁰
 10-5-93
 1^o line inspection Wed
 2^o " " Thurs

707 Ferry St
 Oakland CA 94607
 TRANSBAY CONTAINER
 3982