

(510) 429-8088
(800) 523-8088
FAX (510) 429-8089

Of Northern California, Inc.

FROM: TANK PROTECT ENGINEERING

DATE: May 5, 1993

TO: ACHA

ATTN: Jennifer Eberle

RE: Lab results

105 Jackson Street, Oakland, CA

NO. OF PAGES: 3

(Include cover sheet)

If all pages are not received please notify sender.

MESSAGE:

For your review and response.

ok to backfill

Laboratory Report

S&W
Soil and Water
Environmental
Laboratory

Drinking Water
 Waste Water • Asbestos
 Hazardous Waste – Soil
 Calderon Testing – Air

14072 W. Park Avenue
 Boulder Creek, CA 95006
 (408) 338-3053

Client **Tank Protect Engineering** Report Date **05/01/93**
2821 Whipple Rd.
Union City CA 94587


Sample Site **United Beverage Dist.** Date Received **04/28/93**
105 Jackson St.
Oakland
859-042793

Analysis Requested **Total Hydrocarbons – Gas** Procedure **EPA 5020** Date Analyzed **04/29/93**
BTEX **EPA 8020**

S&W Ref. #	Client Ref. #	Matrix/Analysis	Concentration	Detection Limit
1183-TP1-A	S-1	Soil/TPH-B	1.0	1 ppm
1183-TP1-A	S-1	Soil/BTEX		
		Benzene	*	5 ppb
		Toluene	*	5 ppb
		Ethylbenzene	*	5 ppb
		Xylenes	*	5 ppb
<i>3.5' bgs</i>				
1183-TP1-B	S-2	Soil/TPH-B	*	1 ppm
1183-TP1-B	S-2	Soil/BTEX		
		Benzene	*	5 ppb
		Toluene	*	5 ppb
		Ethylbenzene	*	5 ppb
		Xylenes	*	5 ppb
<i>6.5' bgs</i>				
1183-TP1-C	SP -1A-D	Soil/TPH-B	2.0	1 ppm
1183-TP1-C	SP -1A-D	Soil/BTEX		
		Benzene	*	5 ppb
		Toluene	*	5 ppb
		Ethylbenzene	*	5 ppb
		Xylenes	*	5 ppb

* No detectable amount @ detection limit

Analyst Signature



911 P03 MAY 05 '93 10:31



TANK PROTECT ENGINEERING

2021 WHIPPLE ROAD
 UNION CITY, CA 94587
 (415) 429-8088
 (800) 523-8088
 FAX (415) 429-8089

1183-TP1

LAB: _____

TURNAROUND: _____

P.O. #: 571

PAGE 1 OF 1

CHAIN OF CUSTODY

PROJECT NO. 239-042793		SITE NAME & ADDRESS UNITED PROSTATE DISTRIBUTORS 105 JACKSON ST OAKLAND				(1) TYPE OF CONTAINER	ANALYTES REQUESTED TOTAL LIGHT BC AROMATIC BC TOTAL HEAVY BC OIL & GREASE PVC SCAN (2000) OTHER TANK LEAKS	REMARKS	
SAMPLER NAME, ADDRESS AND TELEPHONE NUMBER LOUIS TRAMS, INC. 2021 WHIPPLE ROAD, UNION CITY, CA 94587 (415) 429-8088									
ID NO.	DATE	TIME	SOIL	WATER	SAMPLING LOCATION				
S-1	4/2/93		✓		S-1 @	DRAIN TUBE	A		
S-2							B		
SP-1A		3:00			SP-1A @ 10-15' (STORAGE)		COMPOSITE } C		
SP-1B		3:10			SP-1B @ 10-15' (STORAGE)				
SP-1C		3:20			SP-1C @ 20-25' (STORAGE)				
SP-1D		3:25			SP-1D @ 20-25' (STORAGE)				
Relinquished by: (Signature)		Date / Time		Received by: (Signature)		Date / Time		Received by: (Signature)	
Relinquished by: (Signature)		Date / Time		Received by: (Signature)		Date / Time		Received by: (Signature)	
Relinquished by: (Signature)		Date / Time		Received for Laboratory by: (Signature)		Date / Time		Remarks	

DATE: _____