

R.S. EAGAN & CO.

General Contractors
General Engineering, Process Piping & Electrical



LIC. # 476428

150-K MASON CIRCLE
CONCORD, CA 94520
(415) 682-3636

*JG
file UG TANKS*

May 14, 1987

Alameda County Health Agency
470 27th Street Room 324
Oakland, Ca. 94612

Attention: Mr. T. M. Gerow

Subject: Roadway Express, 1708 Wood Street, Oakland

Gentlemen:

Enclosed herewith is a lab report furnished to us by Trace Analysis Laboratory. This lab report is for soil and water samples taken at the subject project, where the 10,000 gallon gasoline tank and the 2,000 gallon motor oil tank were removed. As per your advise, we have installed a four inch monitoring well at each of these locations. For any further monitoring work required, we will advise the owner of the property of their responsibility to file a unauthorized release of product. However, we do not have the forms to do so, would you please send one of these forms to the attention of Jerry Swart, 1077 Gorge Boulevard, Akron, OH. 44309-0088.


Sincerely,

R. S. EAGAN & CO.

Robert S. Eagan, President

RSE;as

*forms already acquired
JG
no response necessary*



DATE: 4/30/87
LOG NO.: 4659
DATE SAMPLED: 3/31/87
DATE RECEIVED: 3/31/87

CUSTOMER: R. S. Eagan and Company
REQUESTER: Bob Eagan
PROJECT: Roadway Express, 1708 Wood Street, Oakland

<u>Sample Type</u>	<u>Sample</u>	<u>Volatile Hydrocarbons</u>	<u>Benzene</u>	<u>Toluene</u>	<u>Xylene</u>	<u>Oil and Grease</u>
<u>Soil</u>		<u>mg/kg</u>	<u>mg/kg</u>	<u>mg/kg</u>	<u>mg/kg</u>	<u>mg/kg</u>
	I, Fill, 10,000 gallon gas tank, 13'	< 3	< 0.02	< 0.02	< 0.02	
	II, Vent, 10,000 gallon gas tank, 13'	< 3	< 0.02	< 0.02	< 0.02	
	III, Fill, 2,000 gallon motor oil, 11'					610
	IV, Vent, 2,000 gallon motor oil, 11'					770
<u>Water</u>		<u>mg/l</u>	<u>mg/l</u>	<u>mg/l</u>	<u>mg/l</u>	<u>mg/l</u>
	Gas tank	500	< 0.07	1.3	6.7	
	Motor oil tank					21

Ronald H. Ming Chew
Supervisory Chemist




Roadway Express
1708 Wood Street
Oakland


Wood Street

18th Street

I-fill



2,000 gal motor oil



III-fill

II-vent

Campbell Street

ENVIRONMENTAL PROTECTION AGENCY
Office of Enforcement

CHAIN OF CUSTODY RECORD

PROJ. NO.		PROJECT NAME				NO. OF CON- TAINERS	REMARKS				
SAMPLERS: (Signature)		1708 Wood Street, Oakland									
STA. NO.	DATE	TIME	COMP.	GRAB	STATION LOCATION						
I-Fill	3/30/87		✓		10,000 gal gas tank	1	✓				13 ft Soil
II-Vent	"		✓		" "	1	✓				" "
III-Fill	"		✓		2,000 gal Motor Oil	1	✓				11 ft Soil
IV-Vent	"		✓		" " "	1	✓				" "
gas tank	"		✓		gas tank (10,000 gal)	2	✓				Water Samples; 2-40ml UOA
motor oil	"		✓		motor oil (2000 gal.)	1	✓				" " ; 1-500 ml
Relinquished by: (Signature)		Date / Time		Received by: (Signature)		Relinquished by: (Signature)		Date / Time		Received by: (Signature)	
Relinquished by: (Signature)		Date / Time		Received by: (Signature)		Relinquished by: (Signature)		Date / Time		Received by: (Signature)	
Relinquished by: (Signature)		Date / Time		Received for Laboratory by: (Signature)		Date / Time		Remarks			

Distribution: Original Accompanies Shipment; Copy to Coordinator Field Files