

Certified Mailer #:

April 23, 1990

*Littles*  
5YR-45T1

Mr. Kyle Christy  
Atlantic Richfield Company  
2000 Alameda de las Pulgas  
San Mateo, California 94403

Re: Five-Year Permits for Operation of Four Underground Storage  
Tanks to be Installed at ARCO Facility Number 2112, 1260 Park  
Street, Alameda, California, 94501

Dear Mr. Christy:

To obtain five-year permits for operation of the four 10,000 gallon  
underground storage tanks to be installed at ARCO Facility 2112, you  
must submit the following information to our office:

- 1) Tank and piping as-builts - submit within 30 days of tank  
installation completion;
- 2) Part B Underground storage tank permit applications - the  
ones already submitted are now either incorrect or  
incomplete. Copies of blank application forms are  
enclosed. Complete one one Part B form for each underground  
tank (a total of four Part B forms).
- 3) A written routine tank monitoring procedure per Title 23,  
Section 2632 (d)(1); and
- 4) A written response plan per Title 23, Section 2632 (d)(2).

Please note that underground storage tanks may not be used without a  
permit. Should you have any questions, please feel free to contact  
me at (415) 271-4320.

Sincerely,

Katherine Chesick,  
Senior Hazardous Materials Specialist

enclosures

cc: Mr. Steve Welge, Atlantic Richfield Company, San Mateo  
Ms. Frances Hedrick, Barghausen Consulting Engineers, Inc.  
Gil Jensen, Alameda County District Attorney, Consumer and  
Environmental Protection Division  
Rafat A. Shahid, Alameda County Environmental Health  
Department  
Files