

New Loc. 01 62

UNDERGROUND STORAGE TANK UNAUTHORIZED RELEASE (LEAK)/CONTAMINATION SITE REPORT

CALIFORNIA REGIONAL WATER

EMERGENCY  YES  NO HAS STATE OFFICE OF EMERGENCY SERVICES REPORT BEEN FILED?  YES  NO STATE TANK ID # *Sehman* *ACND 4/19*

REPORT DATE *03/31/88* LOCAL CASE # *APR 22 1988* REGIONAL BOARD CASE # \_\_\_\_\_ US EPA ID # \_\_\_\_\_

REPORTED BY: NAME OF INDIVIDUAL FILING REPORT *ALEX WOELPER* QUALIFYING CONTROL BOARD *(916) 484-6361* SIGNATURE *Walter Ben J of Brown + Caldwell as Agent to ARCO.*

REPRESENTING  LOCAL AGENCY  OTHER  OWNER/OPERATOR  REGIONAL BOARD COMPANY OR AGENCY NAME *ARCO PETROLEUM PRODUCTS CO.*

ADDRESS *2000 ALAMEDA DELAS PULGAS, SAN MATEO, CA 94403*

RESPONSIBLE PARTY: NAME *ARCO PETROLEUM PRODUCTS CO.* CONTACT PERSON *KYLE CHRISTIE* PHONE *(415) 571-2434*

ADDRESS *2000 ALAMEDA DE LAS PULGAS, SAN MATEO, CA 94403*

SITE LOCATION: FACILITY NAME (IF APPLICABLE) *ARCO STATION 374* OPERATOR *SANTOSH KUMAR SUD* PHONE *(415) 658-7508*

ADDRESS *6407 Telegraph Ave. OAKLAND, CA ALAMEDA COUNTY, 94609*

CROSS STREET \_\_\_\_\_ TYPE OF AREA  COMMERCIAL  INDUSTRIAL  RESIDENTIAL  RURAL  OTHER \_\_\_\_\_ TYPE OF BUSINESS  RETAIL FUEL STATION  UNKNOWN  OTHER \_\_\_\_\_

IMPLEMENTING AGENCIES: LOCAL AGENCY *ALAMEDA COUNTY HEALTH DPT.* AGENCY NAME \_\_\_\_\_ CONTACT PERSON *ED HOWELL* PHONE *(415) 874-7237*

REGIONAL BOARD *S.F. BAY REGIONAL WATER BOARD* CONTACT PERSON *GREG ZENTNER* PHONE *(415) 464-0804*

TSCD \_\_\_\_\_

SUBSTANCES INVOLVED: CAS # (ATTACH EXTRA SHEET IF NEEDED) \_\_\_\_\_ NAME *GASOLINE, UNLEADED* QUANTITY LOST (GALLONS) *~20 during test*

(1) \_\_\_\_\_ (2) \_\_\_\_\_

DISCOVERY/ABATEMENT: DATE DISCOVERED *02/08/88* HOW DISCOVERED  INVENTORY CONTROL  SUBSURFACE MONITORING  OTHER: *tank integrity test, annual*

DATE DISCHARGE BEGAN \_\_\_\_\_ METHOD USED TO STOP DISCHARGE (CHECK ALL THAT APPLY)  REMOVE CONTENTS  REPLACE TANK  CLOSE TANK  REPAIR TANK  REPAIR PIPING  CHANGE PROCEDURES  OTHER: *stopped pumping unleaded*

SOURCE/CAUSE: SOURCE(S) OF DISCHARGE  TANK LEAK  UNKNOWN  PIPING LEAK  OTHER (SPECIFY) \_\_\_\_\_

TANKS ONLY/CAPACITY \_\_\_\_\_ GAL CAUSE(S)  OVERFILL  CORROSION  RUPTURE/FAILURE  SPILL  UNKNOWN  OTHER \_\_\_\_\_

RESOURCES AFFECTED/AT RISK: RESOURCES AFFECTED YES NO THREATENED UNKNOWN

AIR (VAPOR)	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SOIL (VADOSE ZONE)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>
GROUNDWATER	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
SURFACE WATER OR STORM DRAIN	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
BUILDING OR UTILITY VAULT	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
OTHER (SPECIFY)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

WATER SUPPLIES AFFECTED YES NO THREATENED UN- KNOWN # OF WELLS

PUBLIC DRINKING WATER	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
PRIVATE DRINKING WATER	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
INDUSTRIAL	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
AGRICULTURAL	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____
OTHER (SPECIFY)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	_____

GROUNDWATER BASIN NAME  UNKNOWN

COMMENTS: *Test showed product line and vapor/vent line failure. Two islands in front of station have been out of service since 2/8/88. Single side-island has been placed into service 2/12/88 after repairs.*

COMPLETE AND ATTACH A CLEANUP TRACKING REPORT IF ANY CLEANUP WORK OR PLANNING HAS STARTED