



99 AUG 13 PM 3:40

August 11, 1999

Mr. Calvin N. Wong
Chief of Building Services
Community and Economic Development Agency
Engineering Services Division
250 Frank H. Ogawa Plaza, 2nd Floor
Oakland, CA 94612

Re: MONITORING WELL LOCATION
RELATING TO ENCROACHMENT PERMIT APPLICATION
The Salvation Army
810 Clay Street
Oakland, CA 94604

Dear Mr. Wong:

Per our telephone conversation, you requested that the monitoring well to be installed at this site either be moved from the sidewalk area into the street or that a skid-proof well box be installed. ASE has been unable to find any well boxes certified as skid-proof. Therefore, ASE will relocate the well into the street parking area. The revised well location is shown on the attached figure. If you have any questions or further comments or concerns, please feel free to call me at (925) 820-9391.

Respectfully submitted,

AQUA SCIENCE ENGINEERS, INC.

Robert E. Kitay, R.G., R.E.A.
Senior Geologist

cc: Mr. Larry Seto, Alameda County Health Care Services Agency, 1131
Harbor Bay Parkway, Suite 250, Alameda, CA 94502

Major Al Summerfield, The Salvation Army, 810 Clay Street, P.O. Box
12397. Oakland, CA 94604



NORTH

SCALE
1" = 30'

J & M Meats Building

Parking

SB-3

Parking

Clay Street

Sidewalk

Basement #3

SALVATION ARMY BUILDING

Adjacent Building

Basement #4

Former Gasoline Station Area

Basement #2

BH-A

SB-1

Basement #1

BH-B

Sidewalk

SB-2

Area of Attempted Borings

Eighth Street

LEGEND



Proposed Monitoring Well Location



Soil boring drilled 4/99



Hand augered soil boring drilled in basement area



Soil boring drilled 1/99

PROPOSED MONITORING WELL LOCATION MAP

THE SALVATION ARMY
810 CLAY STREET
OAKLAND, CALIFORNIA

AQUA SCIENCE ENGINEERS, INC.

FIGURE 2