

<sup>110</sup>  
P/O Mary I & Deborah A & J.L. David TFS  
7042 El Fuerte St Carlsbad CA 92009

DATE: 7/6/92  
TO : Local Oversight Program  
FROM: Belton  
SUBJ: Transfer of Eligible Oversight Case

Site name: Diablo Cellular  
Address: 106 & 110 Hegenbeyer Rd city Oak zip 94621  
Closure plan attached?  Y N DepRef remaining \$ \_\_\_\_\_  
DepRef Project # U568991 STID #(if any) None 4240  
Number of Tanks: 3 removed?  Y N Date of removal 8/21/90 & 9/15/90  
Leak Report filed?  Y N Date of Discovery 8/31/90  
Samples received?  Y N Contamination: TPHg, d, TOG  
Petroleum  Y N Types: Avgas Jet leaded unleaded Diesel  
fuel oil waste oil kerosene solvents  
Monitoring wells on site 0 Monitoring schedule? Y  N

Briefly describe the following:  
Preliminary Assessment \_\_\_\_\_  
Remedial Action \_\_\_\_\_  
Post Remedial Action Monitoring \_\_\_\_\_  
Enforcement Action \_\_\_\_\_

Comments:  
3 units removed, 8/21/90 & 9/15/90, at two locations. 2 gasoline tanks removed at 106 Heg. - found TPHg up to 190 ppm in side wall files, found up to 790 ppm in pump island and up to 980 g in a product line sample. On tank 3 found up to <sup>1300</sup> ~~2100~~ TOG, <sup>2100</sup> ~~1700~~ g & <sup>110</sup> ~~400~~ D. Also found TOG in sump removed plus 570 g, 420 p 780 TOG(Hc), plus detectable naphthalene, 2-methyl naphthalene