

CASE CLOSURE SUMMARY
Leaking Underground Fuel Storage Tank Program

I. AGENCY INFORMATION

Date: March 20, 2000

Agency name: **Alameda County-HazMat** Address: **1131 Harbor Bay Pkwy**
 City/State/Zip: **Alameda, CA 94502** Phone: **(510) 567-6700**
 Responsible staff person: **Barney Chan** Title: **Hazardous Materials Spec.**

II. CASE INFORMATION

Site facility name: **Diablo Cellular**
 Site facility address: **106-110 Hegenberger, Oakland, CA 94621**
 RB LUSTIS Case No: **N/A** Local Case No./LOP Case No.: **4240**
 URF filing date: **9/4/90** SWEEPS No: **N/A**

<u>Responsible Parties:</u>	<u>Addresses:</u>	<u>Phone Numbers:</u>
J.L. David, et al Trs. c/o Ms. Deborah David	1880 Century Park East, Suite 900, Los Angeles CA 90067	(310) 277-0200

<u>Tank No:</u>	<u>Size in gal.:</u>	<u>Contents:</u>	<u>Closed in-place or removed?:</u>	<u>Date:</u>
1	10,000	Gasoline	Removed	8/22/90
2	10,000	"	"	"
3	10,000	"	"	9/7/90

III. RELEASE AND SITE CHARACTERIZATION INFORMATION

Cause and type of release: **Unknown**
 Site characterization complete? **YES**
 Date approved by oversight agency: **1/10/96**
 Monitoring Wells installed? **Yes** Number: **4**
 Proper screened interval? gw encountered from ~14.5-19.5' bgs, but gw is **confined and rises to much shallower levels.**
 Highest GW depth below ground surface: **2.6'bgs** Lowest depth: **9.58'bgs**
 Flow direction: **South-southwest**
 Most sensitive current use: **Commercial**
 Are drinking water wells affected? **No** Aquifer name:
 Is surface water affected? **No** Nearest affected SW name: **NA**
 Off-site beneficial use impacts (addresses/locations): **None**

Report(s) on file? **YES** Where is report(s) filed? **Alameda County**
1131 Harbor Bay Pkwy
Alameda, CA 94502 and