



# PORT OF OAKLAND

May 27, 1994

Barney Chan  
Hazardous Materials Specialist  
Alameda Health Care Services Agency  
Department of Environmental Health  
80 Swan Way, Room 200  
Oakland, CA 94621

Dear Mr. Chan:

RE: Request for Tank Tightness Test Results - Oakland Airport  
Underground Storage Tank MF11, John Glenn Drive (Building M-  
104)

Please find the enclosed results of a tank integrity test that was conducted on the above-referenced underground storage tank on October 21, 1993. The results show that the tank meets the regulatory standard for tightness. If you have any questions regarding this issue, please do not hesitate to contact me at 272-1373.

Sincerely,

Patricia Murphy  
Associate Environmental Scientist

Enclosure

ALCO  
HAZMAT  
94 MAY 31 PM 2:48

Western Operations

1252 Quarry Lane  
P.O. Box 9019  
Pleasanton, CA 94566  
(510) 426-2600  
Fax (510) 426-0106

**Clayton**  
ENVIRONMENTAL  
CONSULTANTS

October 27, 1993

Mr. Dan Schoenholz  
PORT OF OAKLAND  
Environmental Department  
530 Water Street  
Oakland, CA 94607

Clayton Project No. 50767.00

Subject: Tank Integrity Testing Results

Dear Mr. Schoenholz:

Clayton Environmental Consultants, Inc. is pleased to report the results and observations of the tank integrity tests recently completed at:

Port of Oakland  
M-104 (North Field)  
Oakland, California

The tank was tested on October 21, 1993, using the Horner EZY-CHEK tank testing system.

The results of the tests are provided below.

Tank	Capacity (Gallons)	Product	Level	Results (Gal/Hr)
M-104	8,000	Diesel	High	-0.01918

\* GPH @ 95% confidence of <.1 as accepted by the State of California and the Environmental Protection Agency.

The tank was shown to be "product tight."

ENG50767-00.27

Mr. Dan Schoenholz  
Port of Oakland  
October 27, 1993

Page 2  
Clayton Project No. 50767.00

In certain jurisdictions, notification of tank test results is required within 30 days of the test. If notification is required, it is the responsibility of the tank owner to provide this information to the proper regulatory agency.

Sincerely,



Richard J. Silva  
Geologist/Environmental Technician  
Lic. #91-1437

RJS/cmh


Enclosures:

Chart Recorder Graph	1
Data Sheet	1

**CHART RECORDER GRAPH**

PORT OF OAKLAND  
M-104 - NORTH FIELD  
OAKLAND, CA

8,000 GALLON DIESEL  
STEEL 4



BR 55140  
21 1073



WELD  
OPERATIONS

WELD  
OPERATIONS

2

3

5

1


7

8

**DATA SHEET**

# DATA CHART FOR TANK SYSTEM TIGHTNESS TEST (EZY CHEK)

Time (Military)	Reading No	PRODUCT MONITORING ON LLR				TEMPERATURE COMPENSATION A				TEMPERATURE COMPENSATION B				NET VOL CHANGE		
		Start	End	+Gain -Loss	X Factor A	Start	End	+Gain -Loss	X Factor B	+Expansion -Contraction	Start	End	+Gain -Loss	X Factor B	+Expansion -Contraction	LLR
1430	1	76	76	0	.00158	0	5.784	5.787	+0.003	3.650	+0.01095					
1435	2	76	74	-2		-.00316	5.787	5.786	-.001		-.00365					-.01095
1440	3	74	71	-3		-.00474	5.786	5.785	-.001		-.00365					+0.0049
1445	4	71	69	-2		-.00316	5.785	5.784	-.001		-.00365					-.0119
1450	5	69	66	-3		-.00474	5.784	5.783	-.001		-.00365					+0.0049
1455	6	66	63	-3		-.00474	5.783	5.782	-.001		-.00365					-.00109
1500	7	63	61	-2		-.00316	5.782	5.782	0		0					-.00109
1505	8	61	58	-3		-.00474	5.782	5.781	-.001		-.00365					-.00316
1510	9	58	55	-3		-.00474	5.781	5.781	-.001		-.00365					-.00109
1515	10	55	53	-2		-.00316	5.781	5.782	-.001		-.00365					-.00425
1520	11	53	51	-2		-.00316	5.782	5.782	0		0					-.00109
1525	12	79	78	-1		-.00158	5.782	5.782	0		0					+0.0049
1530	13	78	76	-2		-.00316	5.782	5.782	0		0					-.00316
1535	14	76	74	-2		-.00316	5.782	5.782	0		0					-.00959
1540	15	74	72	-2		-.00316	5.782	5.781	-.001		-.00365					-.01275
1545	16	72	70	-2		-.00316	5.781	5.780	-.001		-.00365					+0.0049
1550	17	70	67	-3		-.00474	5.780	5.779	-.001		0					-.01177
1555	18	67	65	-2		-.00316	5.779	5.779	0		0					-.00316



- A. Tank Bot. to Grade 130 1/2"
- B. Tank Top to Grade 34"
- C. Tank Diameter 96 1/2"
- D. Test Level above grade 10"
- E. Depth of water in tank 0"
- F. Depth for taking sample 65"
- G. Temp. Probe depth (connector) 36"
- H. Test level to Tank Bot. 140"
- I. Groundwater above tank bottom 0"
- J. Product Pressure per 1" height 0.32 PSI

Test Pressure Formula

$$\frac{140 \times 0.32}{H} - \left( \frac{I}{J} \times 0.036 \right) = 4.48$$

NET TEST PRESSURE

Send Report to:  
 Client PORT OF OAKLAND  
 Address 530 WATER STREET  
 City, State OAKLAND, CALIFORNIA  
 Phone (510) 272-1220  
 Attn: MR. DAN SCHENHOLZ

CERTIFICATION This is to certify that this tank system was tested on date shown. Those indicated Tight meet the criteria established by the National Fire Protection Association Pamphlet 329.

Tank No M-104 (NORTH FIELD)  
 Tight YES  
 Leakage Indicated -0.01918  
 Technician RICHARD SILVA LIC. # 91-1437  
 Date Tested OCTOBER 21 1983