

RECEIVED

2:40 pm, Oct 02, 2008

Alameda County
Environmental Health

APPENDIX A

Tank Removal Inspection Report

OAKLAND FIRE SERVICES AGENCY/OFFICE OF EMERGENCY SERVICES HAZARDOUS MATERIALS UNIT

505 - 14th Street, Oakland, CA 94612 (510) 238-3938

HAZARDOUS MATERIALS INSPECTION REPORT

Site Number	Facility Name	Facility Address	Zip Code
	SEKHON	6600 FOOT HILL	05

Inspection Report

FINAL ON TWO 10K GAL VST -
 2.23.99 - TURNING SUMM) SENSORS OPERATIONAL
 ALARM OPERATORS - MECH FLOAT SENSORS

TLS-350 INSTALLED & OPERATIONAL

2.24 99 -
 ALL 4 DISPENSORS HAVE POSITIVE
 SHUT DOWN - ALL OPERATIONAL - MECH-FLOAT SENSORS

FINAL Insp - PASSED @ 11:00AM 2.24.99

TANKS TO GO INTO OPERATION TOMORROW

WHITMAN PETROLEUM CONTRACTOR
 ROD - BERTOLI

508 4664

Facility Contact/Print Name: Rod Bertoli	Inspected by: <input type="checkbox"/> Insp. Griffin 238-7759 <input type="checkbox"/> Insp. Johnson 238-3804 <input checked="" type="checkbox"/> Insp. Craford 238-1158 <input type="checkbox"/> Insp. Gomez 238-7253
Facility Contact/Signature: Rod Bertoli	
Date: 2.23.99 + 2.24.99	

OAKLAND FIRE SERVICES AGENCY/OFFICE OF EMERGENCY SERVICES
 HAZARDOUS MATERIALS UNIT
 505 - 14th Street, Oakland, CA 94612 (510) 238-3938

HAZARDOUS MATERIALS INSPECTION REPORT

Site Number	Facility Name	Facility Address	Zip Code
	SEKTON	6600 FOOTHILL	05

Inspection Report

PRIMARY - DOUBLE WALL FIBERGLASS - 15000

OLD SINGLE WALL FIBERGLASS - 2 X 10,000

* LEAK TEST Sumps X 2 - OK

* S PSE ON TANKS X 2 - PASSED

12 PSE ON VALVE/VENT - PASSED

SECONDARY ON THURSDAY - 11:AM

ALL PARAMETERS PASSED

SMP TEST PERFORMED

707 938-1901

Facility Contact/Print Name:

Rod Bertoli

Facility Contact/Signature:

Inspected by:

- Insp. Griffin 238-7759
- Insp. Johnson 238-3604
- Insp. Craford 238-7758
- Insp. Gomez 238-7253

Date:

2.2.99

OAKLAND FIRE SERVICES AGENCY/OFFICE OF EMERGENCY SERVICES
 HAZARDOUS MATERIALS UNIT
 505 - 14th Street, Oakland, CA 94612 (510) 238-3938

HAZARDOUS MATERIALS INSPECTION REPORT

Site Number	Facility Name	Facility Address	Zip Code
	TANK REMOVAL	6600 FEOTHILL	05

Inspection Report

OWNER - RAVI SANKHAR - 568 7664

TANK REMOVAL - ONE 9,000 GAL GASOLINE

CALIBRATED IN DECEMBER WITH
 A READING OF
 700 lbs CO₂ #1 O₂ % 10
 LEL % 1

OWNERS TRIPAL 707 838 1807

ECI ON SITE FOR REMOVAL @ 1:50 PM

GROUNDWATER @ TM + 2 FT IN PIT -
 SOME OOR + FLOABLES - SHOULD BE
 BITUMENS - STOCK PILE HAS OOR

TANK IS APPARENTLY FREE FROM ENTRAPPED - ON O FOR TRANSPORT

Facility Contact Print Name:	Inspected by: <input type="checkbox"/> Insp. Griffin 238-7759 <input type="checkbox"/> Insp. Johnson 238-3804 <input checked="" type="checkbox"/> Insp. Craford 238-7758 <input type="checkbox"/> Insp. Gomez 238-7253
Facility Contact Signature:	
Date: 12-15-98	