

20179

UNDERGROUND STORAGE TANK UNAUTHORIZED RELEASE (LEAK) / CONTAMINATION SITE REPORT

EMERGENCY YES NO HAS STATE OFFICE OF EMERGENCY SERVICES REPORT BEEN FILED? YES NO

FOR LOCAL AGENCY USE ONLY
 I HEREBY CERTIFY THAT I HAVE DISTRIBUTED THIS INFORMATION ACCORDING TO THE DISTRIBUTION SHOWN ON THE INSTRUCTION SHEET ON THE BACK PAGE OF THIS FORM.
 SIGNED: Robert Weston DATE: 5-11-00

REPORT DATE: 05/11/00 CASE #

REPORTED BY: NAME OF INDIVIDUAL FILING REPORT: ROBERT WESTON PHONE: (510) 5676781 SIGNATURE: Robert Weston
 REPRESENTING: LOCAL AGENCY OWNER/OPERATOR REGIONAL BOARD OTHER COMPANY OR AGENCY NAME: COUNTY OF ALAMEDA
 ADDRESS: 1131 HARBOR BAY PARKWAY

RESPONSIBLE PARTY: NAME: STOP N SAVE INC. CITY: ALAMEDA STATE: CA ZIP: 94502
 CONTACT PERSON: SEAN KAPOOR PHONE: 510 732-5700
 ADDRESS: 25064 VIKING STREET CITY: HAYWARD STATE: CA ZIP: 94541

SITE LOCATION: FACILITY NAME (IF APPLICABLE): STOP N SAVE OPERATOR: SEAN KAPOOR PHONE: (510) 538-5713
 ADDRESS: 2005 STOCKPILE AVENUE CITY: CASTRO VALLEY STATE: ALAMEDA ZIP: 94546
 CROSS STREET:

IMPLEMENTING AGENCIES: LOCAL AGENCY: COUNTY OF ALAMEDA AGENCY NAME: SFRWQCB CONTACT PERSON: TOM PEACOCK PHONE: (510) 567-6782
 REGIONAL BOARD: SFRWQCB CONTACT PERSON: CHUCK HEADLEE PHONE: (510) 622-

SUBSTANCES INVOLVED: (1) GASOLINE NAME: QUANTITY LOST (GALLONS): UNKNOWN

DISCOVERY/ABATEMENT: DATE DISCOVERED: 05/22/00 HOW DISCOVERED: TANK TEST TANK REMOVAL INVENTORY CONTROL SUBSURFACE MONITORING NUISANCE CONDITIONS
 DATE DISCHARGE BEGAN: UNKNOWN METHOD USED TO STOP DISCHARGE (CHECK ALL THAT APPLY): REMOVE CONTENTS CLOSE TANK & REMOVE REPAIR PIPING
 HAS DISCHARGE BEEN STOPPED? YES NO IF YES, DATE: REPAIR TANK CLOSE TANK & FILL IN PLACE CHANGE PROCEDURE
 REPLACE TANK OTHER

SOURCE/CAUSE: SOURCE OF DISCHARGE: TANK LEAK UNKNOWN PIPING LEAK OTHER CAUSE(S): OVERFILL RUPTURE/FAILURE SPILL UNKNOWN CORROSION OTHER

CASE TYPE: CHECK ONE ONLY UNDETERMINED SOL ONLY GROUNDWATER DRINKING WATER - (CHECK ONLY IF WATER WELLS HAVE ACTUALLY BEEN AFFECTED)

CURRENT STATUS: CHECK ONE ONLY NO ACTION TAKEN PRELIMINARY SITE ASSESSMENT WORKPLAN SUBMITTED POLLUTION CHARACTERIZATION
 LEAK BEING CONFIRMED PRELIMINARY SITE ASSESSMENT UNDERWAY POST CLEANUP MONITORING IN PROGRESS
 REMEDIATION PLAN CASE CLOSED (CLEANUP COMPLETED OR UNNECESSARY) CLEANUP UNDERWAY

REMEDIAL ACTION: CHECK APPROPRIATE ACTION(S) (SEE BACK FOR DETAILS) EXCAVATE & DISPOSE (ED) REMOVE FREE PRODUCT (FP) ENHANCED BIO DEGRADATION (IT)
 CAP SITE (CD) EXCAVATE & TREAT (ET) PUMP & TREAT GROUNDWATER (GT) REPLACE SUPPLY (RS)
 CONTAINMENT BARRIER (CB) NO ACTION REQUIRED (NA) TREATMENT AT HOOKUP (HU) VENT SOIL (VS)
 VACUUM EXTRACT (VE) OTHER (OT)

COMMENTS: STOCKPILE CONTAINS 1100 PPM TPHG 4 PPM BENZENE 12 PPM MTBE NATIVE 3.8 MTBE PPM