

## Wickham, Jerry, Env. Health

---

**From:** Winey, Colleen [cwiney@zone7water.com]  
**Sent:** Wednesday, March 28, 2012 5:46 PM  
**To:** Wickham, Jerry, Env. Health  
**Subject:** Arco Station #00771, RO 200

Hi Jerry,

The Arco Station on Rincon in Livermore (RO 200) is classified as a high priority case by Zone 7's ranking system. The site has detected benzene and MTBE in groundwater well above their respective MCLs and in addition, the site is within 2,000 feet of an active municipal supply well. The RP for this case submitted a Case Evaluation and Justification for No Further Action to ACEH on January 5, 2012. In the letter they state that the closest active wells are 2,300 feet away. However, California Water Service actually has an active municipal supply well located approximately 850 feet to the northeast. Based on the levels of benzene still present in the groundwater (up to 15,000 ug/L) and the close proximity to an active municipal supply well (850 feet), Zone 7 would be opposed to closing this case at this time. If you have any questions or would like to discuss this further please feel free to contact me.

Thanks,  
Colleen

Colleen Winey, PG  
Zone 7 Water Agency  
100 North Canyons Parkway  
Livermore, CA 94551  
925-454-5063  
925-454-5727 fax