

Civil Engineering Unit Oakland United States Coast Guard 2000 Embarcadero, Suite 200 Oakland, CA 94606-5337 Staff Symbol: evd

PROTECTION FAX: 510-535-7288

98 NOV -9 PH 4: 5090

November 4, 1998

Mr. Larry Seto Alameda County Environmental Health Services 1131 Harbor Bay Parkway, Suite 250 Alameda, CA 94502

Dear Mr. Seto:

Enclosure (1) is a copy of the air sample collected from building 15. The sample was collected on 24 September in accordance with protocol NIOSH 1501. No benzene was detected in the shop workspace above the closed-in-place underground storage tank.

This analysis demonstrates there is no contaminant pathway from the small amount of benzene remaining in the subsurface. Consequently, there is no risk to human health. As we previously discussed, the extent of the benzene plume in groundwater has been characterized and does not pose a threat to the environment. We believe no further action is either necessary or warranted at this site and request your concurrence on closure.

For questions regarding this or other issues related to the site, please contact Mr. Joseph Sabel at 510-535-7239. Fax transmissions may be sent to 510-535-7288. Electronic mail may be sent to jsabel@d11.uscg.mil.

Sincerely,

DAVE STALTERS

Chief, Environmental Division

U.S. Coast Guard

By direction of the Commanding Officer

Encl: (1) Lab analysis

Copy: CG MLCPAC (sa. kse)

CG ISC Alameda

Amit lab rpt



10/8/98

Submitted To: Helen Porter

USCG MLCPAC

Coast Guard Island, Bldg. 54-B

Alameda, CA 94501-5100

Reference Data:

Benzene

Sample Location: ISC Alameda Bldg. 15

Sample Type: Charcoal tube

Client Sample No.: IHEH002 through IHEH006

PO #: 32-75232-2L003

Method Reference: NIOSH 1501 Sample Set ID#: 98-C-6308

DATACHEM Lab No.: 98-38880 through 98-38884

Date Submitted: 10/5/98 Preparation Date: 10/7/98 Analysis Date: 10/7/98

The samples were prepared by desorption in carbon disulfide.

The analysis was performed on a Hewlett Packard 5890 gas chromatograph equipped with a flame ionization detector and a Nukol capillary column with temperature programming from 40°C to 150°C.

The results are provided in the enclosed data table.

Tai V. Nguyen

Analyst

James K. Baxter Laboratory Director

SALT LAKE CITY OFFICE 960 MEST LeVOY DRIVE SALT LAKE CITY UTAH 84123-2547 801 266-7700 FAX 801 268-9992

CINCINNATI OFFICE 4088 GLENDALE-MILFORD ROAD CINC NNATI CHIO 45242 3706 513 733-5336 FAX 513 733-5347

MARYLAND OFFICE 17824 MACDUFF AVENUE OUNEY MARYLAND 20802 301 924-1967 FAX 301 924-1981

LEADING ANALYTICAL CHEMISTRY INTO THE 21ST CENTURYSK

4 - 6 - 1 - 1 - 1 - 1 - 1 - 1 



Sample Set ID: 98-C-6308

## Data Table

## Benzene

Client #	DCL #	Air sampling Volume, L	μg/sample	ppm
IHEH002	98-38880	84	ND	<0.0037
IHEH003	98-38881	83	ND	<0.0038
IHEH004	98-38882	83	ND	<0.0038
IHEH005	98-38883	83	ND	<0.0038
IHEH006	98-38884	-0-	ND	n/a
	Limit of detection		1.	

ND - Below the reported detection limit. n/a Not Applicable.

Tai V. Nguyen

Taillalle

Analyst

James K. Baxter

Laboratory Director



To: INDUSTRIAL HYGIENE AIR SAMPLE SURVEY FORM المحالات المناس Survey#: -UIC: Element #: BIDG 15 FE 180 Hlamede Geographic Unit Location Sample Class: Air Sample Stressor Summary 2 Computer Page benteen Sample Coll. Type AIG Name N/A SSN/Badge # Operation Code NA NB-NB AK Respirator NA Code PPE Code(s) BENZENE Stressor 98018305 <del>98 NB 30</del>3 9<del>8DPB364</del> 98088302 Sample # 48D1B301 IHEH OOG THEH OCOY 2000 AB 43 MENGOOZ. IMEHOOO3 Laboratory # DEFICE CLAKES Asistedanba Location/Mode 4241 N/Y} ムネオー 424 Duration 729min NIF 196 mlom 195 195 196. Flow Rate MA Volume 1003 ± NA (0,0038 ppm 2010038ppn 20,00 38ppm Results/Units **Exposure Summary** Result Type Results/Units Product Used: Sue Similarly Exposed Employees: ☐ Yes ☐ No \_\_\_\_\_ Date Reported: \_\_ Date Received:\_\_\_\_\_ Limit of Detection: ~ La.6038 -12pm Analytical Method Used: 1501 Analysis Performed By: Data Clery

NOHIMS S2B (2/91)

- કેંગ્રહે

NOHIMS IH FORMS DEFINITIONS

Form of

100

	-Primary							
Sampling Data	Type							
Calibrator: BioS	Mfg	Dry cal	· · · · · · · · · · · · · · · · · · ·	Type	SN/Code			
Calibrated By: HP Calibration Date: Pre 205ep Post 205ep 48								
Cambiated by:	1 .	2	3	4	5			
Pump Mfg -	SKC	SKC	SKS_	skc '	ske NA			
Pump Model	210-1601	210-1001	210-1601	210-1001	NA			
Pump Type	LowFlow	Lowflew	Lowflow	rongian	N/A Blank			
Pump SN/Code	6984	6959	<del>964</del> 697	T-				
Pre-Cal Flow Rate	1917.1 ml/a	195.9 ml/n		T	1 1			
Post-Cal Flow Rate	195.4-ml	194. 4 my		193.8 m/m	N/A			
Lowest Flow Rate	196 my	- 195 ml/g	196 ml/m	195 ml/m	1 N/A 14			
Field Sample #	98018301"	28 DPB302	THEH OME	ł	THEHOOGO			
Media **	THEH COOZ	Charcoat	Chascoal	CECTOCA	charcoal			
Lot/Tube #	*2000 SXC	2000 SKC	2000 SEC	ZOOO SKC	2000 SKC			
Expiration Date		1	11/1-7	1448	1			
Time Off	1445	1446	1447	<del> </del>	NIA			
Time On	0736	0739	0741	0744	10/1)			
Pump Check(s)				Postcul				
Calculations:  Cal Ave., On Post Col 1984 (959) (973) (964) (965) (973) (974) (975) (975) (976)								
IN H. POFLER CDR Bleider LT is Hers HT								

\*BY MY SIGNATURE, I VERIFY THAT I HAVE REVIEWED THIS FORM FOR COMPLETENESS AND ACCURACY AND THAT THE WORK DOCUMENTED HEREIN WAS CONDUCTED AND RECORDED IN ACCORDANCE WITH NAVY INSTRUCTIONS, FEDERAL REGULATIONS, AND/OR ACCEPTED INDUSTRIAL HYGIENE PROCEDURES