



FACSIMILE COVER SHEET

CHEVRON U.S.A. PRODUCTS COMPANY
MARKETING - NORTHWEST REGION

Mailing Address : Chevron U.S.A. Products Company
P.O. Box 5004
San Ramon, CA 94583-0804

Date: <u>5-8-96</u>		Fax Number: <u>510 337 9335</u>	
To: <u>JENNIFER EBERLE ACHCS</u>			
From:	Phone Number	Room / Building	
<u>PHIL BRIGGS</u>	<u>510 842 9136</u>		
Subject: <u>SIR REPORTS FOR 90121 3026 LAKE SHORES AVE, OAKLAND</u>			
<p>Remarks: <u>FOR YOUR REQUEST, I AM ENCLISING THE SIR REPORTS FOR JAN, FEB, MAR OF 1996 AT THIS STATION. ALL TANKS/LINES TESTED THAT IN THAT PERIOD.</u></p> <p><u>FIRST QUARTER MONITORING REPORT WILL BE FORTHCOMING SHORTLY.</u></p>			

Number of Pages Including Cover Sheet 4

To Reply By Facsimile - Dial (510) 842-8932

USTMAN SIR SYSTEM
Monthly Statistical Inventory Reconciliation (SIR) Report

STATION NAME: CSI	STATION #: 90121
COMPANY NAME: CHEVRON-NORTHWEST REGION	AREA 4
ADDRESS: 3026 LAKESHORE AVENUE	
CITY: OAKLAND	ZIP: 94610
STATE: CA	PHONE: 510/839-3251
COUNTY: ALAMEDA	
PERIOD ANALYZED: MARCH, 1996	
DATE OF REPORT: 04/18/96	

PART A:

Tank ID:	Tank and Lines Status:	Product:	Data		
			Quality:	Dels:	Sales:
D	TIGHT	D	GOOD	12733	12435
P	TIGHT	P	FAIR	56557	54900
S	TIGHT	S	GOOD	63550	62455
UL	TIGHT	UL	FAIR	110347	109093

USTMAN INDUSTRIES INC. is a certified Statistical Inventory Reconciliation (SIR) release detection vendor. Tank status results for monthly monitoring are based on parameters specified by the EPA protocol for SIR methods.

PART B:

O/S listed below represent removals, additions or delivery discrepancies which were accounted for as part of the SIR analysis.

Tank ID: Comments and Recommendations:

D	{3/3/1996:DEL 104}	{3/4/1996: -176}	{3/13/1996:DEL 189}
P	{3/9/1996: 248}	{3/11/1996: -119}	{3/12/1996:DEL -264}
	{3/31/1996:DEL -98}		
S	{3/11/1996: -93}	{3/17/1996:DEL 161}	{3/24/1996:DEL -150}
UL	{3/7/1996:DEL -118}	{3/8/1996:DEL -210}	{3/13/1996:DEL 261}
	{3/19/1996:DEL -97}		

USTMAN SIR SYSTEM
Monthly Statistical Inventory Reconciliation (SIR) Report

STATION NAME: APSI	STATION #: 90121
COMPANY NAME: CHEVRON-NORTHWEST REGION	AREA 4
ADDRESS: 3026 LAKESHORE AVENUE	
CITY: OAKLAND	ZIP: 94610
STATE: CA	PHONE: 510/839-3251
COUNTY: ALAMEDA	
PERIOD ANALYZED: FEBRUARY, 1996	
DATE OF REPORT: 03/21/96	

PART A:

Tank ID:	Tank and Lines Status:	Product:	Data Quality: Dels: Sales:		
D	TIGHT	D	FAIR	10481	10810
P	TIGHT	P	POOR	48626	50188
S	TIGHT	S	POOR	57844	58631
UL	TIGHT	UL	GOOD	99947	98904

USTMAN INDUSTRIES INC. is a certified Statistical Inventory Reconciliation (SIR) release detection vendor. Tank status results for monthly monitoring are based on parameters specified by the EPA protocol for SIR methods.

PART B:

O/S listed below represent removals, additions or delivery discrepancies which were accounted for as part of the SIR analysis.

Tank ID: Comments and Recommendations:

D {2/1/1996:DEL 2064} {2/10/1996: 260} {2/16/1996: -108}
 {2/17/1996: 206} {2/18/1996: -138}

P {2/21/1996:DEL -387} {2/22/1996:DEL 183} {2/23/1996:DEL 105}
 {2/27/1996:DEL -138}

S {2/2/1996:DEL -80} {2/5/1996:DEL 152} {2/17/1996: 674}
 {2/18/1996:DEL -532} {2/20/1996:DEL -115}

UL {2/7/1996:DEL -290} {2/22/1996:DEL -256}

USTMAN SIR SYSTEM
Monthly Statistical Inventory Reconciliation (SIR) Report

STATION NAME: APSI	STATION #: 90121
COMPANY NAME: CHEVRON-NORTHWEST REGION	AREA 4
ADDRESS: 3026 LAKESHORE AVENUE	
CITY: OAKLAND	ZIP: 94610
STATE: CA	PHONE: 510/839-3251
COUNTY: ALAMEDA	
PERIOD ANALYZED: JANUARY, 1996	
DATE OF REPORT: 03/06/96	

PART A:

Tank ID:	Tank and Lines Status:	Product:	Data		
			Quality:	Dele:	Sales:
D	TIGHT	D	GOOD	13447	13137
P	TIGHT	P	POOR	58303	56500
S	TIGHT	S	FAIR	64004	62956
UL	TIGHT	UL	FAIR	104453	103444

USTMAN INDUSTRIES INC. is a certified Statistical Inventory Reconciliation (SIR) release detection vendor. Tank status results for monthly monitoring are based on parameters specified by the EPA protocol for SIR methods.

PART B:

O/S listed below represent removals, additions or delivery discrepancies which were accounted for as part of the SIR analysis.

Tank ID: Comments and Recommendations:

D	{1/2/1996: -1042}	{1/11/1996: 218}	{1/19/1996: -172}
P	{1/3/1996:DEL -134}	{1/7/1996: 258}	{1/12/1996:DEL -288}
	{1/13/1996:DEL 124}	{1/29/1996:DEL 116}	
S	{1/3/1996:DEL -238}	{1/8/1996:DEL 246}	{1/12/1996:DEL -142}
	{1/29/1996:DEL 175}		
UL	{1/3/1996:DEL -168}	{1/7/1996: 104}	{1/11/1996:DEL -117}
	{1/12/1996:DEL -137}	{1/29/1996:DEL 146}	{1/31/1996: 117}

USTMAN SIR SYSTEM
Monthly Statistical Inventory Reconciliation (SIR) Report

STATION NAME: CSI #1514	STATION #: 90121
COMPANY NAME: CHEVRON-NORTHWEST REGION	AREA 5
ADDRESS: 3026 LAKESHORE AVENUE	
CITY: OAKLAND	ZIP: 94610
STATE: CA	PHONE: 510/839-3251
COUNTY: ALAMEDA	STATE ID: 5
PERIOD ANALYZED: FEBRUARY, 1997	
DATE OF REPORT: 04/11/97	

PART A:

Tank ID:	Tank & Lines Leak Status:	Rate	MDL	Product:	Capacity	Dels:	Sales:
D	NO DATA			D	10000	0	0
P	PASS	0.08	0.14	P	10000	43910	44693
S	PASS	0.05	0.15	S	10000	50526	50081
UL	PASS	-0.00	0.09	UL	10000	106631	105511

USTMAN INDUSTRIES INC. is a certified Statistical Inventory Reconciliation (SIR) release detection vendor. Tank status results for monthly monitoring are based on parameters specified by the EPA protocol for SIR methods.

PART B:

Tank ID:	Comments and Recommendations:
D	No comments.
P	No comments.
S	Tank passed based on comparison of net and gross deliveries.
UL	No comments.

04/10/1997 04:26 5108952009 BILLIE STEVENS: PAGE 08

Dealer/Co-op **SS 9-0121** Date **April 9, 1997**
 Address **3026 Lake Shore** Facility Number **SS 9-0121**
 City **OAKLAND,** State **CALIF** Zip Code _____
 We have on this date changed meter readings at the service station listed for the following reasons:
 Meter Calibration Pump Change
 Computer Change Change

Pump No.	Pump Tests				Test Gal.	Computer/Pump Change			
	Mechanical Readings		Electronic Readings			Mechanical Readings		Electronic Readings	
	Start	Stop	FAST	SLOW		Old Computer	New Computer	Old Computer	New Computer
3	0101275	0101375	+1	+1	10				
4	5670114	5670214	+2	+2	10				
7	0483570	0483670	+1	+2	10				
8	5133838	5133938	+2	+3	10				
11	2997138	2997238	+2	+3	10				
12	2540974	2541074	+2	+2	10				
15	1896337	1896437	0	+1	10				
16	9688983	9689083	+2	+3	10				
19	9701688	9701788	0	0	10				
20	7385803	7385903	+2	+2	10				

Meter Adjustment Nut Sealed Safety Impact Valve Sealed Tanks Locked Strainer Housing Cap Sealed Computer Linkage Sealed Dial Face Sealed

I (We) certify the above meter readings to be true and correct and that all product was returned to proper tank.

Repairman Signature David Stevens **DAVID STEVENS**

I confirm the above statement and certify the above meter readings.

Station Representative Signature _____

USTMAN SIR SYSTEM
Monthly Statistical Inventory Reconciliation (SIR) Report

STATION NAME: BROADWAY CHEVRON	STATION #: 92506
COMPANY NAME: CHEVRON-NORTHWEST REGION	AREA 5
ADDRESS: 2630 BROADWAY	
CITY: OAKLAND	ZIP: 94612
STATE: CA	PHONE: 510/834-6444
COUNTY: ALAMEDA	STATE ID: 5
PERIOD ANALYZED: FEBRUARY, 1997	
DATE OF REPORT: 04/11/97	

PART A:

Tank ID:	Tank & Lines Leak		MDL	Product:	Capacity Dels: Sales:		
	Status:	Rate			Capacity	Dels	Sales
P	PASS	0.04	0.12	P	10000	16373	15444
S	PASS	0.08	0.13	S	10000	23448	21837
UL	PASS	0.01	0.08	UL	10000	56482	52309

USTMAN INDUSTRIES INC. is a certified Statistical Inventory Reconciliation (SIR) release detection vendor. Tank status results for monthly monitoring are based on parameters specified by the EPA protocol for SIR methods.

PART B:

O/S listed below represent removals, additions or delivery discrepancies which were accounted for as part of the SIR analysis.

Tank ID: Comments and Recommendations:

P No comments.

S No comments.

UL Tank passed based on comparison of net and gross deliveries - loss was due to temperature.
 {2/12/1997:DEL 2999}


Totalizer Reading Changes Report

Dealer/Co-op SS 9-2506			Date April 8, 1997		We have on this date changed meter readings at the service station listed for the following reasons: <input checked="" type="checkbox"/> Meter Calibration <input type="checkbox"/> Pump Change <input type="checkbox"/> Computer Change <input type="checkbox"/> Change
Address 2630 Broadway			Facility Number SS 9-2506		
City OAKLAND	State CALIF	Zip Code			

Pump No.	Pump Tests				Test Gal.	Computer/Pump Change			
	Mechanical Readings		Electronic Readings			Mechanical Readings		Electronic Readings	
	Start	Stop	FAST	SLOW		Old Computer	New Computer	Old Computer	New Computer
1	704175	704185	+1	0	10				
2	209771	209781	-2	-4	10				
7	077607	077717	0	+1	10				
8	043188	043228	0	0		Replaced meter			
9	564363	564373	+3	+2	10				
10	537669	537679	+2	+2	10				
14	209407	209507	+3	+4	10				
15	182483	182493	+1	0	10				
16	017200	017210	+2	+1	10				
20	080081	800091	+1	+3	10				

Meter Adjustment Nut Sealed Safety Impact Valve Sealed Tanks Locked Strainer Housing Cap Sealed Computer Linkage Sealed Dial Face Sealed

I (We) certify the above meter readings to be true and correct and that all product was returned to proper tank.

Repairman Signature:  CHRIS STEVENS

I confirm the above statement and certify the above meter readings.

Station Representative Signature: _____