

Date: April 1991
Chevron Service Station No. 9-0121
3026 Lakeshore Avenue, Oakland, CA
Easting: 566320
Northing: 4183718

01

Missing 6/21/91
7/18/91
8/13/91

BRIEF HISTORY

- Tank leaks were detected in 1969.
- In 1980, the tanks were replaced. At this time, six wells were installed for product recovery.
- In July 1981, Groundwater Technology supervised the installation of four additional monitoring wells.
- A 30-inch recovery well with 24-inch casing was installed adjacent to a neighboring apartment building between December 1981 and February 1982. Separate-phase hydrocarbons were observed in this well.
- In April 1990, a total of seven monitoring wells were monitored and sampled, a total of ten monitoring wells are believed to exist on site (two could not be located, MW-F and MW-E, and one was not sampled). Groundwater analytical results of TPH-as-gasoline showed concentrations ranging from non-detectable (MW-G) to 40,000 parts per billion (MW-D). Groundwater monitoring conducted in April 1990 indicated a depth to water of 5- to 10-feet below surface grade.

WORK DONE THIS PERIOD

- All groundwater-monitoring and extraction wells were abandoned on March 27 and 28, 1991.

GROUNDWATER MONITORING

- No groundwater monitoring was conducted for this quarter.

GROUNDWATER SAMPLING


- No groundwater sampling occurred for this quarter.

PLANNED SITE ACTIVITIES

- A monitoring-well installation program is currently being developed.



GROUNDWATER
TECHNOLOGY, INC.



LEGEND
○ MONITORING WELL

PARK

MacARTHUR BLVD.

LAKE SHORE BLVD.

BEACON ST.

APPROXIMATE GROUNDWATER
FLOW DIRECTION

CHEVRON

EXCELSIOR CT.

U/G TANKS

CHEVRON U.S.A. 9-0121
OAKLAND, CALIFORNIA

SITE PLAN

0 FEET 30

