



LILJA INDUSTRIAL CONSTRUCTION CORP.

GENERAL ENGINEERING CONTRACTOR

P.O. BOX 156 SAN RAMON, CA 94583

TELEPHONE (415) 820-2399

CALIFORNIA LICENSE NO. 314629

Barber

August 7, 1986

Owens-Illinois, Inc.
3600 Alameda Avenue
Oakland, CA 94604

Attention: Ms Kathy Allen

Subject: Underground Tank Removal
Revised Quotation

Dear Kathy:

We are pleased to submit our revised lump sum quotation for the subject project of \$139,905.00.

47200 - ^{Waste} Disposal - Expense

This revision reflects the elimination of the removal of one 15,000 gal, and 2-24,000 gal diesel tanks. All other work outlined in your "Underground Tank Specifications" of June 18, and our quotation "Underground Tank Removal" of July 17 (copy attached) remains in effect.

If you have any questions, or if we can be of further assistance please advise.

Sincerely,

LILJA INDUSTRIAL CONSTRUCTION CORP.

L. L. Broline
L. L. Broline
Project Manager

LLB:lb

Expense

(1)	12,000	gal.	Kleenmold
(1)	4,000	"	gasoline
(1)	4,000	"	diesel
(1)	500	"	diesel
(1)	8,300	"	fuel oil

Capital

(1)	1,000	gasoline	underground
(1)	4,000	diesel	
(1)	8,000	fuel oil	



Enclosure 4

DATE: 7/25/86 (Partial Draft)

LOG NO.: 3865

CUSTOMER: Exceltech, Inc.
 REQUESTER: Mike Hansen
 PROJECT: No. 1467, Owens Illinois

Sample Type	Sample	Volatile Hydrocarbons	Oil & Grease	Benzene	Toluene	Xylene
<u>Soil</u>		<u>mg/kg</u>	<u>mg/kg</u>			
	B3-1		1,100			
	B3-2		440			
	B3-3	18,000	8,700			
	B3-4	1,300	1,100			
	B4-2	640	210			
	B4-4	2.8	30			
	B4-5	21	30			
	B5-1		990			
	B5-2	1,200	1,800			
	B5-3		210			
	R-1		20,000			
	R-2	1,300	3,000			
	R-3		840			
	R-4		20,000			
	R-5		56,000			
<u>Water</u>		<u>mg/l</u>	<u>mg/l</u>	<u>mg/l</u>	<u>mg/l</u>	<u>mg/l</u>
	B-3	14	150	0.64	<0.0005	1.0
	B-4	26	14	<0.0005	0.079	1.3

S. C. Furman, Ph.D.
 Laboratory Director

SCF:les