

EXXON COMPANY, U.S.A.

ENVIRONMENTAL
PROTECTION

99 SEP 23 PM 2:24

P.O. BOX 4032 • CONCORD, CA 94524-4032
MARKETING DEPARTMENT • ENVIRONMENTAL ENGINEERING

DARIN L. ROUSE
SENIOR ENGINEER

(925) 246-8768
(925) 246-8798 FAX

No apparent tank or line
leaks 9/98 - 8/99

September 22, 1999

#245

Mr. Barney Chan
Alameda County Health Care Services Agency
Department of Environmental Health
1131 Harbor Bay Parkway, Room 250
Alameda, California 94502-6577

RE: Exxon RAS #7-0238/2200 East 12th Street, Oakland, California.

Dear Mr. Chan:

Attached for your review and comment is a letter report entitled *Tank and Line Testing*, dated September 14, 1999, for the above referenced site. The report was prepared by Environmental Resolutions, Inc. (ERI) of Novato, California, and details the results of the tank and line testing at the subject site.

If you have any questions or comments, please contact me at (925) 246-8768.

Sincerely,



Darin L. Rouse
Senior Engineer

Attachment ERI's Report of Tank and Line Testing, dated September 14, 1999.

cc: w/ attachment
Mr. Stephen Hill - California Regional Water Quality Control Board-San Francisco Bay Region

w/o attachment
Mr. John C. Skance - Environmental Resolutions, Inc.
Ms. Kathy Simonelli - Geologic Services Corporation



ENVIRONMENTAL RESOLUTIONS, INC.

September 14, 1999
229303DR.L03

Mr. Darin L. Rouse
Exxon Company, U.S.A.
P.O. Box 4032
Concord, California 94524-4032

Subject: **Report of Tank and Line Testing at Exxon Service Station 7-0238,
2200 East 12th Street, Oakland, California.**

Mr. Rouse:

At the request of Exxon Company, U.S.A. (Exxon), Environmental Resolutions, Inc. (ERI) is submitting this letter report presenting the results of the underground storage tank (UST) and product line testing at the subject site. The subject site is located at the northeast corner of 22nd Avenue and East 12th Street in Oakland, California as shown on the Site Vicinity Map (Plate 1). The locations of the USTs, dispenser islands and other select site features are shown on the Generalized Site Plan (Plate 2).

During a meeting held on April 22, 1999, between the Alameda County Health Care Services Agency, Department of Environmental Health (the County), ERI and Exxon, the County requested that tank and line testing be performed at this site. Subsequent to the meeting, ERI has discussed this site with Exxon's maintenance and compliance department. As a result, ERI was informed that this site is equipped with an Emco Electronics BECO SYSTEM 3000 UST monitoring system. The system continuously operates 24 hours a day measuring various attributes of the fuel storage and delivery system. Leak tests are performed periodically on the lines and tanks during periods of station inactivity. The system performs a 0.1 gallons per hour (gph) leak test once per year, a 0.2 gph leak test once per month, and a 3 gph leak test once per 24 hour period. ERI has subsequently requested the print-out of electronically stored information for the tank and line tests performed over the last 12 months. Results of the leak tests are summarized in Table 1. A copy of the print-out from the system is included as Attachment A. Please note that the system performs the 3 gph test every 24 hours and if the system passes that test data is not stored electronically due to electronic storage capacity of the unit. The results of these tests indicate that the system has passed all leak tests during this period. For your information, a copy of the BECO SYSTEM 3000 system specifications is presented in Attachment B.

This report is presented in supplementation of ERI's *Report of Findings* dated June 23, 1999.

ERI recommends this letter report be sent to the following:

Mr. Barney Chan
Alameda County Health Care Services Agency
Department of Environmental Health
1131 Harbor Bay Parkway, Room 250
Alameda, California 94502-6577


Mr. Stephen Hill
California Regional Water Quality Control Board
San Francisco Bay Region
1515 Clay Street, Suite 1400
Oakland, California 94612

Please call Mr. John C. Skance, ERI's project manger for this site, at (415) 382-5996 with any questions.

Sincerely,
Environmental Resolutions, Inc.



John C. Skance
Assistant Project Manager



Mark S. Dockum, R.G., C.E.G.
Senior Project Manager

- Attachments Table 1: Results of Leak Tests
- Plate 1: Site Vicinity Map
- Plate 2: Generalized Site Plan
- Attachment A: Documentation of Leak Tests
- Attachment B: EECO System 3000 Specifications

TABLE 1
RESULTS OF LEAK TESTS
 Exxon Service Station 7-0238
 2200 East 12th Street
 Oakland, California
 (Page 1 of 2)

Area Tested	Date	Time	0.1 GPH Test	0.2 GPH Test
Line 1: Plus	9/1/98	19:14		Passed
	10/2/98	2:01		Passed
	11/2/98	2:53		Passed
	12/2/98	2:24		Passed
	1/2/99	7:30		Passed
	1/7/99	3:55	Passed	
	2/2/99	5:58		Passed
	3/3/99	2:10		Passed
	4/2/99	5:56		Passed
	5/2/99	7:34		Passed
	6/1/99	23:29		Passed
	7/2/99	2:12		Passed
8/1/99	7:09		Passed	
Line 2: Regular	9/1/98	16:18		Passed
	10/2/98	2:16		Passed
	11/2/98	2:44		Passed
	12/2/98	1:41		Passed
	1/2/99	1:44		Passed
	1/2/99	3:22	Passed	
	2/2/99	1:03		Passed
	3/1/99	14:57		Passed
	4/2/99	0:57		Passed
	5/2/99	2:31		Passed
	6/1/99	15:41		Passed
	7/2/99	2:50		Passed
	8/1/99	17:59		Passed
	Line 4: Supreme	5/5/98	14:58	
6/2/98		8:22		Passed
7/2/98		23:58		Passed
8/2/98		10:32		Passed
9/3/98		8:25		Passed
10/2/98		2:18		Passed
11/3/98		12:05		Passed
1/23/99		1:33		Passed
1/23/99		2:03	Passed	
2/21/99		19:33		Passed
4/2/99		17:00		Passed
6/11/99		10:45		Passed
7/16/99		14:07		Passed

TABLE 1
RESULTS OF LEAK TESTS
 Exxon Service Station 7-0238
 2200 East 12th Street
 Oakland, California
 (Page 2 of 2)

Area Tested	Date	Time	0.1 GPH Test	0.2 GPH Test	
Tank 1: Plus	9/1/98	3:31		Passed	
	10/1/98	3:44		Passed	
	11/3/98	1:36		Passed	
	12/2/98	6:01		Passed	
	1/1/99	3:39		Passed	
	1/19/99	3:58	Passed		
	2/3/99	3:17		Passed	
	3/1/99	3:15		Passed	
	4/4/99	3:16		Passed	
	5/1/99	3:45		Passed	
	6/2/99	3:15		Passed	
	7/1/99	3:19		Passed	
	8/1/99	3:29		Passed	
	Tank 2: Regular	9/2/98	3:16		Passed
		10/1/98	3:35		Passed
11/3/98		3:21		Passed	
12/2/98		5:28		Passed	
1/2/99		5:22		Passed	
2/4/99		4:13		Passed	
3/4/99		3:06		Passed	
4/4/99		7:33		Passed	
4/11/99		7:12	Passed		
5/1/99		3:38		Passed	
6/2/99		3:16		Passed	
7/1/99		3:46		Passed	
8/1/99		3:46		Passed	
Tank 3: Supreme		9/1/98	3:14		Passed
	10/1/98	3:21		Passed	
	11/1/98	7:34		Passed	
	12/3/98	5:42		Passed	
	1/4/99	5:27		Passed	
	1/29/99	5:07	Passed		
	2/1/99	3:01		Passed	
	3/1/99	4:39		Passed	
	4/3/99	2:53		Passed	
	5/1/99	5:52		Passed	
	6/2/99	3:12		Passed	
	7/3/99	3:47		Passed	
	8/1/99	3:00		Passed	


Notes:

Time = Time is presented using a 24-hour clock.

Line 1: Plus = Product line number one containing Plus grade product.

0.1 GPH Test = Pressure test at a flowrate of 0.1 gallons per hour.

GPH = Gallons per hour.



FN: 22930001

EXPLANATION



Source: U.S.G.S. 7.5 minute topographic quadrangle map Oakland East, California (Photorevised 1980)

APPROXIMATE SCALE




PROJECT ERI 2293

SITE VICINITY MAP

EXXON SERVICE STATION 7-0238
2200 East 12th Street
Oakland, California

PLATE

1



FN 22930002

EXPLANATION

- MW9I
- ⊕ Groundwater Monitoring Well



GENERALIZED SITE PLAN

EXXON SERVICE STATION 7-0238
2200 East 12th Street
Oakland, California

PROJECT NO.
2293
PLATE
2

ATTACHMENT A
DOCUMENTATION OF LEAK TESTS

EXXON #70238
2200 E 12TH ST
OAKLAND CA 94606
510-535-1672
V005H

08-05-99 11:23:29

LAST PASSED LINE TESTS:

LINE 1 89 STP

0.1 GPH TEST:
01-07-99 03:55:00
0.2 GPH TEST:
08-01-99 07:09:00

LINE 2 87 STP

0.1 GPH TEST:
01-02-99 03:22:00
0.2 GPH TEST:
08-01-99 17:59:00

LINE 4 SUPREME

0.1 GPH TEST:
01-23-99 02:03:00
0.2 GPH TEST:
07-16-99 14:07:00

LINE TEST HISTORY

LINE 1 89 STP

PASSED 0.1 LEAK TESTS
01-07-99 03:55

PASSED 0.2 LEAK TESTS

08-01-99 07:09
07-02-99 02:12
06-01-99 23:29
05-02-99 07:34
04-02-99 05:56
03-03-99 02:10
02-02-99 05:58
01-02-99 07:30
12-02-98 02:24
11-02-98 02:53
10-02-98 02:01
09-01-98 19:14

LINE 2 87 STP

PASSED 0.1 LEAK TESTS
01-02-99 03:22

PASSED 0.2 LEAK TESTS

08-01-99 17:59
07-02-99 02:50
06-01-99 15:41
05-02-99 02:31
04-02-99 00:57
03-01-99 14:57
02-02-99 01:03
01-02-99 01:44
12-02-98 01:41
11-02-98 02:44
10-02-98 02:16
09-01-98 16:18

LINE 4 SUPREME

PASSED 0.1 LEAK TESTS
01-23-99 02:03

PASSED 0.2 LEAK TESTS

07-16-99 14:07
06-11-99 10:45
04-02-99 17:00
02-21-99 19:33
01-23-99 01:33
11-03-98 12:05
10-02-98 02:18
09-03-98 08:25
08-02-98 10:32
07-02-98 23:58
06-02-98 08:22
05-05-98 14:58

EXXON #70238
2200 E 12TH ST
OAKLAND CA 94606
510-535-1672
V005H

08-05-99 11:22:51

LAST PASSED TANK TESTS

TANK 1 PLUS

0.1 GPH TEST:

01-19-99 03:58:00
PRODUCT LEVEL: 24.9 "
PERCENT VOLUME: 21 %
PRODUCT TEMP: 64.5 OF

0.2 GPH TEST:

08-01-99 03:29:00
PRODUCT LEVEL: 29.4 "
PERCENT VOLUME: 26 %
PRODUCT TEMP: 73.4 OF

TANK 2 REGULAR

0.1 GPH TEST:

04-11-99 07:12:00
PRODUCT LEVEL: 36.8 "
PERCENT VOLUME: 36 %
PRODUCT TEMP: 64.4 OF

0.2 GPH TEST:

08-01-99 03:46:00
PRODUCT LEVEL: 53.3 "
PERCENT VOLUME: 59 %
PRODUCT TEMP: 75.1 OF

TANK 3 SUPREME

0.1 GPH TEST:

01-29-99 05:07:00
PRODUCT LEVEL: 24.2 "
PERCENT VOLUME: 20 %
PRODUCT TEMP: 64.8 OF

0.2 GPH TEST:

08-01-99 03:00:00
PRODUCT LEVEL: 19.2 "
PERCENT VOLUME: 14 %
PRODUCT TEMP: 74.6 OF

TANK TEST HISTORY

TANK 1 PLUS

PASSED 0.1 LEAK TESTS

01-19-99 03:58

PASSED 0.2 LEAK TESTS

08-01-99 03:29
07-01-99 03:19
06-02-99 03:15
05-01-99 03:45
04-04-99 03:16
03-01-99 03:15
02-03-99 03:17
01-01-99 03:39
12-02-98 06:01
11-03-98 01:36
10-01-98 03:44
09-01-98 03:31

TANK 2 REGULAR

PASSED 0.1 LEAK TESTS

04-11-99 07:12

PASSED 0.2 LEAK TESTS

08-01-99 03:46
07-01-99 03:46
06-02-99 03:16
05-01-99 03:38
04-04-99 07:33
03-04-99 03:06
02-04-99 04:13
01-02-99 05:22
12-02-98 05:28
11-03-98 03:21
10-01-98 03:35
09-02-98 03:16

TANK 3 SUPREME

PASSED 0.1 LEAK TESTS


01-29-99 05:07

PASSED 0.2 LEAK TESTS

08-01-99 03:00
07-03-99 03:47
06-02-99 03:12
05-01-99 05:52
04-03-99 02:53
03-01-99 04:39
02-01-99 03:01
01-04-99 05:27
12-03-98 05:42
11-01-98 07:34
10-01-98 03:21
09-01-98 03:14

ATTACHMENT B

EECO 3000 SYSTEM SPECIFICATIONS



The Friendliest System For Leak Detection and Inventory Management

Unmatched User Friendliness, Virtually No Operator Training Necessary

- Touch screen & printer located in the sales area for easy operator access
- Menu options and data displayed on touch screen
- Information accessed by simply touching the screen
- On screen help instructions provide operator assistance
- EECO Guide™ printed help instructions tell the operator what to do, who to call, and what action to take in the event of an alarm
- EECO Guide prints automatically when any problem condition occurs

Regulatory Compliance

- Tanks, lines, sumps, wells
- Programmable leak tests (daily, weekly, monthly, continuous, or on demand)
- Selectable leak rates (3GPH, .2GPH, .1GPH)
- Selectable leak test type (standard or quick)
- Notification of compliance deadlines

Modular Console

- System design allows for easy field upgrade or expansion
- System modules can be removed and replaced in minutes

Inventory Management

- Fuel Height and Volume
- Reconciliation Information reports
- Automatic fuel delivery reports
- Fuel order product reports

Reporting Capabilities

- Reports can be sent to the system printer, on-site computer, or off-site computer
- Modem auto-dial feature sends alarms and selected reports to remote computer automatically
- Selectable reports can be programmed to be sent automatically four times daily

Extensive Self Monitoring Capabilities

- Designed to minimize service time and costs
- Diagnostic codes displayed on the console tell service technicians exactly what is wrong
- Rolling 250 event detailed history aids in trouble shooting

**Tank Level Monitor (TLM) Option Monitors
Tanks Continuously, 24 Hours A Day, 7 Days
A Week**

- Standard system monitors up to 8 tanks
- Theft detection mode initiates automatically during scheduled time the station is closed

TLM SPECIFICATIONS

Number of tanks: Up to 8 tanks
 Probe Inputs: Intrinsically safe magnetostrictive
 Probe Power Supply: 26 VDC
 Level Precision: $\pm .0005'$
 Level Accuracy: $\pm .04\%$ full scale
 Temperature Precision: $\pm .0021^\circ$ F
 Temperature Accuracy: $\pm .5^\circ$ F
 .2 GPH Leak Test: 99% P_d, 1% P_{fa}
 .2 GPH Quick Leak Test: 95% P_d, 5% P_{fa}
 .1 GPH Leak Test: 99% P_d, 1% P_{fa}
 .1 GPH Quick Leak Test: 96% P_d, 4% P_{fa}
 EPA Leak Test Certified: 15,000 gallon tank (56,775 liters)

CONSOLE SPECIFICATIONS

Dimensions: 20" W, 15" H, 7.75" D (50.8 x 38.1 x 19.7 cm)
 Weight: 42 lbs.
 Operating Temperature: 32° to 104° F (0° to 40° C)
 Humidity: 90% non-condensing
 Typical Mounting Location: Protected, non-hazardous area
 Power Requirements: 120 VAC \pm 10%, 60 Hz, 15 amp dedicated circuit
 Listings and Approvals: UL, FCC, CSA, UL, ETL, DOC
 System Relay: 10 amp, 250 VAC contacts
 Relay Boards (optional): 2 boards (each has 4 relays)
 RS-232 (optional): 3 ports (modem, local, & pass through)
 Internal Modem (optional): 3 ports (phone line, local & pass through)

LINE LEAK DETECTOR SPECIFICATIONS

Number of Lines: Max of 8 (4 per module)
 Pipe Connections: 2" NPT
 3 GPH Leak Test: 100% P_d, 0% P_{fa}
 .2 GPH Leak Test: 100% P_d, 0% P_{fa}
 .1 GPH Leak Test: 100% P_d, 0% P_{fa}
 EPA Leak Test Certified: 67.4 gallons (255.1 liters)

Information subject to change without notice.

Comprehensive Programmable Alarms

- Overfill
- Order Product
- High Water
- Leak Test Failed
- Leak Test Required
- High Product
- Low Product
- Water Present
- Theft

PROBE SPECIFICATIONS

Type: Magnetostrictive/Float
 Material: Stainless steel shaft, aluminum head
 Location: Hazardous, Class I, Division 1, Group D
 Temperature Measurement: 6 RTDs spaced for equal volumetric measurement
 Temperature Range: -4° F to 156° F (-20° C to 70° C)
 Data Cable: < 250' Belden #8760
 250' to 1500' Belden 9182

TOUCH SCREEN SPECIFICATIONS

Dimensions: 8.5 x 11.0 x 4.0 inches (21.6 x 27.9 x 10.2 cm)
 Weight: 11.5 lbs.
 Operating Temperature: 32° to 104° F (0° to 40° C)
 Humidity: 90% non-condensing
 Location: Protected, non-hazardous area
 Power Requirements: 120 VAC, 60 Hz, 15 watts
 Listings and Approvals: UL, CSA, ETL, ULC

LEAK SENSOR SPECIFICATIONS

Number of Sensors: Up to 8
 Sensor Types: EECO Choice
 Discriminating Dispenser Pan: Q0003-001
 Discriminating STP Sump: Q0003-002
 Discriminating Interstitial: Q0003-003
 Discriminating Monitoring Well: Q0003-xx4
 Wet Interstitial: Q0003-005
 Liquid Only Interstitial: Q0003-006
 Liquid Float: Q0003-009
 Vapor: Q0003-010

Printed in USA



**TUTHILL
CORPORATION**

**Emco Electronics
Division**

114-300 Mackenran Drive
 Cary, North Carolina USA 27511
 Tel 919 460-6000 Fax 919 460-7585