

## Khatri, Paresh, Env. Health

---

**From:** Khatri, Paresh, Env. Health  
**Sent:** Friday, August 20, 2010 11:00 AM  
**To:** 'Goloubow, Ron'  
**Cc:** Drogos, Donna, Env. Health  
**Subject:** RE: Aspire Oakland - Wells under the building

Good Morning Ron,

Your proposal to relocate Building A approximately 15 feet to the northwest to retain wells (AS-3I & AS-1I) appears acceptable. Additionally, as discussed in yesterday's meeting, ACEH still recommends installing the soil vapor monitoring points below the vapor barrier in addition to above the vapor barrier and within the passive (or possibly active) slab venting system, as ARCADIS proposed.

We look forward to your submittal.

Sincerely,

Paresh C. Khatri  
Hazardous Materials Specialist  
Alameda County Environmental Health  
Local Oversight Program  
1131 Harbor Bay Parkway  
Alameda, CA 94502-6577

Phone: (510) 777-2478  
Fax: (510) 337-9335

E-mail: [Paresh.Khatri@acgov.org](mailto:Paresh.Khatri@acgov.org)

<http://www.acgov.org/aceh/lop/lop.htm>

**Confidentiality Notice:** This e-mail message, including any attachments, is for the sole use of intended recipient(s) and may contain confidential and protected information. Any unauthorized review, use, disclosure, or distribution is prohibited. If you are not the intended recipient, please contact the sender by reply e-mail and destroy all copies of the original message.

---

**From:** Goloubow, Ron [mailto:Ron.Goloubow@arcadis-us.com]  
**Sent:** Friday, August 20, 2010 9:19 AM  
**To:** Khatri, Paresh, Env. Health  
**Subject:** Aspire Oakland - Wells under the building

Paresh thanks for taking the time to meet with us yesterday. I am going to ask the architect if they can shift building A about 15 feet to the north west. That shift will allow for wells AS1I, AS3I and AS8I to be retained. I contemplated moving the building further to retain well ASMW2I but since ASMW2I is only approximately 10 to 15 feet from well AS1I I believe the requested groundwater data could be provided by samples collected from well AS1I. Also moving the building further to the northwest will infringe on the fire lane.

We are planning to retain the following eight wells for future groundwater monitoring: AS1I, AS3I, ASMW4I, AS6I, SMW5I, ASMW4I, NW2I, and MW4 (see attached map). Wells not included on this list would be abandoned.

This will all be formalized in a *revised groundwater monitoring plan* but since Aspire is trying to design the building now I wanted to get your opinion on this matter. Please let me know as soon as possible if that will satisfy the County's request to retain wells.

Thanks Ron.

**Ron Goloubow, PG** | Senior Associate Geologist | [ron.goloubow@arcadis-us.com](mailto:ron.goloubow@arcadis-us.com)

**ARCADIS U.S., Inc.** | 1900 Powell Street, Suite 1200 | Emeryville, CA 94608

T. 510.596.9550 | M. 510.501-1789 | F. 510.652.2246

[www.arcadis-us.com](http://www.arcadis-us.com)

---

NOTICE: This e-mail and any files transmitted with it are the property of ARCADIS U.S., Inc. and its affiliates. All rights, including without limitation copyright, are reserved. The proprietary information contained in this e-mail message, and any files transmitted with it, is intended for the use of the recipient(s) named above. If the reader of this e-mail is not the intended recipient, you are hereby notified that you have received this e-mail in error and that any review, distribution or copying of this e-mail or any files transmitted with it is strictly prohibited. If you have received this e-mail in error, please notify the sender immediately and delete the original message and any files transmitted. The unauthorized use of this e-mail or any files transmitted with it is prohibited and disclaimed by ARCADIS U.S., Inc. and its affiliates. Nothing herein is intended to constitute the offering or performance of services where otherwise restricted by law.

