

Khatri, Paresh, Env. Health

Subject: RO0000473
Entry Type: Phone call
Start: Fri 4/10/2009 2:29 PM
End: Fri 4/10/2009 2:29 PM
Duration: 0 hours

I received a call from Kurt, a concerned nearby resident, who claimed to have seen water bubbling out of the ground at the subject site. I told him that I would look into it and would call him back. I contacted SOMA Environmental to verify whether any fieldwork is being conducted without ACEH notification. SOMA stated that they are not aware of any activities at the site, but will be in the area and will stop by the site. SOMA called back to inform ACEH that since the property recently transacted, the new owner had hired a contractor to clean up the station. When the water main was turned on, water began seeping up through cracks in the asphalt, but subsided when the water main was turned back off. Therefore, there appears to be a break in the water line, which will be repaired sometime next week. I call Kurt back to inform him of the activities that had transpired.