

CVHS  
19400 Santa Maria  
Castro Valley

8-6-93

MEMO TO FILE:

Jeff Farhoonand of Tank Protect Engineering (TPE) and I discussed the sample results for this site.

The fuel UST pit was given the "OK" for backfilling except for that area where sample DSP-4D was collected (6.9 ppm TPH/D). Over excavation of waste oil pit was approved, requesting I be notified when confirmatory samples would be collected. I reminded Jeff that the waste oil UST sample (WOS-1) still required SVOC (8270) and metals analysis.

I requested the submittal of a ULR.

SOS

