

DRY  
CLEANING



# R & J QUICK CLEAN CENTER

RAY LORGE • JIM LORGE  
2522 CASTRO VALLEY BOULEVARD  
CASTRO VALLEY, CALIFORNIA 94546  
(415) 581-9797

91 MAR 22 AM 10:54



ACHCSA  
Hazardous Materials Division  
80 Swan Way, Room 200  
Oakland, Ca. 94621  
Attn: Scott Seery


Dear Scott;

I have enclosed a copy of the Tank Closure report,  
which we just received from KTW.

Under Kevin Krause's direction we are going to backfill  
the excavation, with new imported fill. This will allow  
us room to air out the contaminated soil, so that we can  
transport it to a landfill that is acceptable.

We will keep you informed as we progress.

Sincerely,

  
Ray Lorge



43289 Osgood Road, Fremont, Calif. 94539

(415) 623-0480

Cal. State Cont. Lic. # 572427

---

**RJ QUICK CLEAN**

**2522 Castro Valley Boulevard  
Castro Valley, California**

**Tank Closure Report**

Tank # 1

Mr. Raymond Lorge  
Mr. Jim Lorge  
RJ Quick Clean  
2522 Castro Valley Boulevard  
Castro Valley, California 94546

Dear Sirs:

K.T.W. & Associates is pleased to submit this report describing closure activities associated with the removal of one (1) underground storage tank at your site located at 2517 San Carlos Street, Castro Valley, California. This report provides a description of site activities and observations, the condition of the excavated tank, the condition of tank backfill and other subsurface materials, sampling procedures and locations, laboratory analytical procedures and certified analytical results, chain of custody documentation, and hazardous waste manifest.

### **Site Description**

The site is located at 2517 San Carlos Street, Castro Valley, California. A site location map is presented in Plate 1. One 1,000 gallon, underground gasoline, storage tank, was formerly located at the subject site. A site map showing the location of the site structure, former underground tank and dispensing island is presented in Plate 2.

### **Closure Plan and Permitting**

A closure plan and permit application for removal of underground tanks was completed and submitted to the Alameda County Health Care Services Agency, Hazardous Materials Division. An additional permit was filed with the Bay Area Air Quality Management District even though displacement of volatile vapors was not expected due to the tank having been filled with water to the top of the fill pipe.

### **Underground Tank Closure**

Tank removal activities occurred on February 6, 1991. Inspector Scott Seery was present to observe the tank removal and sampling activities.

Construction services associated with closure were performed by K.T.W. & Associates. Robert Chew of R.Y. Chew Geotechnical provided a California Registered Geologist to perform environmental sampling and documentation services.

The presence of groundwater in the tank pit showed visual signs of contamination, as well as a strong gasoline odor. The tank contained approximately 1,000 gallons of water prior to its removal. The water was removed from the tank via vacuum truck and manifested under a hazardous waste manifest presented in Attachment B. At the direction of Scott Seery, an additional 395 gallons, of visibly contaminated water, were removed from the tank excavation. The recharge rate was noted to be steady, and to occur on all sides of the excavation.

Closure activities were documented in the Hazardous Materials Inspection Form prepared by Scott Seery located in Attachment A. Upon removal the structural integrity of the tank was observed to be sound. The tank was of cold-rolled steel construction, and the piping consisted of single wall steel. The tank was removed and transported from the site by a permitted hazardous waste transporter under hazardous waste manifest. Copies of the hazardous waste manifest are presented in Attachment B.

### **General Observations, Underground Tank Closure**

The tank, which had been used to store gasoline approximately forty-five years ago, contained the following trim: a riser assembly for filling, a vent line, and a product line for the dispensing of the material. According to anecdotal information supplied by the client, the tank had not contained product for at least thirty years.

The condition of the lines prior to removal were unsound, and contained several corrosion holes.

All the fittings appeared to be properly installed, however, the corrosion holes appeared to be of sufficient size in the vent line to allow for the introduction of groundwater. The riser assembly that constituted the fill pipe for the tank appeared to be sound and free of defects. A very strong hydrocarbon odor was observed while removing the overburden. This odor remained strong throughout the excavation and subsequent overexcavation activities. The material was stockpiled on-site pending analysis results, and was not incorporated as backfill in the excavation. Backfilling of the excavation has yet to be completed with clean imported fill material.

The following day, overexcavation began at the site to determine if the contamination was localized in nature. Since it did not appear to be the case, overexcavation was discontinued after the removal of approximately thirty (30) additional yards.

### **Soil Sampling**

Soil samples were collected from the tank excavation, and from the sidewalls of the overexcavation as well. Soil sampling of the tank excavation occurred on February 6, 1991. The sampling following the overexcavation occurred on February 7, 1991. These samples were obtained by excavating to the native soil interface and driving a brass tube into the native soil. Soil samples were collected in brass tubes, sealed in foil and plastic caps, and promptly stored in a cooler. Following completion of field work, samples were submitted to BSK Analytical Labs, a certified analytical laboratory, for analyses under appropriate chain of custody protocol.

### **Certified Analytical Results**

Samples collected for minimum verification analyses (MVA) were analyzed in accordance with appropriate regulatory guidelines contained within Regional Board Staff Recommendations for Initial Evaluation and Investigation of Underground Tanks (RWQCB, 1988). Copies of soil analytical results are presented in Attachment C.

### MVA for Underground Tank Excavation

The soil samples collected from the soil below the east and west ends of the tank, showed a range of the compounds associated with gasoline contamination. The analysis performed on the soil for gasoline and its constituents showed levels ranging from non-detected (N.D.) to 2200 parts per million (ppm) of Total Petroleum Hydrocarbons as Gasoline (TPH-G). The results from the sampling activities that occurred immediately after overexcavation showed TPH-G constituents ranging from N.D. to 1500 ppm. Analytical results are shown in Attachment C. It was noted in the QA/QC summary that the total petroleum hydrocarbon sample results showed that the readings were of a lower molecular weight, in fact extractable components of gasoline, rather than being indicative of another fuel. The QA/QC data has been attached to the analysis results. No organic lead was detected in any of the analyses.

### **Regulatory Guidelines**

The Regional Water Quality Control Board - San Francisco Bay Region has established a level of 100 ppm Total Petroleum Hydrocarbons (TPH) concentrations in soil as a general decision value for requiring further definition of site soil and groundwater contamination where shallow groundwater conditions are known to exist. The origin of the 100 ppm level was to "develop a method to prioritize the case load and indicate whether a significant volume of fuel had been released or discharged" (RWQCB, June, 1988).

Copies of this report should be submitted to:

Regional Water Quality Control Board  
1111 Jackson Street, Rm. 6000  
Oakland, CA 94607  
Attn: Dyan Whyte

RJ Quick Clean  
March 8, 1991  
Page 5

Alameda County Health Care Services Agency  
Hazardous Materials Division  
80 Swan Way, Room 200  
Oakland, California 94621  
Attention: Scott Seery

Additional copies of this report have been provided for the purpose of regulatory submittal.

Should you have any questions or comments regarding the evaluations presented in this report, please call.

Respectfully,

Kevin Krause  
Vice President  
K.T.W. & Associates, Inc.


Thomas M. Gregory  
President  
K.T.W. & Associates, Inc.

KK/emm

Attachments

**PLATES**





● = SITE

SCALE NTS
DATE 3/11/91
DRWG. BY EMM




SITE LOCATION  
 RJ QUICK CLEAN  
 2522 Castro Valley Blvd.  
 Castro Valley, California

PLATE

1

PROJECT: 1133



SCALE NTS
DATE 3/11/91
DRWG. BY EMM



PROJECT: 1133

GENERALIZED SITE MAP  
 RJ QUICK CLEAN  
 2517 San Carlos Street  
 (2522 Castro Valley Blvd.)  
 Castro Valley, California

PLATE  
 2

**ATTACHMENT A**

**Hazardous Materials  
Inspection Form**

white -env.health  
yellow -facility  
pink -files

# ALAMEDA COUNTY, DEPARTMENT OF ENVIRONMENTAL HEALTH

## Hazardous Materials Inspection Form

80 Swan Way, #200  
Oakland, CA 94621  
(415) 271-4320

II, III

Site ID # \_\_\_\_\_ Site Name MANUAL PADILLA TRUCKING Today's Date 2/6/91

Site Address 2517 San Carlos (2522 Castro Valley Blvd.)

City Castro Valley Zip 94546 Phone \_\_\_\_\_

MAX AMT stored > 500 lbs, 55 gal., 200 cft.?

### Inspection Categories:

- I. Haz. Mat/Waste GENERATOR/TRANSPORTER
- II. Business Plans, Acute Hazardous Materials
- III. Underground Tanks

\* Calif. Administration Code (CAC) or the Health & Safety Code (HS&C)

1:00 - 4:00

### Comments:

On-site to witness UST closure. One (1) 1,000 gallon tank thus far identified, and this closure report documents its removal. (Note: An additional UST is likely located on the east side of the building as another vent line is attached vertically to the east wall. A survey using a metal detector (magnetic) identified a subsurface anomaly ~~in~~ beneath the driveway along the eastern edge of the property, proximal to the noted vent line.). The tank was full of water upon my arrival. A vacuum truck from Evergreen Oil removed liquid from the tank, and product-impacted H<sub>2</sub>O from the UST excavation. Brown floating product is evident upon the G.W. in the excavation. GW can be seen flowing into the pit from the north, east and west walls of the excavation, at a depth below grade (BG) ranging from a few inches to approx 18" BG. As the GW was being vacuumed from the excavation, the odor of gasoline became more evident. The sand backfill is stained a green color. Bob Bohman arrived on site to confirm LEL/O<sub>2</sub> concentrations. Tank pulled.

- ### II.A BUSINESS PLANS (Title 19)
- 1. Immediate Reporting 2703
  - 2. Bus. Plan Stds. 25503(b)
  - 3. RR Cars > 30 days 25503.7
  - 4. Inventory Information 25504(a)
  - 5. Inventory Complete 2730
  - 6. Emergency Response 25504(b)
  - 7. Training 25504(c)
  - 8. Deficiency 25505(a)
  - 9. Modification 25505(b)

- ### II.B ACUTELY HAZ. MATLS
- 10. Registration Form Filed 25533(a)
  - 11. Form Complete 25533(b)
  - 12. RMPP Contents 25534(c)
  - 13. Implement Sch. Req'd? (Y/N) \_\_\_\_\_
  - 14. OnSite Conseq. Assess. 25524(c)
  - 15. Probable Risk Assessment 25534(d)
  - 16. Persons Responsible 25534(g)
  - 17. Certification 25534(f)
  - 18. Exemption Request? (Y/N) 25534(b)
  - 19. Trade Secret Requested? 25538

- ### III. UNDERGROUND TANKS (Title 23)
- General
- 1. Permit Application 25284 (H&S)
  - 2. Pipeline Leak Detection 25292 (H&S)
  - 3. Records Maintenance 2712
  - 4. Release Report 2651
  - 5. Closure Plans 2670

- Monitoring for Existing Tanks
- 6. Method
    - 1) Monthly Test
    - 2) Daily Vadose
      - Semi-annual groundwater
      - One time soil
    - 3) Daily Vadose
      - One time soil
      - Annual tank test
    - 4) Monthly Gndwater
      - One time soil
    - 5) Daily Inventory
      - Annual tank testing
      - Cont pipe leak det
      - Vadose/gndwater mon.
    - 6) Daily Inventory
      - Annual tank testing
      - Cont pipe leak det
    - 7) Weekly Tank Gauge
      - Annual tank tsg
    - 8) Annual Tank Testing
      - Daily Inventory
      - 9) Other \_\_\_\_\_
  - 7. Precs Tank Test 2643
    - Date: \_\_\_\_\_
  - 8. Inventory Rec. 2644
  - 9. Soil Testing 2646
  - 10. Ground Water 2647

- New Tanks
- 11. Monitor Plan 2632
  - 12. Access. Secure 2634
  - 13. Plans Submit 2711
    - Date: \_\_\_\_\_
  - 14. As Built 2635
    - Date: \_\_\_\_\_

Rev 6/88

Contact: Tom Gregory

Title: CO. OWNER KTW + ASSOC.

Signature: [Signature]

Inspector: S. Seay

Signature: [Signature]

II, III

white -env.health  
yellow -facility  
pink -files

# ALAMEDA COUNTY, DEPARTMENT OF ENVIRONMENTAL HEALTH

80 Swan Way, #200  
Oakland, CA 94621  
(415) 271-4320

## Hazardous Materials Inspection Form

II, III

Site ID # \_\_\_\_\_ Site Name Manual Padilla Trucking Today's Date 2/6/91

- II.A BUSINESS PLANS (Title 19)**
- \_\_\_ 1. Immediate Reporting 2703
  - \_\_\_ 2. Bus. Plan Sids. 25503(b)
  - \_\_\_ 3. RR Cons > 30 days 25503.7
  - \_\_\_ 4. Inventory Information 25504(a)
  - \_\_\_ 5. Inventory Complete 2730
  - \_\_\_ 6. Emergency Response 25504(b)
  - \_\_\_ 7. Training 25504(c)
  - \_\_\_ 8. Deficiency 25505(a)
  - \_\_\_ 9. Modification 25505(b)

Site Address 2517 San Carlos  
City Castro Valley Zip 94 Phone \_\_\_\_\_

- II.B ACUTELY HAZ. MAT'LS**
- \_\_\_ 10. Registration Form Filed 25533(a)
  - \_\_\_ 11. Form Complete 25533(b)
  - \_\_\_ 12. RMPP Contents 25534(c)
  - \_\_\_ 13. Implement Sch. Req'd? (Y/N) \_\_\_\_\_
  - \_\_\_ 14. OnSite Conseq. Assess. 25524(c)
  - \_\_\_ 15. Probable Risk Assessment 25534(d)
  - \_\_\_ 16. Persons Responsible 25534(g)
  - \_\_\_ 17. Certification 25534(i)
  - \_\_\_ 18. Exemption Request? (Y/N) 25536(b)
  - \_\_\_ 19. Trade Secret Requested? 25538

\_\_\_ MAX AMT stored > 500 lbs, 55 gal., 200 cft.?

**Inspection Categories:**

- \_\_\_ I. Haz. Mat/Waste GENERATOR/TRANSPORTER
- II. Business Plans, Acute Hazardous Materials
- \_\_\_ III. Underground Tanks

\* Calif. Administration Code (CAC) or the Health & Safety Code (HS&C)

**III. UNDERGROUND TANKS (Title 23)**

- General**
- \_\_\_ 1. Permit Application 25284 (H&S)
  - \_\_\_ 2. Pipeline Leak Detection 25292 (H&S)
  - \_\_\_ 3. Records Maintenance 2712
  - \_\_\_ 4. Release Report 2651
  - \_\_\_ 5. Closure Plans 2670

- Monitoring for Existing Tanks**
- \_\_\_ 6. Method
    - 1) Monthly Test
    - 2) Daily Vadose
      - Semi-annual groundwater
      - One time soil
    - 3) Daily Vadose
      - One time soil
      - Annual tank test
    - 4) Monthly Gndwater
      - One time soil
    - 5) Daily Inventory
      - Annual tank testing
      - Cont pipe leak det
      - Vadose/gndwater mon.
    - 6) Daily Inventory
      - Annual tank testing
      - Cont pipe leak det
    - 7) Weekly Tank Gauge
      - Annual tank testing
    - 8) Annual Tank Testing
      - Daily Inventory
    - 9) Other \_\_\_\_\_

- \_\_\_ 7. Precs Tank Test 2643
  - Date: \_\_\_\_\_
- \_\_\_ 8. Inventory Rec. 2644
- \_\_\_ 9. Soil Testing 2646
- \_\_\_ 10. Ground Water 2647

- New Tanks**
- \_\_\_ 11. Monitor Plan 2632
  - \_\_\_ 12. Access. Secure 2634
  - \_\_\_ 13. Plans Submit 2711
    - Date: \_\_\_\_\_
  - \_\_\_ 14. As Built 2635
    - Date: \_\_\_\_\_

**Comments:**  
The tank appears sound, and is of bare steel construction. No holes or rust were evident. David Glick (David C. Glick Assoc.) was on hand to collect samples.

The tank was transported under manifest number 90574133 by Erickson, Inc.

One sample was collected from each end of the tank. The sample from the west end was at ~6' BG. From the east, ~7' BG. No water sample was collected.

Over excavation of the pit will continue over the course of the next several days

Rev 8/88

Contact: Tom Gregory  
Title: Co-owner KTW + Assoc  
Signature: \_\_\_\_\_

Inspector: \_\_\_\_\_  
Signature: S. Seely

II, III

**ATTACHMENT B**

**Hazardous Waste Manifests  
and Certificate**

90574133

IN CASE OF AN EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8902; WITHIN CALIFORNIA CALL 1-800-852-7550

GENERATOR  
TRANSPORTER  
FACILITY

<b>UNIFORM HAZARDOUS WASTE MANIFEST</b>		1. Generator's US-EPA ID No. <b>CA1000015158352174073</b>		2. Page 1 of 1		Information in the shaded areas is not required by Federal law.			
3. Generator's Name and Mailing Address <b>R.S. QUICK CLEAN (RAY LORGE) 2522 CASTRO VALLEY BLVD. CASTRO VALLEY, CA. 94546</b>				A. State Manifest Document Number <b>90574133</b>					
4. Generator's Phone <b>(415) 581-9797</b>				B. State Generator's ID					
6. Transporter 1 Company Name <b>ERICKSON TRUCKING</b>		US EPA ID Number <b>CA10009466392</b>		C. State Transporter's ID <b>106245</b>		D. Transporter's Phone <b>(415) 235-1393</b>			
7. Transporter 2 Company Name		8. US EPA ID Number		E. State Transporter's ID		F. Transporter's Phone			
9. Designated Facility Name and Site Address <b>Erickson, Inc. 255 Parr Blvd. Richmond, Ca. 94801</b>				10. US EPA ID Number <b>CA10009466392</b>		G. State Facility's ID <b>CA10009466392</b>			
				H. Facility's Phone <b>(415) 235-1393</b>					
11. US DOT Description (Including Proper Shipping Name, Hazard Class, and ID Number)						12. Containers No.	13. Total Quantity	14. Unit Wt/Vol	1. Waste No.
a. Waste Empty Storage Tank <b>NON-RCRA Hazardous Waste Solid.</b>						<b>001</b>	<b>11000</b>	<b>P</b>	State <b>512</b> EPA/Other <b>NONE</b>
b.									State EPA/Other
c.									State EPA/Other
d.									State EPA/Other
15. Special Handling Instructions and Additional Information <b>Qty. 1 Empty Storage Tank (s) #5579 Tank (s) have been inerted with 15 lbs. Dry Ice per 1000 Gal. Capacity.</b>						K. Handling Codes for Wastes Listed Above a. <b>01</b> b. c. d.			
16. Special Handling Instructions and Additional Information <b>Keep away from sources of ignition. Always wear hardhats when working around U.S.T.'s 24 Hr. Contact Name RAY LORGE &amp; Phone (415) 581-9797</b>									
18. GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations.  If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.									
Printed/Typed Name				Signature		Month Day Year			
17. Transporter 1 Acknowledgement of Receipt of Materials									
Printed/Typed Name <b>ROBERT CANEPA</b>				Signature <i>Robert Canepa</i>		Month Day Year <b>02/06/91</b>			
18. Transporter 2 Acknowledgement of Receipt of Materials									
Printed/Typed Name <b>JIM D. LORGE</b>				Signature <i>Jim D Lorge</i>		Month Day Year <b>12/6/91</b>			
19. Discrepancy Indication Space <b>Generator Sign Manifest at line 18 s/B in Area 16</b>									
20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19.									
Printed/Typed Name <b>Donald H. Rossell Jr</b>				Signature <i>Donald H. Rossell Jr</i>		Month Day Year <b>02/06/91</b>			

No 5579-74073  
K.T.W.

**CERTIFICATE**  
Certified Services Company  
255 Parr Boulevard  
Richmond, California 94801

Day or Night  
Telephone  
(415) 235-1393

For: Erickson, Inc. Tank No.(s.) 5579 Location: Richmond Date: 02-08-91 Time: 1:00 p.m.  
Test Method: Visual Gastech/1314 SMPN Last Product: Loaded Gas

This is to certify that I have personally determined that the tank(s) in the following list are in accordance with the American Petroleum Institute and have found the condition of each to be in accordance with its assigned designation. This certificate is based

on conditions existing at the time the inspection herein set forth was completed and is issued subject to compliance with all qualifications and instructions.

Tank(s)	Condition
1- <u>1,000</u> Gal. Tank	Safe For Fire
	Oxy 20.0%
	LEL-LESS THAN 0.1%

Remarks: \_\_\_\_\_

In the event of any physical or atmospheric changes affecting the gas-free condition of the above tanks, or if in any doubt immediately stop all hot work and contact the

undersigned. This permit is valid for 24 hours if no physical or atmospheric changes occur.

**Standard Safety Designation:**

**Safe for Men:** Means that in the compartment or space so designated (a) The oxygen content of the atmosphere is at least 19.5 percent by volume; and that (b) Toxic materials in the atmosphere are within permissible concentrations; and (c) In the judgment of the Inspector, the residues are not capable of producing toxic materials under existing atmospheric conditions while maintained as directed on the Inspector's certificate.

**Safe for Fire:** Means that in the compartment so designated (a) The concentration of flammable materials in the atmosphere is below 10 percent of the lower explosive limit; and that (b) In the judgment of the Inspector, the residues are not capable of producing a higher concentration than permitted under existing atmospheric conditions in the presence of fire and while maintained as directed on the Inspector's certificate, and further, (c) All adjacent spaces have either been cleaned sufficiently to prevent the spread of fire, are satisfactorily inerted, or in the case of fuel tanks, have been treated as deemed necessary by the Inspector.

The undersigned representative acknowledges receipt of this certificate and understands the conditions and limitations under which it was issued.

K. Deighes  
Representative Title

[Signature]  
Inspector



# THIS SHIPPING ORDER

must be legibly filled in, in Ink, in Indelible Pencil, or in Carbon, and retained by the Agent.

Shipper's No. \_\_\_\_\_

CARRIER: **Erickson, Trucking Inc.**

SCAC

Carrier's No. **019**  
Date \_\_\_\_\_

TO: **LMC Corp.**  
600 S. 4th St.  
Richmond, Ca. 94805  
Zip

FROM: **Erickson, Inc.**  
Shipper **255 Parr Blvd.**  
Street **Richmond, Ca. 94801**  
Origin **Zip**

Route: \_\_\_\_\_

Vehicle Number \_\_\_\_\_

No Shipping Units	HM	Kind of Packages, Description of Articles (IF HAZARDOUS MATERIALS - PROPER SHIPPING NAME)	HAZARD CLASS	I.D. Number	WEIGHT (subject to correction)	RATE	LABELS REQUIRED (for exemption)
7		NON-D.O.T. REGULATED MATERIAL NON-HAZARDOUS, GAS FREE					
		UNDERGROUND STORAGE TANKS FOR SCRAP.					
		74071-5595	NONE	N/A	N/A	N/A	NONE
		74082-5584, 5583					
		74075-5580					
		74073- <del>5580</del>					
		74072-5568, 5571					

Remit C.O.D. to:  
Address: \_\_\_\_\_  
City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

**C.O.D. Amt:** \$ \_\_\_\_\_

**C.O.D. FEE:**  
Prepaid   
Collect  \$ \_\_\_\_\_

NOTE - Where the rate is dependent on value, shippers are required to state specifically in writing the agreed or declared value of the property. The agreed or declared value of the property is hereby specifically stated by the shipper to be not exceeding \$ \_\_\_\_\_ Per \_\_\_\_\_

Subject to Section 7 of the conditions, if this shipment is to be delivered to the consignee without recourse on the consignor, the consignor shall sign the following statement:  
The carrier shall not make delivery of this shipment without payment of freight and of other lawful charges.  
(Signature of Consignor)

**FREIGHT CHARGES**  
 PREPAID  COLLECT

RECEIVED, subject to the classifications and lawfully filed tariffs in effect on the date of issue of this Bill of Lading, the property described above in apparent good order, except as noted (contents and condition of contents of packages unknown), marked, consigned, and destined as indicated above which said carrier (the word carrier being understood throughout this contract as meaning any person or corporation in possession of the property under the contract) agrees to carry to its usual place of delivery at said destination, if on its route, otherwise to deliver to another carrier on the route to said destination. It is mutually agreed as to each carrier of all or any of, said property over all or any portion of said route to destination and as to each party at any time interested in all or any said property, that every service to be performed hereunder shall be subject to all the bill of lading terms and conditions in the governing classification on the date of shipment.  
Shipper hereby certifies that he is familiar with all the bill of lading terms and conditions in the governing classification and the said terms and conditions are hereby agreed to by the shipper and accepted for himself and his assigns.

This is to certify that the above-named materials are properly classified, described, packaged, marked and labeled and are in proper condition for transportation according to the applicable regulations of the Department of Transportation.

**PLACARDS REQUIRED**

**No**

**PLACARDS SUPPLIED**

YES  NO - FURNISHED BY CARRIER  
DRIVER SIGNATURE: \_\_\_\_\_

SHIPPER: **Erickson, Inc.**  
PER: **Shannan Lowry**  
DATE: **2-8-91**

CARRIER: \_\_\_\_\_  
PER: \_\_\_\_\_  
DATE: \_\_\_\_\_

EMERGENCY RESPONSE TELEPHONE NUMBER: \_\_\_\_\_

Manned 24 hours/day by a person with knowledge of the hazards of the material and emergency response information or who has access to a person with that knowledge.

Agent must detach and retain this Shipping Order and must sign the Original Bill of Lading.  
9-BLS-A3 (Rev. 5/90)

### WEIGHMASTER CERTIFICATE

THIS IS TO CERTIFY that the following described commodity was weighed, measured or counted by a weighmaster whose signature is on this certificate who is a recognized authority of accuracy as prescribed by Chapter 7 (commencing with Section 12700) of Division 5 of the California Business and Professions Code, administered by the Division of Measurement Standards of the California Department of Food and Agriculture.

**LMC METALS**  
A DIVISION OF SIMSMETAL USA CORPORATION  
600 SOUTH 4th STREET  
RICHMOND CALIFORNIA 94804  
(415) 238-0608

TICKET# 33437

ACCOUNT: 22168801  
ERICKSON INC.  
255 PARR BLVD.  
RICHMOND, CA  
CASH I.D.:

MATL. 10201-1 UNP  
PRICE / TON: \_\_\_\_\_  
TOTAL PRICE: \_\_\_\_\_  
WEIGHT ADJUSTMENT: 0 PERCENT: \*\*\*\*\*%  
INBOUND WEIGHT: 42740 Lbs.

42740 (M) Gross Weight Lbs.  
29480 Tare Weight Lbs.  
13260 Net Weight Lbs.

TRUCK NO. \_\_\_\_\_ LICENSE NO. \_\_\_\_\_  
DRIVER: \_\_\_\_\_  
2/08/91- 13:54 FRT. CODE: 1 COST: \$ 0.00  
2/08/91- 14:15

SIGNATURE OF SELLER OR AGENT  
**Diamond Perry**  
LMC METALS WEIGHMASTER  
2-86097

FOR SALVAGE VEHICLE SALES: I hereby certify, under penalty of perjury, that any vehicles sold have been cleared for dismantling with the Department of Motor Vehicles.

HOLD HARMLESS AGREEMENT: Seller will indemnify and hold buyer harmless from damages, demands and liabilities, including reasonable attorney's fees, resulting from the breach of any warranty hereunder and driver agrees to be responsible for damage to vehicle during unloading.

BILL OF SALE: I warrant that I am the owner (or owner's representative) of the material described herein and have the right to sell same. That it contains no hazardous material as defined by Federal or State law and that for payment hereby received, I sell and convey title to LMC METALS.

CUSTOMER COPY

IN CASE OF AN EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8802; WITHIN CALIFORNIA CALL 1-800-852-7550  
 GENERATOR  
 TRANSPORTER  
 FACILITY

<b>UNIFORM HAZARDOUS WASTE MANIFEST</b>		1. Generator's US EPA ID No. C A D 9 8 0 6 9 5 7 6 1		Manifest Document No. 217139		2. Page 1 of 1		Information in the shaded areas is not required by Federal law.		
3. Generator's Name and Mailing Address EVERGREEN ENVIRONMENTAL SERVICES 6880 Smith Avenue, Newark, CA 94560						A. State Manifest Document Number 89721829				
4. Generator's Phone ( 415 795-4410						B. State Generator's ID H A H Q 3 6 . 0 1 4 4 9 4				
5. Transporter 1 Company Name C.O.R.I. dba EVERGREEN ENVIRON. SERVICES				6. US EPA ID Number C A D 9 8 0 6 9 5 7 6 1		C. State Transporter's ID 107213		D. Transporter's Phone (800) 972-5284		
7. Transporter 2 Company Name				8. US EPA ID Number		E. State Transporter's ID		F. Transporter's Phone		
9. Designated Facility Name and Site Address EVERGREEN OIL INC. 6880 Smith Avenue Newark, CA 94560				10. US EPA ID Number C A D 9 8 0 8 8 7 4 1 8		G. State Facility's ID C A D 9 8 0 8 8 7 4 1 8		H. Facility's Phone (415) 795-4400		
11. US DOT Description (Including Proper Shipping Name, Hazard Class, and ID Number)						12. Containers No. Type		13. Total Quantity	14. Unit Wt/Vol	15. Waste No.
a. <input checked="" type="checkbox"/> WASTE PETROLEUM OILS, NOS, COMBUSTIBLE LIQUID, NA 1270						0 0 1 T T		2060 G		State 221 EPA/Other NONE
b.										State EPA/Other
c.										State EPA/Other
d.										State EPA/Other
J. Additional Descriptions for Materials Listed Above 1.1 - Waste oil with an undetermined amount of halogens. 1.2 - Waste Water						K. Handling Codes for Wastes Listed Above a. 01 b. c. d.				
16. Special Handling Instructions and Additional Information Wear Protective Clothing						EMERGENCY NO 415 795-4400 KIRK HAYWARD				
18. GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations. If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.										
Printed/Typed Name DAN SHRIGLEY				Signature <i>Don Shrigley</i>		Month Day Year 020691				
17. Transporter 1 Acknowledgement of Receipt of Materials										
Printed/Typed Name DAN SHRIGLEY				Signature <i>Don Shrigley</i>		Month Day Year 020691				
18. Transporter 2 Acknowledgement of Receipt of Materials										
Printed/Typed Name				Signature		Month Day Year				
19. Discrepancy Indication Space										
20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in item 19.										
Printed/Typed Name Diana Hernandez				Signature <i>Diana Hernandez</i>		Month Day Year 020691				

**ATTACHMENT C**

**Certified Analytical  
Reports**

# BSK Analytical Laboratories

1414 Stanislaus Street \* Fresno, California 93706 \* Telephone (209) 485-8310 \* Fax (209) 485-6935

Robert Y. Chew Geotechnical  
26203 Production Avenue, Suite 7  
Hayward, CA 94545

Report Issue Date: 02/21/91  
Date Received: 02/07/91  
Project Number: 91009

Lab Number	Date Sampled	Client's Sample Description	Date Analyzed
Ch910631-1	02/06/91	1525 hrs. West end of tank	02/11/91

Soil Analyses for BTXE, TPH, and TVH

Results Reported in Milligrams per Kilogram (mg/kg)

Compound	Lab.No. 0631-1	Detection Limit (DLR)
Benzene.....	ND	1.0
Toluene .....	ND	1.0
Ethylbenzene .....	16	1.0
Total Xylene Isomers .....	39	1.0
Total Petroleum Hydrocarbons	600*	10.00
Total Volatile Hydrocarbons	2200	500

Method: BTEX-EPA 8020 TPH-DHS GC/FID

DLR: Detection Limit For the Purposes of Reporting

ND: None Detected

\*This sample contains lower molecular weight Hydrocarbons.

  
Cynthia Pigman,  
QA/QC Supervisor

1000  
111

Michael Brechmann,  
Organics Supervisor

# BSK Analytical Laboratories

1414 Stanislaus Street \* Fresno, California 93706 \* Telephone (209) 485-8310 \* Fax (209) 485-6935

Robert Y. Chew Geotechnical  
26203 Production Avenue, Suite 7  
Hayward, CA 94545

Report Issue Date: 02/21/91  
Date Received: 02/07/91  
Project Number: 91009

<u>Lab Number</u>	<u>Date Sampled</u>	<u>Client's Sample Description</u>	<u>Date Analyzed</u>
Ch910631-2	02/06/91	1530 hrs. East end of tank	02/11/91

## Soil Analyses for BTXE, TPH, and TVH

Results Reported in Milligrams per Kilogram (mg/kg)


Compound	Lab.No. 0631-2	Detection Limit (DLR)
Benzene.....	ND	0.02
Toluene .....	ND	0.02
Ethylbenzene .....	10	0.02
Total Xylene Isomers .....	13	0.02
Total Petroleum Hydrocarbons	350*	10.00
Total Volatile Hydrocarbons	1300	10.00


Method: BTXE-EPA 8020 TPH-DHS GC/FID

DLR: Detection Limit For the Purposes of Reporting

ND: None Detected

\*This sample contains lower molecular weight Hydrocarbons.

  
Cynthia Pigman,  
QA/QC Supervisor

  
Michael Brechmann,  
Organics Supervisor

# BSK Analytical Laboratories

1414 Stanislaus Street \* Fresno, California 93706 \* Telephone (209) 485-8310 \* Fax (209) 485-6935

Robert Y. Chew Geotechnical  
26203 Production Avenue, Suite 7  
Hayward, CA 94545

Report Issue Date: 02/21/91  
Date Received: 02/07/91  
Project Number: 91009

<u>Lab Number</u>	<u>Date Sampled</u>	<u>Client's Sample Description</u>	<u>Date Analyzed</u>
Ch910631-1	02/06/91	1525 hrs. West end of tank	02/19/91
Ch910631-2	02/06/91	1530 hrs. East end of tank	02/19/91

Soil Analyses for  
Total Organic Lead


Results Reported in Milligrams per Kilogram (mg/kg)

Compound	Results 0631-1	Results 0631-2	Detection Limit (DLR)
Total Organic Lead .....	ND	ND	2.0

DLR: Detection Limit For the Purposes of Reporting

Method: DHS

ND: None Detected

  
Cynthia Pigman, QA/QC Supervisor

  
Doug Deasy, Inorganics Supervisor

# BSK Analytical Laboratories

1414 Stanislaus Street \* Fresno, California 93706 \* Telephone (209) 485-8310 \* Fax (209) 485-6935

Robert Y. Chew Geotechnical  
26203 Production Avenue, Suite 7  
Hayward, CA 94545

Report Issue Date: 02/21/91  
Date Received: 02/08/91  
Project Number: 91009

<u>Lab Number</u>	<u>Date Sampled</u>	<u>Client's Sample Description</u>	<u>Date Analyzed</u>
Ch910661-1	02/07/91	1405 hrs. North Wall (OX)	02/11/91

Soil Analyses for BTXE, TPH, and TVH

Results Reported in Milligrams per Kilogram (mg/kg)


Compound	Lab.No. 0661-1	Detection Limit (DLR)
Benzene.....	0.2	0.1
Toluene .....	ND	0.1
Ethylbenzene .....	1.9	0.1
Total Xylene Isomers .....	3.1	0.1
Total Petroleum Hydrocarbons	77*	10.00
Total Volatile Hydrocarbons	270	50


Method: BTXE-EPA 8020 TPH-DHS GC/FID

DLR: Detection Limit For the Purposes of Reporting

ND: None Detected

\*This sample contains lower molecular weight Hydrocarbons.

  
Cynthia Pigman,  
QA/QC Supervisor

  
Michael Brechmann,  
Organics Supervisor

# BSK Analytical Laboratories

1414 Stanislaus Street \* Fresno, California 93706 \* Telephone (209) 485-8310 \* Fax (209) 485-6935

Robert Y. Chew Geotechnical  
26203 Production Avenue, Suite 7  
Hayward, CA 94545

Report Issue Date: 02/21/91  
Date Received: 02/08/91  
Project Number: 91009

Lab Number	Date Sampled	Client's Sample Description	Date Analyzed
Ch910661-2	02/07/91	1409 hrs. East Wall (OX)	02/11/91

Soil Analyses for BTXE, TPH, and TVH

Results Reported in Milligrams per Kilogram (mg/kg)


Compound	Lab.No. 0661-2	Detection Limit (DLR)
Benzene.....	0.4	0.2
Toluene .....	ND	0.2
Ethylbenzene .....	3.9	0.2
Total Xylene Isomers .....	7.9	0.2
Total Petroleum Hydrocarbons	180*	10.00
Total Volatile Hydrocarbons	460	100


Method: BTXE-EPA 8020 TPH-DHS GC/FID

DLR: Detection Limit For the Purposes of Reporting

ND: None Detected

\*This sample contains lower molecular weight Hydrocarbons.

  
Cynthia Pigman,  
QA/QC Supervisor

  
Michael Brechmann,  
Organics Supervisor



# BSK Analytical Laboratories

1414 Stanislaus Street \* Fresno, California 93706 \* Telephone (209) 485-8310 \* Fax (209) 485-6935

Robert Y. Chew Geotechnical  
 26203 Production Avenue, Suite 7  
 Hayward, CA 94545

Report Issue Date: 02/21/91  
 Date Received: 02/08/91  
 Project Number: 91009

<u>Lab Number</u>	<u>Date Sampled</u>	<u>Client's Sample Description</u>	<u>Date Analyzed</u>
Ch910661-3	02/07/91	1413 hrs. South Wall (OX)	02/11/91

Soil Analyses for BTXE, TPH, and TVH

Results Reported in Milligrams per Kilogram (mg/kg)


Compound	Lab.No. 0661-3	Detection Limit (DLR)
Benzene.....	0.2	0.1
Toluene .....	ND	0.1
Ethylbenzene .....	1.1	0.1
Total Xylene Isomers .....	3.5	0.1
Total Petroleum Hydrocarbons	200*	10.00
Total Volatile Hydrocarbons	330	50


Method: BTXE-EPA 8020 TPH-DHS GC/FID

DLR: Detection Limit For the Purposes of Reporting

ND: None Detected

\*This sample contains lower molecular weight Hydrocarbons.

  
 Cynthia Pigman,  
 QA/QC Supervisor

  
 Michael Brechmann,  
 Organics Supervisor

# BSK Analytical Laboratories

1414 Stanislaus Street \* Fresno, California 93706 \* Telephone (209) 485-8310 \* Fax (209) 485-6935

Robert Y. Chew Geotechnical  
26203 Production Avenue, Suite 7  
Hayward, CA 94545

Report Issue Date: 02/21/91  
Date Received: 02/08/91  
Project Number: 91009

<u>Lab Number</u>	<u>Date Sampled</u>	<u>Client's Sample Description</u>	<u>Date Analyzed</u>
Ch910661-4	02/07/91	1417 hrs. West Wall (OX)	02/11/91

Soil Analyses for BTXE, TPH, and TVH

Results Reported in Milligrams per Kilogram (mg/kg)


Compound	Lab.No. 0661-4	Detection Limit (DLR)
Benzene.....	ND	1.0
Toluene .....	ND	1.0
Ethylbenzene .....	12	1.0
Total Xylene Isomers .....	16	1.0
Total Petroleum Hydrocarbons	1200*	10.00
Total Volatile Hydrocarbons	1500	500


Method: BTXE-EPA 8020 TPH-DHS GC/FID

DLR: Detection Limit For the Purposes of Reporting

ND: None Detected

\*This sample contains lower molecular weight Hydrocarbons.

  
Cynthia Pigman,  
QA/QC Supervisor

  
Michael Brechmann,  
Organics Supervisor

# BSK Analytical Laboratories

1414 Stanislaus Street \* Fresno, California 93706 \* Telephone (209) 485-8310 \* Fax (209) 485-6935

Robert Y. Chew Geotechnical  
26203 Production Avenue, Suite 7  
Hayward, CA 94545

Report Issue Date: 02/21/91  
Date Received: 02/08/91  
Project Number: 91009

Lab Number	Date Sampled	Client's Sample Description	Date Analyzed
Ch910661-5	02/07/91	1421 hrs. Center - Bottom (OX)	02/11/91

Soil Analyses for BTXE, TPH, and TVH

Results Reported in Milligrams per Kilogram (mg/kg)

Compound	Lab.No. 0661-5	Detection Limit (DLR)
Benzene.....	ND	0.2
Toluene .....	ND	0.2
Ethylbenzene .....	4.3	0.2
Total Xylene Isomers .....	5.7	0.2
Total Petroleum Hydrocarbons	300*	10.00
Total Volatile Hydrocarbons	610	100


Method: BTXE-EPA 8020 TPH-DHS GC/FID

DLR: Detection Limit For the Purposes of Reporting

ND: None Detected

\*This sample contains lower molecular weight Hydrocarbons.

  
Cynthia Pigman,  
QA/QC Supervisor

  
Michael Brechmann,  
Organics Supervisor

# BSK Analytical Laboratories

1414 Stanislaus Street \* Fresno, California 93706 \* Telephone (209) 485-8310 \* Fax (209) 485-6935

Robert Y. Chew Geotechnical  
 26203 Production Avenue, Suite 7  
 Hayward, CA 94545

Report Issue Date: 02/21/91  
 Date Received: 02/08/91  
 Project Number: 91009


<u>Lab Number</u>	<u>Date Sampled</u>	<u>Client's Sample Description</u>	<u>Date Analyzed</u>
Ch910661-1	02/07/91	1405 hrs. North Wall (OX)	02/19/91
Ch910661-2	02/07/91	1409 hrs. East Wall (OX)	02/19/91


Soil Analyses for  
 Total Organic Lead

Results Reported in Milligrams per Kilogram (mg/kg)

Compound	Results 0661-1	Results 0661-2	Detection Limit (DLR)
Total Organic Lead .....	ND	ND	2.0

DLR: Detection Limit For the Purposes of Reporting  
 Method: DHS  
 ND: None Detected

  
 Cynthia Pigman, QA/QC Supervisor

  
 Doug Deasy, Inorganics Supervisor

# BSK Analytical Laboratories

1414 Stanislaus Street \* Fresno, California 93706 \* Telephone (209) 485-8310 \* Fax (209) 485-6935

Robert Y. Chew Geotechnical  
 26203 Production Avenue, Suite 7  
 Hayward, CA 94545

Report Issue Date: 02/21/91  
 Date Received: 02/08/91  
 Project Number: 91009

Lab Number	Date Sampled	Client's Sample Description		Date Analyzed
Ch910661-3	02/07/91	1413 hrs.	South Wall (OX)	02/19/91
Ch910661-4	02/07/91	1417 hrs.	West Wall (OX)	02/19/91

Soil Analyses for  
 Total Organic Lead


Results Reported in Milligrams per Kilogram (mg/kg)


Compound	Results 0661-3	Results 0661-4	Detection Limit (DLR)
Total Organic Lead .....	ND	ND	2.0

DLR: Detection Limit For the Purposes of Reporting

Method: DHS

ND: None Detected

  
 Cynthia Pigman, QA/QC Supervisor

  
 Doug Deasy, Inorganics Supervisor

# BSK Analytical Laboratories

1414 Stanislaus Street \* Fresno, California 93706 \* Telephone (209) 485-8310 \* Fax (209) 485-6935

Robert Y. Chew Geotechnical  
26203 Production Avenue, Suite 7  
Hayward, CA 94545

Report Issue Date: 02/21/91  
Date Received: 02/08/91  
Project Number: 91009


<u>Lab Number</u>	<u>Date Sampled</u>	<u>Client's Sample Description</u>	<u>Date Analyzed</u>
Ch910661-5	02/07/91	1421 hrs. Center - Bottom (OX)	02/19/91


Soil Analyses for  
Total Organic Lead

Results Reported in Milligrams per Kilogram (mg/kg)

Compound	Results 0661-5	Detection Limit (DLR)
Total Organic Lead .....	ND	2.0

DLR: Detection Limit For the Purposes of Reporting  
Method: DHS  
ND: None Detected

  
Cynthia Pigman, QA/QC Supervisor

  
Doug Deasy, Inorganics Supervisor

U667

1000-7682

BSK Log Number \_\_\_\_\_

ANALYSIS REQUEST/CHAIN OF CUSTODY RECORD

Client Name <b>R&amp;J Quick Clean</b>			Project or P.O.# <b>Project No. 91009</b>			Lab Use Only in this section Analysis required TPH-G/BTEX TPH-D TETRA-ETH Lead Hazardous sample Special handling required						
Address <b>2517 San Carlos (2522 Castro Valley Blvd.)</b>			Phone #									
City, State, Zip <b>Castro Valley, CA 94546</b>			Report, attention <b>Robert Chew</b>			2/21/91						
Date sampled	Time sampled	Type (See key below)	Sampled by <b>PCG</b>	Number of containers	Lab Sample number							Sample Seals (See key below)
2/7/91	2:05 PM	SO	North wall (OX)	1	-1	A	1	1	1	ix soil Tube		
2/7/91	2:09 PM	SO	East wall (OX)	1	-2	↓	1	1	1	↓		
2/7/91	2:13 PM	SO	South wall (OX)	1	-3	↓	1	1	1			
2/7/91	2:12 PM	SO	West wall (OX)	1	-4	↓	1	1	1			
2/7/91	2:21 PM	SO	center-bottom (OX)	1	-5	↓	1	1	1			

**IMPORTANT NOTICE:** No samples will be analyzed without an authorized signature in this section.

I am hereby requesting BSK's Normal Chain-of-Custody Procedures for the above samples. I understand that these procedures are generally consistent with those outlined in the US EPA SW 846 and that there is no extra charge for this service.

By: Rod R. Schurman  
Authorized Signature

I am hereby requesting BSK's Formal Chain-of-Custody Procedures for the above samples. I understand that these procedures are generally consistent with those outlined in U.S. EPA Contract Laboratory Program Statement of Work, Section F, and that there is a charge of \$5000 per work order or \$500 a bottle, whichever is greater.

By: \_\_\_\_\_  
Authorized Signature

Signature	Print Name	Company	Date	Time
<u>Rod R. Schurman</u>	Rod R. Schurman	Robert Y. Chew Geotechnical, Inc	2/7/91	2:25 PM
<u>Mickey Clemons</u>	MOBERNICE	BSK Lab	2/8/91	0930
Relinquished by				
Received by				
Relinquished by				
Received by				

**BSK** & Associates Chemical Laboratories

1414 Stanislaus Street Fresno, California 93706

Telephone (209) 485-8310 • Fax (209) 485-7427

**KEY:** Type: AQ-Aqueous SL-Sludge SO-Soil PE-Petroleum OT-Other

Seals: P-Present A-Absent B-Broken

DISTRIBUTION: WHITE, CANARY - LABORATORY PINK - ORIGINATOR

Note:

Samples are discarded 14 days after results are reported unless other arrangements are made

Hazardous samples will be returned to client or disposed of at client expense.

0651

ANALYSIS REQUEST/CHAIN OF CUSTODY RECORD

Client Name <i>R&amp;J Quick Clean</i>			Project or P.O.# <i>Proj. No 41008</i>			Lab Use Only in this section <i>TPH-G/B/T/X/E</i> <i>TPH-D</i> <i>TETRA-ETHYL LEAD</i>						Analysis required											
Address <i>2517 San Carlos (2522 Castro Valley Blvd)</i>			Phone #									Hazardous sample Special handling required						<i>2/20/91</i>					
City, State, Zip <i>Castro Valley, CA 94546</i>			Report, attention <i>ROBERT CITEW</i>																				
Date sampled	Time sampled	Type (See key below)	Sampled by	Number of containers	Lab Sample number	Sample Seals (See key below)							Remarks										
			<i>DCG</i>																				
<i>2/6/91</i>	<i>3:25 pm</i>	<i>SO</i>	<i>West End of Tank</i>	<i>1</i>	<i>-1</i>	<i>A</i>	<i>1</i>	<i>1</i>	<i>1</i>							<i>1X SOIL TUBE</i>							
<i>2/6/91</i>	<i>3:30 pm</i>	<i>SO</i>	<i>East End of Tank</i>	<i>1</i>	<i>-2</i>	<i>✓</i>	<i>1</i>	<i>1</i>	<i>1</i>							<i>✓</i>							

IMPORTANT NOTICE: No samples will be analyzed without an authorized signature in this section.

I am hereby requesting BSK's Normal Chain-of-Custody Procedures for the above samples. I understand that these procedures are generally consistent with those outlined in the US E.P.A. SW 846 and that there is no extra charge for this service.

By: *Robert Citew*  
Authorized Signature

I am hereby requesting BSK's Formal Chain-of-Custody Procedures for the above samples. I understand that these procedures are generally consistent with those outlined in U.S. EPA Contract Laboratory Program Statement of Work, Section F, and that there is a charge of \$50.00 per work order or \$5.00 a bottle, whichever is greater.

By: \_\_\_\_\_  
Authorized Signature

Signature	Print Name	Company	Date	Time
<i>Robert Citew</i>	<i>ROBERT CITEW</i>	<i>ROBERT Y. CITEW GEOTECHNICAL, INC.</i>	<i>2/6/91</i>	<i>4:45 pm</i>
<i>Jos. Estrada</i>	<i>Jo. Estrada</i>	<i>LAB</i>	<i>2/7/91</i>	<i>0830</i>
Relinquished by				
Received by				
Relinquished by				
Received by				

**BSK** & Associates Chemical Laboratories

1414 Stanislaus Street Fresno, California 93706  
Telephone (209) 485-8310 • Fax (209) 485-7427

**KEY:** Type: AQ-Aqueous SL-Sludge SO-Soil PE-Petroleum OT-Other  
Seals: P-Present A-Absent B-Broken  
DISTRIBUTION: WHITE, CANARY - LABORATORY PINK - ORIGINATOR  
Note:  
Samples are discarded 14 days after results are reported unless other arrangements are made.  
Hazardous samples will be returned to client or disposed of at client expense.