

PETROLEUM ENGINEERING, INC

GENERAL CONTRACTORS
205 FIFTH STREET • SANTA ROSA, CA 95401 • PHONE (707) 545-0360 • LICENSE NO. 224358

LETTER OF TRANSMITTAL

Texaco, U.S.A.
1670 South Amphlett Boulevard, Suite 215
San Mateo, California 94402
ATTN Mr. H. A. Peth

DATE October 5, 1984
PROJECT Texaco Service Station
62-488-0450
3940 Castro Valley Boulevard
Castro Valley, California

WE ARE SENDING YOU THE FOLLOWING ITEMS:

- | | | | | |
|---|---|--|--|----------------------------------|
| <input type="checkbox"/> PRINTS | <input type="checkbox"/> SHOP DRAWINGS | <input type="checkbox"/> PLANS | <input type="checkbox"/> SPECIFICATION | <input type="checkbox"/> SAMPLES |
| <input type="checkbox"/> MAINT & OPR INST | <input type="checkbox"/> COPY OF LETTER | <input checked="" type="checkbox"/> <u>Data Charts - Tank Test</u> | | |

COPIES	DATE	NO.	DESCRIPTION
3	9/6/84		Petro-Tite data chart for tank system tightness test

THESE ARE TRANSMITTED AS CHECKED BELOW:

- | | | |
|---|---|---|
| <input type="checkbox"/> FOR APPROVAL | <input type="checkbox"/> APPROVED AS SUBMITTED | <input type="checkbox"/> RESUBMIT _____ COPIES FOR APPROVAL |
| <input checked="" type="checkbox"/> FOR YOUR USE | <input type="checkbox"/> APPROVED AS NOTED | <input type="checkbox"/> SUBMIT _____ COPIES FOR DISTRIBUTION |
| <input checked="" type="checkbox"/> AS REQUESTED | <input type="checkbox"/> RETURNED FOR CORRECTIONS | <input type="checkbox"/> RETURN _____ CORRECTED PRINTS |
| <input type="checkbox"/> FOR REVIEW AND COMMENT | <input type="checkbox"/> _____ | |
| <input type="checkbox"/> FOR BIDS DUE _____ 19_____ | <input type="checkbox"/> PRINTS RETURNED AFTER LOAN TO US | |

REMARKS All tanks tested tight.

SIGNED: *Donald C. Marchant*
Donald C. Marchant

Data Chart for Tank System Tightness Test

petro title
TANK TESTER

PLEASE PRINT

<p>1. OWNER <input type="checkbox"/> Property <input type="checkbox"/> Tank(s)</p>	<p>TEXACO 3940 Castro Valley Blvd Castro Valley</p> <p>Name: _____ Address: _____ Representative: _____ Telephone: _____</p> <p>Name: _____ Address: _____ Representative: _____ Telephone: _____</p>																				
<p>2. OPERATOR</p>	<p>Station closed</p> <p>Name: _____ Address: _____ Telephone: _____</p>																				
<p>3. REASON FOR TEST (Explain Fully)</p>	<p>GASOLINE found in sewer at bottom of hill.</p>																				
<p>4. WHO REQUESTED TEST AND WHEN</p>	<p>Castro Valley Fire Dept. - Hank Peth engineer - Texaco</p> <p>Name: _____ Title: _____ Company/pt Affiliation: _____ Date: _____</p> <p>Address: _____ Telephone: _____</p>																				
<p>5. WHO IS PAYING FOR THIS TEST?</p>	<p>TEXACO Hank Peth</p> <p>Company, Agency or Individual: _____ Person Authorizing: _____ Title: _____ Telephone: _____</p> <p>Billing Address: _____ City: _____ State: _____ Zip: _____</p> <p>Attention of: _____ Order No. _____ Other Instructions: _____</p>																				
<p>6. TANK(S) INVOLVED</p>	Identify by Direction	Capacity	Brand/Supplier	Grade	Approx. Age	Steel/Fiberglass															
	2-Eastern tanks	2/4,000	TEXACO	Super Unleaded	?	Steel															
	Southern	6,000	"	Unleaded	?	"															
	Western	6,000	"	Regular	?	"															
<p>7. INSTALLATION DATA</p>	Location	Cover	Fills	Vents	Siphones	Pumps															
	Front of Lube bays	6" concrete	4" drop tubes removed	2"	2-4,000	Red jacket removed															
	North inside driveway, Rear of station, etc.	Concrete, Black Top, Earth, etc.	Size, Titofill make, Drop tubes, Remote Fills	Size, Manifoldded	Which tanks?	Suction, Remote Make if known															
<p>8. UNDERGROUND WATER</p>	<p>Depth to the Water table _____"</p> <p>Is the water over the tank? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p>																				
<p>9. FILL-UP ARRANGEMENTS</p>	<p>Tanks to be filled _____ hr. _____ Date Arranged by _____</p> <p>Extra product to "top off" and run TSTT. How and who to provide? Consider NO Lead.</p> <p>Using water as test agent - Water taken from Fire hydrant</p> <p>Terminal or other contact for notice or inquiry _____</p> <p>Company: _____ Name: _____ Telephone: _____</p>																				
<p>10. CONTRACTOR, MECHANICS, any other contractor involved</p>	<p>Petroleum Eng - Mitch Hassfeld</p> <p>205 5th St Santa Rosa CA</p>																				
<p>11. OTHER INFORMATION OR REMARKS</p>	<p>Water used as test agent - Castro Valley Fire Dept. on location</p> <p>Additional information on any items above. Officials or others to be advised when testing is in progress or completed. Visitors or observers present during test etc.</p>																				
<p>12. TEST RESULTS</p>	<p>Tests were made on the above tank systems in accordance with test procedures prescribed for petro title as detailed on attached test charts with results as follows:</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 40%;">Tank Identification</th> <th style="width: 15%;">Tight</th> <th style="width: 25%;">Leakage Indicated</th> <th style="width: 20%;">Date Tested</th> </tr> </thead> <tbody> <tr> <td>Regular</td> <td style="text-align: center;"><input checked="" type="checkbox"/></td> <td></td> <td>9/5/04</td> </tr> <tr> <td>Unleaded</td> <td style="text-align: center;"><input checked="" type="checkbox"/></td> <td></td> <td>9/7/04</td> </tr> <tr> <td>Super Unleaded</td> <td style="text-align: center;"><input checked="" type="checkbox"/></td> <td></td> <td>9/6/04</td> </tr> </tbody> </table>					Tank Identification	Tight	Leakage Indicated	Date Tested	Regular	<input checked="" type="checkbox"/>		9/5/04	Unleaded	<input checked="" type="checkbox"/>		9/7/04	Super Unleaded	<input checked="" type="checkbox"/>		9/6/04
Tank Identification	Tight	Leakage Indicated	Date Tested																		
Regular	<input checked="" type="checkbox"/>		9/5/04																		
Unleaded	<input checked="" type="checkbox"/>		9/7/04																		
Super Unleaded	<input checked="" type="checkbox"/>		9/6/04																		
<p>13. CERTIFICATION</p>	<p>This is to certify that these tank systems were tested on the date(s) shown. Those indicated as "Tight" meet the criteria established by the National Fire Protection Association Pamphlet 329.</p> <p>9/7/04</p> <p>565 / 674</p> <p>Serial No of Thermal Tester</p> <p>Mitch Hassfeld</p> <p>Technician</p> <p>Petroleum Eng</p> <p>Testing Contractor or Company. By: Mitch Hassfeld Signature</p> <p>205 5th St - Santa Rosa CA</p> <p>Address</p>																				