

ALAMEDA COUNTY  
HEALTH CARE SERVICES

AGENCY

DAVID J. KEARS, Agency Director



R0974

DEPARTMENT OF ENVIRONMENTAL HEALTH  
Hazardous Materials Program  
80 Swan Way, Rm. 200  
Oakland, CA 94621  
(415)

August 16, 1990

Rigo Bolanos  
Southland Corporation  
40563 Encyclopedia Circle  
Fremont CA 94538

RE: 7-Eleven Store #19035C  
100 Lewelling Blvd.  
San Lorenzo CA 94580

**SECOND NOTICE OF VIOLATION**

Dear Mr. Bolanos:

On June 4, 1990, you were issued a Notice of Violation as the result of violations noted during my inspection of May 8, 1990. Since June 4, a precision tank test has been received by this office. However, no Hazardous Materials Business Plan has been received. Sections 25505 and 25505.3 of the Health and Safety Code require that businesses handling hazardous materials such as motor fuel prepare and submit a hazardous materials management plan to the administering agency.

**A Business Plan for the above referenced site must be submitted to this office by August 31, 1990. Any business failing to submit this document may be liable for civil penalties of up to \$2000 per day.**

You may contact me at 271-4320 with any questions.

Sincerely,

Pamela J. Evans  
Hazardous Materials Specialist

c: Gil Jensen, Alameda County District Attorney's Office  
James and Stella Wu, Franchise Holders



DEPARTMENT OF ENVIRONMENTAL HEALTH  
Hazardous Materials Program  
80 Swan Way, Rm. 200  
Oakland, CA 94621  
(415)

June 4, 1990

Rigo Bolanos  
Southland Corporation  
40563 Encyclopedia Circle  
Fremont CA 94538

Re: 7-Eleven Store #19035C  
100 Lewelling Blvd.  
San Lorenzo CA 94580

**NOTICE OF VIOLATION**

Dear Mr. Bolanos:

On May 8, 1990, Hazardous Materials Specialist Pamela Evans inspected the above premises. Three underground fuel storage tanks owned by Southland Corporation are operated at this location. During this inspection, Ms. Evans noted the following violations of the California Health and Safety Code and California Code of Regulations, Title 23:

1. Sections 25505 and 25503.5 (a), (H&SC) - No Hazardous Materials Business Plan for the above referenced establishment has been submitted to this office. Businesses handling hazardous materials, such as motor fuel, are required to prepare and submit a business plan for emergency response to a release or threatened release of hazardous material.
2. Section 2643 (e), (CCR) - No precision tank test results have been submitted to this agency for the underground tanks at the above referenced facility. A tank test report is required within 30 days of leak detection test.

As specified on the inspection report, the Business Plan, Quarterly reports, and precision tank test results for the past year must be submitted by June 8, 1990. You may contact Hazardous Materials Specialist Pamela Evans at 271-4320 with any questions.

Sincerely,

Edgar B. Howell, Chief  
Hazardous Materials Division

EBH:PJE

c: Gil Jensen, Alameda County District Attorney's Office