

FILE OR ENVELOPE
 PER NO. Removal No. of
 OWNER Old Herald News
 Address 6207 Sierra Ct
 Dublin Phone
 Contractor Tom Daniels
 Address PO Box 335
 Danville Phone
 OTHER (Specify)
 Address
 Phone
 CONTACT FOR INVESTIGATION

PLAN REVIEW
 \$ 432⁰⁰ Rec'd. 1/15/91
 No. Plans Rec'd.
 Plans Approved
 Layout Made
 Rejected
 Applicant Notified
 Plans Returned
 Permit Issued
 CONSTRUCTION
 Pre-Plaster/drywall
 Pre-Final
 Final
 POOL
 Pre-Concrete/Gunite
 Pre-Plaster
 Final
 Absorption Bed
 OTHER

MICHAEL DESCHENES
 ENVIRONMENTAL GEOLOGIST
 2950 Buskirk Avenue, Suite 120
 Walnut Creek, CA 94596
 (415) 934-4884
 FAX: 934-0418
 Aqua Terra Technologies
 Consulting Engineers & Scientists
 ATT

3728

XR	Date	By	REMARKS	LOCATION
	begin 9-30 AM			
5/9/91	Rem	HAH	200.515 (under ID #) O ₂ → 18% EL → 6% fire dept. O.K. Tank looks O.K. However, the pit samples (two on both ends) Smell (and also oil drops) gas. 2 soil samples → Pit 1 soil sample → pile. no water in the pit. end 11:30	
		6/2/92	EL	Call Mr Kent for reports - Says they will be here next week - prepared 2nd notice of violation
		7/21	a	Spoke w/ Mark Thompson. He wants to know what the site situation is like. If vacant lot or ongoing business
		7/22	EL	Site visit. Facility is GE Consumer Service. no MW noticed. no soil stockpile.
		7/24	EL	Referred to M. Thompson for information
3/19/91	Rem		Site visit with Aqua Terra one monitoring well	

Vicinity Map
 US 77190
 \$ 432⁰⁰
 Jan 15, 1991
 Greg Kent 828 7810
 6207 Sierra Ct.
 Dublin, CA 94568
 OLD HERALD NEWS
 S+ID
 13728