

7/15/92

Spoke w/ David Blunt at Mittelhauser Corp.

R.

He feels well screen was installed at 20-30' BGS because of confined aquifer and should not affect water sample results. Water sample was also taken in June '92 w/ N.D.

FILE OR PER NO.	ENVELOPE No. _____ of _____	PLAN REVIEW \$ 642.00 No. 592301 Plans Approved Layout Made Rejected Applicant Notified Plans Returned Permit Issued CONSTRUCTION PROGRESS ACCEPTANCE	By ELC ELC	Date 1/23/91 1/23/91	By Date	By Date	By Date
<input type="checkbox"/> OWNER BEDFORD PROPERTIES Address 7470 GOLDEN GATE DR. DUBLIN, CA Phone 275-8162 94568	<input type="checkbox"/> CONTRACTOR W.A. CROSS Address P.O. BOX 448 NAPA, CA 94559 Phone 525-2780	FOOD Pre-Plaster/Drywall Pre-Final Final	POOL Pre-Concrete/Gunite Pre-Plaster Final	EXCAVATION Septic Tank Absorption Field Absorption Bed House Sewer	FINAL Septic Tank Absorption Field Absorption Bed	OTHER	U.G. TANKS Pre-Covering Final
<input type="checkbox"/> OTHER (Specify)	Address Phone						
<input type="checkbox"/> CONTACT FOR INVESTIGATION							

373

R01150

R01150

3500gal	10,000gal	REMARKS
Date	By	REMARKS
1/19/91	Rain	Plan review and approved
1/28/91	Rain	1 EL 0% O ₂ 12%. Tank I
		1 EL 0% O ₂ 12%. Tank II
		Trident Truck Line
		DHS # 106097 (91)
		CAL.T. 115587
		Tank I - 10,000gals (diesel)
		look no holes / pit
		Waters from yesterdays drain
		no "sheen" on the pit
		Tank II 3500 gal (gas)
		no holes / no "sheen"

REMARKS	
Date	By
7/17/92	EL
7/18	EL
7/15	EL
7/17	EL
8/10/92	EL
8/17/92	EL

LOCATION: manure dropper
DEB JIM 3/1/91

Vicinity Map
Project # 592301
Fee Paid \$642.00
Date 1/23/91

Parnia Kaboli
743-0335

Roger Papler
2401 Crow Canyon Dr.
San Ramon
CA 94583

6700 Golden Gate Dr.
Dublin, CA 94568
BEDFORD PROPERTIES

1541D
13731