

ALAMEDA COUNTY
HEALTH CARE SERVICES

AGENCY
DAVID J. KEARS, Agency Director



ENVIRONMENTAL HEALTH SERVICES
ENVIRONMENTAL PROTECTION
1131 Harbor Bay Parkway, Suite 250
Alameda, CA 94502-6577
(510) 567-6700
FAX (510) 337-9335

August 14, 2001
SLIC 3633/CO0000369

Mr. Bob Cochran
Chevron Products Co.
P.O. Box 6004
San Ramon, CA 94583

**Re: No Further Action for Diesel Fuel Release at Chevron Facility #20-6142, 333 23rd St.,
Oakland CA 94606**

Dear Mr. Cochran:

Our office has received and reviewed the technical reports pertaining to the investigation of an accidental discharge of diesel fuel into a monitoring well at the above referenced site. As you are aware, in 1985 an accidental discharge of approximately 6000 gallons of diesel fuel occurred in well B at the above referenced site. Remediation has consisted of the following:

- Removal of approximately 3300 gallons using a vacuum truck
- Removal of 200 gallons via an oil skimmer
- Removal of approximately 250 gallons using a recovery pump in well R-1
- Removal of impacted groundwater via a groundwater extraction system

After the extraction system was turned off, oxygen releasing compound was added to MW-1, MW-9, MW-10, MW-7, MW-8 and MW-11. Long term groundwater monitoring from a total of fourteen (14) wells has demonstrated that the petroleum plume is has been adequately characterized and does not appear to be a threat to the nearby surface water. Our office has conferred with the San Francisco Regional Water Quality Control Board.

Based upon the available information and with the provision that the information provided to this agency was accurate and representative of site conditions, no further action related to the subsurface contamination from the accidental discharge of diesel fuel is required by Alameda County Department of Environmental Protection.

If you have any further questions concerning this matter, please contact Barney Chan at (510) 567-6765.

Sincerely,

Mee Ling Tung, Director
Environmental Protection

c: Roger Brewer, SF-RWQCB
S. Carter, Gettler-Ryan, 6747 Sierra Ct., Suite J, Dublin, CA 94568
NFA333 23rd St SLIC