



Alameda County
OCT 1 2003
Environmental Health

TANK CLOSURE REPORT

600 Central Avenue
Alameda, California
Job No. 8375
September 2, 2003

Prepared For:

Mr. George Haldeman
3286 Jackson Street
San Francisco, CA 94118

Tracy Wallace
Registered Environmental Assessor




TABLE OF CONTENTS

COVER SHEET

TABLE OF CONTENTS

1. SITE LOCATION	1
2. SITE HISTORY	1
3. TANK REMOVAL	1
4. TANK AND SOIL CONDITION	1
5. TANK REMOVAL SAMPLING	2
6. TANK REMOVAL SAMPLE RESULTS	2
7. WASTE MANAGEMENT	3
8. SITE RESTORATION	3
9. FINDINGS / RECOMMENDATION	3

ATTACHMENTS

1. SITE LOCATION

The subject multi-residential property is located at 600 Central Avenue, just west of the intersection of Central and McKay Avenues in Alameda, California. Figure 1 attached shows the general site vicinity. The approximate location of the tank as well as nearby streets is shown on the attached Figure 2. Photographs of the tank removal activities are shown on the attached Figure 3.

2. SITE HISTORY

One underground heating oil storage tank was located on the south side of the building structure in the rear parking lot of the property. The tank had a capacity of approximately 1,500 gallons, measuring about 10 feet long by 5 feet in diameter, and was constructed of steel. The fill port was located on the west end of the tank. The age of the tank is unknown but is believed to be between 60 and 80 years old. The owner had no knowledge of the tank nor are there any indications of previous site investigation activities.

3. TANK REMOVAL

Golden Gate Tank Removal, Inc. (GGTR) applied for and obtained permits from the Alameda Health Care Services Agency (ACHCSA), the City of Alameda Fire Department and OSHA. All site work was performed in accordance with state and local regulations.

In July 2003, GGTR mobilized its equipment and began work on the project. The concrete and/or asphalt pavement covering the tank was removed and disposed at a local recycler. The overburden soil covering the tank was removed and placed in a covered stockpile adjacent to the south side of the tank excavation. Measurements indicated the bottom of the tank to be 8 feet below grade elevation.

As part of the removal operations, GGTR contracted Clearwater Environmental to pump the residual product from the tank into a tanker truck. GGTR then cleaned the interior of the tank by pressure washing with 180-degree water under 3000-psi pressure. A non-toxic enzyme was used to break down thick oil deposits. Clearwater Environmental then removed the wash and rinse water from the tank and transported the Non-RCRA hazardous waste liquid (1,400 Gallons) under Uniform Waste Manifest No. 22535740. A copy of the liquid waste manifest is attached.

On July 14, 2003, GGTR removed the tank from the excavation. After a visual inspection, the tank was then loaded onto a flatbed truck and transported under Uniform Waste Manifest No. 22490575 by Ecology Control Industries to their disposal facility in Richmond, California. A copy of the Waste Manifest and Certificate of Tank Destruction is attached.

4. TANK AND SOIL CONDITION

The tank was found to be in good condition with no visible holes. Discoloration and hydrocarbon odor was noted in the soil underlying the tank, which was over-excavated to the extent feasible, and subsequently removed and stockpiled. The overburden soil was

clay and the soil underlying the tank was predominantly clay. Groundwater was observed in the bottom of the excavation, which appeared to have a slight sheen of product on its surface. The ACHCSA requested that an Underground Storage Tank Unauthorized Release (LEAK) / Contamination Site Report be submitted. A copy of the completed LEAK report is attached.

5. TANK REMOVAL SAMPLING

Immediately following tank removal activities, GGTR collected one four-point composite soil sample from the soil stockpile containing the overburden soil, which contained less than 20 cubic yards of soil. The composite stockpile sample was labeled 8375-SP. Due to the groundwater in the excavation, no soil sample was collected from the bottom of the excavation. However, under the direction of Mr. Robert Weston of the ACHCSA, GGTR pumped the groundwater in the excavation prior to sampling.

On July 15, 2003, GGTR returned to the site and collected a grab sample from the surface of the groundwater that re-entered the excavation. The grab groundwater sample was labeled 8375-W2. On July 31, 2003, at the request of Mr. Weston, GGTR collected another grab sample of the groundwater in the excavation to submit for additional analysis. The sample locations are shown on the attached Figure 2. All samples were transported to North State Environmental Analytical Laboratory (CA ELAP # 1735) under formal chain-of-custody protocol for the required analyses.

6. TANK REMOVAL SAMPLE RESULTS

The stockpile composite soil sample and grab groundwater samples were analyzed for Total Petroleum Hydrocarbons (TPH) as Diesel (TPH-D; EPA Method 8015M), TPH as Gasoline (TPH-G; SW8020F), Benzene, Toluene, Ethylbenzene and Total Xylenes (BTEX; EPA Methods 5030/8020F) and Methyl Tertiary-Butyl Ether (MTBE; EPA Methods 5030/8020F). The grab groundwater sample (8375-W2) was additionally analyzed for Volatile Organic Compounds (VOCs; EPA Method 8260). Table 1 below summarizes the analytical results for the tank removal samples. "ND" indicates Non-Detectable results. A copy of each laboratory certificate of analysis and chain of custody form is attached.

TABLE 1
TANK REMOVAL SAMPLE RESULTS

SAMPLE ID	TPH-D (ppm)	TPH-G (ppm)	B (ppm)	T (ppm)	E (ppm)	X (ppm)	MTBE (ppm)	VOC * (ppm)
8375-SP (Stockpile)	ND	--	ND	ND	ND	ND	ND	--
8375-W2	ND	0.296	--	--	--	--	--	0.065
8375-W3	2.89	0.083	ND	0.0007	ND	0.0012	ND	--

Note: ppm - parts per million [equivalent to milligrams per kilogram (mg/kg)]

-- - not analyzed for this constituent

* - reported as total concentration of VOCs (0.052 ppm chloroform, 0.001 ppm 1,3,5-trimethylbenzene, 0.003 1,2,4-trimethylbenzene, 0.009 ppm naphthalene)

7. WASTE MANAGEMENT

On July 31 and August 4, 2003, as directed by Mr. Weston of the ACHCSA, GGTR removed the stockpiled overburden and over-excavated soil from the site and loaded the soil directly into dump trucks. Poli Trucking transported approximately 36 tons of soil under Non-hazardous Waste Manifest Nos. 50851 and 50852 to Class II Forward Landfill facility in Manteca, California. A copy of each manifest and associated weight ticket is attached.

8. SITE RESTORATION


By August 4, 2003, as approved by the ACHCSA, GGTR backfilled the excavation with clean imported drain rock and soil. The excavation backfill soil was subsequently compacted and the surface was repaved to restore original site conditions.

9. FINDINGS / RECOMMENDATION

No visible holes were observed in the tank. However, discoloration and odor were observed in the soil underlying the tank, which was over-excavated to the extent feasible and disposed at State-licensed, Class II landfill facility. Soil beneath the tank was predominantly clay. Groundwater was observed in the bottom of the excavation during the tank removal and sampling activities. The State-Certified Laboratory analytical results of the stockpile composite soil and grab groundwater samples were below the State Action Levels. Based on these findings, it is the recommendation of Golden Gate Tank Removal, Inc. that no further action be taken and the site be closed with no further action.

ATTACHMENTS

VICINITY MAP, SITE PLAN, PHOTOGRAPHS
ANALYTICAL REPORTS, CHAIN OF CUSTODY FORMS
TANK DISTRUCTION CERTIFICATE
ECI TRANSPORTATION SERVICE ORDER
FORWARD WEIGHT TICKETS
MANIFESTS
PERMITS
LEAK REPORT



GOLDEN GATE TANK REMOVAL, INC.
 255 Shipley Street
 San Francisco, California 94107-1010
 Telephone (415) 512 1555 Fax (415) 512 0964

VICINITY MAP
 600 Central Avenue
 Alameda, CA 94501

Project 8375	By: tlw	Not to scale	June 2003	Figure 1
--------------	---------	--------------	-----------	----------



**Central Avenue
Right of Way**

McKay Avenue

Sidewalk

**Commercial Property
600 Central Avenue**

Driveway

Property Line

Approximate Location of Former
1,500-Gallon Underground Heating
Oil Storage Tank

Fill Port

Overburden Soil Stockpile
showing
4-Point Composite Sample
8375-SP

Parking Lot

GOLDEN GATE TANK REMOVAL, INC

255 Shipley Street
San Francisco, California 94107
Telephone (415) 512 1555 Fax (415) 512 0964

SITE PLAN

Commercial Property
600 Central Avenue
Alameda, California

Project Number 8375

June 2003

By: kmh

Not to scale

Figure 2



Tank in Excavation; Ready for Removal



Tank Loaded on Truck; Ready for Disposal

GOLDEN GATE TANK REMOVAL, INC.

255 Shipley Street
San Francisco, California 94107
Telephone (415) 512 1555 Fax (415) 512 0964

PHOTOGRAPHS

600 Central Avenue
Alameda, California

Project 8375

By: kmh

Not to scale

June, 2003

Figure 3



North State Labs

90 South Spruce Avenue, Suite V • South San Francisco, CA 94080 • (650) 266-4563 • FAX (650) 266-4560

CA FLAP# 1753

C E R T I F I C A T E O F A N A L Y S I S

Lab Number: 03-0980
Client: Golden Gate Tank
Project: 8375/600 CENTRAL AVE. ALAMEDA

Date Reported: 07/18/2003

Diesel Range Hydrocarbons by Method 8015M
MTBE, Toluene, Benzene, Ethylbenzene and Xylenes by 8020

Analyte	Method	Result	Unit	Date Sampled	Date Analyzed
Sample: 03-0980-01	Client ID: 8375-SP			07/14/2003	SO
Benzene	SW8020F	ND<5	UG/KG		07/16/2003
Ethylbenzene	SW8020F	ND<5	UG/KG		07/16/2003
Methyl-tert-butyl ether	SW8020F	ND<5	UG/KG		07/16/2003
Toluene	SW8020F	ND<5	UG/KG		07/16/2003
Xylenes	SW8020F	ND<10	UG/KG		07/16/2003
Diesel Fuel #2	CATFH	ND<1	MG/KG		07/17/2003



North State Labs

CA ELAP# 1753

90 South Spruce Avenue, Suite V • South San Francisco, CA 94080 • (650) 266-4563 • FAX (650) 266-4560

C E R T I F I C A T E O F A N A L Y S I S

Quality Control/Quality Assurance

Lab Number: 03-0980
 Client: Golden Gate Tank
 Project: 8375/600 CENTRAL AVE. ALAMEDA


Date Reported: 07/18/2003

Diesel Range Hydrocarbons by Method 8015M
 MTBE, Toluene, Benzene, Ethylbenzene and Xylenes by 8020

Analyte	Method	Reporting Unit	Blank	Avg MS/MSD	RPD
		Limit		Recovery	
Benzene	SW8020F	5 UG/KG	ND	98/95	3
Toluene	SW8020F	5 UG/KG	ND	95/93	2
Ethylbenzene	SW8020F	5 UG/KG	ND	101/99	2
Xylenes	SW8020F	10 UG/KG	ND	103/102	1
Methyl-tert-butyl ether	SW8020F	5 UG/KG	ND	105/100	5
Diesel Fuel #2	CATFH	1 MG/KG	ND	76/88	15

ELAP Certificate NO:1753

Reviewed and Approved



 John A. Murphy, Laboratory Director

Page 2 of 2



North State Labs

90 South Spruce Avenue, Suite V • South San Francisco, CA 94080 • (650) 266-4563 • FAX (650) 266-4560

CA ELAP#1753

C E R T I F I C A T E O F A N A L Y S I S

Lab Number: 03-0989
Client: Golden Gate Tank
Project: 8375/600 CENTRAL AVE. ALAMEDA

Date Reported: 07/22/2003

Gasoline Range Hydrocarbons by Method 8015M
Diesel Range Hydrocarbons by Method 8015M

Analyte	Method	Result	Unit	Date Sampled	Date Analyzed
Sample: 03-0989-01	Client ID: 8375-W2			07/15/2003	W
Diesel Fuel #2	CATFH	ND<0.05	MG/L		07/22/2003
Gasoline Range Organics	SW8020F	*296	UG/L		07/17/2003

*Does not match gasoline pattern.



North State Labs

90 South Spruce Avenue, Suite V • South San Francisco, CA 94080 • (650) 266-4563 • FAX (650) 266-4560

CA ELAP# 1753

C E R T I F I C A T E O F A N A L Y S I S

Quality Control/Quality Assurance

Lab Number: 03-0989
 Client: Golden Gate Tank
 Project: 8375/600 CENTRAL AVE. ALAMEDA


Date Reported: 07/22/2003

Gasoline Range Hydrocarbons by Method 8015M
 Diesel Range Hydrocarbons by Method 8015M

Analyte	Method	Reporting Unit Limit	Blank	Avg MS/MSD Recovery	RPD
Gasoline Range Organics	SW8020F	50 UG/L	ND	114/84	30
Benzene	SW8020F	0.5 UG/L	ND	93/89	4
Toluene	SW8020F	0.5 UG/L	ND	98/93	5
Ethylbenzene	SW8020F	0.5 UG/L	ND	86/88	2
Xylenes	SW8020F	1.0 UG/L	ND	106/102	4
Methyl-tert-butyl ether	SW8020F	0.5 UG/L	ND	86/84	2
Diesel Fuel #2	CATFH	0.05 MG/L	ND	69/74	7

ELAP Certificate NO:1753

Reviewed and Approved


 John A. Murphy, Laboratory Director

Page 2 of 2



North State Labs

90 South Spruce Avenue, Suite V • South San Francisco, CA 94080 • (650) 266-4563 • FAX (650) 266-4560

CA ELAP# 1753

C E R T I F I C A T E O F A N A L Y S I S

Job Number: 03-0989
 Client : Golden Gate Tank
 Project : 8375/600 CENTRAL AVE. ALAMEDA

Date Sampled : 07/15/2003
 Date Analyzed: 07/17/2003
 Date Reported: 07/22/2003

Volatile Organics by GC/MS Method 8260

Laboratory Number	03-0989-01
Client ID	8375-W2
Matrix	W
Analyte	UG/L
Bromochloromethane	ND<5
Dichlorodifluoromethane	ND<5
Chloromethane	ND<10
Vinyl chloride	ND<5
Bromomethane	ND<5
Chloroethane	ND<5
Trichlorofluoromethane	ND<5
1,1-Dichloroethene	ND<1
Acetone	ND<50
Methylene chloride	ND<50
trans-1,2-Dichloroethene	ND<1
Methyl-tert-butyl ether	ND<1
1,1-Dichloroethane	ND<1
2,2-Dichloropropane	ND<1
cis-1,2-Dichloroethene	ND<1
2-Butanone	ND<10
Chloroform	52
Carbon tetrachloride	ND<1
1,1-Dichloropropene	ND<1
Benzene	ND<1
1,2-Dichloroethane	ND<1
Trichloroethene	ND<2
1,2-Dichloropropane	ND<1
Dibromomethane	ND<1
Bromodichloromethane	ND<1
trans 1,3-Dichloropropene	ND<1
4-Methyl-2-pentanone	ND<10
Toluene	ND<1
cis-1,3 Dichloropropene	ND<1
1,1,2-Trichloroethane	ND<1
Tetrachloroethene	ND<1
1,3-Dichloropropane	ND<1
2-Hexanone	ND<10
Dibromochloromethane	ND<1
1,2 Dibromoethane	ND<1



North State Labs

90 South Spruce Avenue, Suite V • South San Francisco, CA 94080 • (650) 266-4563 • FAX (650) 266-4560

CA ELAP# 1753

C E R T I F I C A T E O F A N A L Y S I S

Job Number: 03-0989
 Client : Golden Gate Tank
 Project : 8375/600 CENTRAL AVE. ALAMEDA

Date Sampled : 07/15/2003
 Date Analyzed: 07/17/2003
 Date Reported: 07/22/2003

Volatile Organics by GC/MS Method 8260

Laboratory Number	03-0989-01
Client ID	8375-W2
Matrix	W
Analyte	UG/L
Chlorobenzene	ND<2
1,1,1,2-Tetrachloroethane	ND<1
Ethylbenzene	ND<1
Xylene, Isomers m & p	ND<2
o-Xylene	ND<1
Styrene	ND<1
Bromoform	ND<1
Isopropylbenzene	ND<1
Bromobenzene	ND<1
1,1,2,2-Tetrachloroethane	ND<1
n-Propylbenzene	ND<1
2-Chlorotoluene	ND<1
4-Chlorotoluene	ND<1
1,3,5-Trimethylbenzene	1
tert-Butylbenzene	ND<1
1,2,4-Trimethylbenzene	3
1,3-Dichlorobenzene	ND<1
1,4-Dichlorobenzene	ND<1
sec-Butylbenzene	ND<1
1,2-Dichlorobenzene	ND<1
n-Butylbenzene	ND<1
Naphthalene	9
1,2,4-Trichlorobenzene	ND<1
Hexachlorobutadiene	ND<1
1,2,3-Trichlorobenzene	ND<1
1,2,3-Trichloropropane	ND<1
Acetonitrile	ND<50
Acrylonitrile	ND<50
Isobutanol	ND<50
1,1,1-Trichloroethane	ND<0.5
SUR-Dibromofluoromethane	94
SUR-Toluene-d8	96
SUR-4-Bromofluorobenzene	101



North State Labs

90 South Spruce Avenue, Suite V • South San Francisco, CA 94080 • (650) 266-4563 • FAX (650) 266-4560

CA ELAP#1753

C E R T I F I C A T E O F A N A L Y S I S

Job Number: 03-0989

Date Sampled : 07/15/2003

Client : Golden Gate Tank

Date Analyzed: 07/17/2003

Project : 8375/600 CENTRAL AVE. ALAMEDA

Date Reported: 07/22/2003

Volatile Organics by GC/MS Method 8260
Quality Control/Quality Assurance Summary

Laboratory Number	03-0989	MS/MSD	RPD	Recovery	RPD
Client ID	Blank	Recovery		Limit	Limit
Matrix	W	W			
Analyte	Results	%Recoveries			
	UG/L				
Bromochloromethane	ND<5				
Dichlorodifluoromethane	ND<5				
Chloromethane	ND<10				
Vinyl chloride	ND<1				
Bromomethane	ND<5				
Chloroethane	ND<5				
Trichlorofluoromethane	ND<5				
1,1-Dichloroethene	ND<1	95/95	0	61-121	25
Acetone	ND<50				
Methylene chloride	ND<50				
trans-1,2-Dichloroethene	ND<1				
Methyl-tert-butyl ether	ND<1				
1,1-Dichloroethane	ND<1				
2,2-Dichloropropane	ND<1				
cis-1,2-Dichloroethene	ND<1				
2-Butanone	ND<10				
Chloroform	ND<1				
Carbon tetrachloride	ND<1				
1,1-Dichloropropene	ND<1				
Benzene	ND<1	100/105	5	74-135	21
1,2-Dichloroethane	ND<1				
Trichloroethene	ND<2	100/105	5	69-129	20
1,2-Dichloropropane	ND<1				
Dibromomethane	ND<1				
Bromodichloromethane	ND<1				
trans-1,3-Dichloropropene	ND<1				
4-Methyl-2 pentanone	ND<10				
Toluene	ND<1	105/110	5	61-141	19
cis-1,3-Dichloropropene	ND<1				
1,1,2-Trichloroethane	ND<1				
Tetrachloroethene	ND<1				
1,3-Dichloropropane	ND<1				
2-Hexanone	ND<10				
Dibromochloromethane	ND<1				
1,2-Dibromoethane	ND<1				
Chlorobenzene	ND<2	115/120	4	70-139	19
1,1,1,2-Tetrachloroethane	ND<1				
Ethylbenzene	ND<1				
Xylene, Isomers m & p	ND<2				
o-Xylene	ND<1				
Styrene	ND<1				



North State Labs

90 South Spruce Avenue, Suite V • South San Francisco, CA 94080 • (650) 266-4563 • FAX (650) 266-4560

CA ELAP# 1753

C E R T I F I C A T E O F A N A L Y S I S

Job Number: 03-0989

Date Sampled : 07/15/2003

Client : Golden Gate Tank

Date Analyzed: 07/17/2003

Project : 8375/600 CENTRAL AVE. ALAMEDA

Date Reported: 07/22/2003

Volatile Organics by GC/MS Method 8260
Quality Control/Quality Assurance Summary

Laboratory Number	03-0989	MS/MSD	RPD	Recovery	RPD
Client ID	Blank	Recovery		Limit	Limit
Matrix	W	W			
Analyte	Results UG/L	%Recoveries			
Bromoform	ND<1				
Isopropylbenzene	ND<1				
Bromobenzene	ND<1				
1,1,2,2-Tetrachloroethane	ND<1				
n-Propylbenzene	ND<1				
2-Chlorotoluene	ND<1				
4-Chlorotoluene	ND<1				
1,3,5-Trimethylbenzene	ND<1				
tert-Butylbenzene	ND<1				
1,2,4-Trimethylbenzene	ND<1				
1,3-Dichlorobenzene	ND<1				
1,4-Dichlorobenzene	ND<1				
sec-Butylbenzene	ND<1				
1,2-Dichlorobenzene	ND<1				
n-Butylbenzene	ND<1				
Naphthalene	ND<2				
1,2,4-Trichlorobenzene	ND<1				
Hexachlorobutadiene	ND<1				
1,2,3-Trichlorobenzene	ND<1				
1,2,3-Trichloropropane	ND<1				
Acetonitrile	ND<50				
Acrylonitrile	ND<50				
Isobutanol	ND<50				
1,1,1-Trichloroethane	ND<0.5				
SUR-Dibromofluoromethane	95	101/106	5	67-129	21
SUR-Toluene-d8	96	97/97	0	72-119	16
SUR-4-Bromofluorobenzene	99	102/103	1	78-121	19

Reviewed and Approved

John A. Murphy
Laboratory Director



North State Labs

90 South Spruce Avenue, Suite V • South San Francisco, CA 94080 • (650) 266-4563 • FAX (650) 266-4560

CA ELAP# 1753

C E R T I F I C A T E O F A N A L Y S I S

Lab Number: 03-1065
 Client: Golden Gate Tank
 Project: 8375/600 CENTRAL AVE. ALAMEDA

Date Reported: 08/04/2003

Gasoline, BTEX and MTBE by Methods SW8020F
 Diesel Range Hydrocarbons by Method 8015M

Analyte	Method	Result	Unit	Date Sampled	Date Analyzed
Sample: 03-1065-01	Client ID: 8375-W3			07/31/2003	W
Benzene	SW8020F	ND<0.5	UG/L		08/01/2003
Ethylbenzene	SW8020F	ND<0.5	UG/L		08/01/2003
Gasoline Range Organics	SW8020F	83	UG/L		08/01/2003
Methyl-tert-butyl ether	SW8020F	ND<0.5	UG/L		08/01/2003
Toluene	SW8020F	0.7	UG/L		08/01/2003
Xylenes	SW8020F	1.2	UG/L		08/01/2003
Diesel Fuel #2	CATFH	2.89	MG/L		08/01/2003



North State Labs

90 South Spruce Avenue, Suite V • South San Francisco, CA 94080 • (650) 266-4563 • FAX (650) 266-4560 CA ELAP# 1753

C E R T I F I C A T E O F A N A L Y S I S

Quality Control/Quality Assurance

Lab Number: 03-1065
 Client: Golden Gate Tank
 Project: 8375/600 CENTRAL AVE. ALAMEDA


Date Reported: 08/04/2003

Gasoline, BTEX and MTBE by Methods SW8020F
 Diesel Range Hydrocarbons by Method 8015M

Analyte	Method	Reporting Unit Limit	Blank	Avg MS/MSD Recovery	RPD
Gasoline Range Organics	SW8020F	50 UG/L	ND	108/109	1
Benzene	SW8020F	0.5 UG/L	ND	113/110	3
Toluene	SW8020F	0.5 UG/L	ND	115/115	0
Ethylbenzene	SW8020F	0.5 UG/L	ND	94/95	1
Xylenes	SW8020F	1.0 UG/L	ND	120/120	0
Methyl-tert-butyl ether	SW8020F	0.5 UG/L	ND	103/105	2
Diesel Fuel #2	CATFH	0.05 MG/L	ND	82/78	5

ELAP Certificate NO:1753

Reviewed and Approved


 John A. Murphy, Laboratory Director



North State Labs

90 South Spruce Avenue, Suite W, South San Francisco, CA 94080
 Phone: (650) 266-4563 Fax: (650) 266-4560

03-1065

Chain of Custody / Request for Analysis
 Lab Job No.: _____ Page 1 of 1

Client: <u>G-TR</u>	Report to: <u>Sawador</u>	Phone: <u>415 512 1555</u>	Turnaround Time <u>24 hrs.</u>
Mailing Address: <u>255 Shibley St SF CA 94107</u>	Billing to: <u>G-TR</u>	Fax: <u>415 512 0964</u>	
		email: <u>Data@Gtr.com</u>	Date: <u>7-31-03</u>
		PO# <u>8375</u>	Sampler: <u>Tim H</u>

Project / Site Address / Global ID: <u>8375 / 600 Central Ave (Alameda)</u>					Analysis Requested				EDF <input type="checkbox"/>	Field Point ID
Sample ID	Sample Type	Container No. / Type	Pres.	Sampling Date / Time	TPH-G	TPH-D	MTBE	BTEX		
<u>8375-W3</u>	<u>WATER</u>	<u>1 LITRE 2 VOA</u>	<u>COOL</u>	<u>7/31/03 / 10:50 AM</u>	<u>X</u>	<u>X</u>	<u>X</u>	<u>X</u>		

Relinquished by: <u>Tim Hallen</u>	Date: <u>7/31/03</u>	Time: <u>3 PM</u>	Received by: <u>[Signature]</u>	Lab Comments/ Hazards
Relinquished by:	Date:	Time:	Received by:	
Relinquished by:	Date:	Time:	Received by:	

22535740
 IN CASE OF EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8802; WITHIN CALIFORNIA, CALL 1-800-852-7550
 GENERATOR
 FACILITY

UNIFORM HAZARDOUS WASTE MANIFEST		1. Generator's US EPA ID No. CA101002566601	Manifest Document No. 35740	2. Page 1 of 1	Information in the shaded areas is not required by Federal law.	
3. Generator's Name and Mailing Address GEORGE HANDEMAN 3086 SAKSON ST. SAN FRANCISCO, CA 94118			A. State Manifest Document Number 22535740			
4. Generator's Phone (415) 667-6143			B. State Generator's ID			
5. Transporter 1 Company Name CLEARWATER ENVIRONMENTAL		6. US EPA ID Number CA101002566601	C. State Transporter's ID [Reserved]			
7. Transporter 2 Company Name			D. Transporter's Phone (510)476-1740			
9. Designated Facility Name and Site Address AL VISO INDEPENDENT OIL 5002 ARCHER STREET AL VISO CA 95002		10. US EPA ID Number CA101002566601	E. State Transporter's ID [Reserved]			
11. US DOT Description (including Proper Shipping Name, Hazard Class, and ID Number) a. (OIL & WATER) NON RCRA HAZARDOUS WASTE LIQUID			12. Containers No. Type 003 TT	13. Total Quantity 01400	14. Unit G	
			I. Waste Number State 203 EPA/Other NONE			
			State EPA/Other			
			State EPA/Other			
			State EPA/Other			
J. Additional Descriptions for Materials Listed Above 11A			K. Handling Codes for Wastes Listed Above a. b. c. d.			
15. Special Handling Instructions and Additional Information WEAR PPE. EMERGENCY CONTACT KIRK HAYWARD 510-476-1740 ERG #171 SITE: 600 CENTRAL AVE. ALAMEDA, CA. JOB # 8375 TANK # 78664 CG TANK RENEWAL						
16. GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations. If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.						
Printed/Typed Name Kirk Hayward		Signature Kirk Hayward		Month Day Year 07 09 03		
17. Transporter 1 Acknowledgement of Receipt of Materials Printed/Typed Name Mike Stone		Signature Mike Stone		Month Day Year 07 09 03		
18. Transporter 2 Acknowledgement of Receipt of Materials Printed/Typed Name		Signature		Month Day Year		
19. Discrepancy Indication Space						
20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19. Printed/Typed Name		Signature		Month Day Year		

DO NOT WRITE BELOW THIS LINE.

IN CASE OF EMERGENCY OR SPILL, CALL THE NATIONAL RESPONSE CENTER 1-800-424-8802: WITHIN CALIFORNIA, CALL 1-800-852-7550

UNIFORM HAZARDOUS WASTE MANIFEST		1. Generator's US EPA ID No. CA191009466392		Manifest Document No. 910575		2. Page 1 1 of 1		Information in the shaded areas is not required by Federal law.			
3. Generator's Name and Mailing Address George Haideman 2286 Jackson St San Francisco, CA 94118						A. State Manifest Document Number 22490575					
4. Generator's Phone (415) 567-1643						B. State Generator's ID					
5. Transporter 1 Company Name Ecology Control Industries			6. US EPA ID Number CA191009466392			C. State Transporter's ID [Reserved]					
7. Transporter 2 Company Name						D. Transporter's Phone 510-235-1393					
8. US EPA ID Number						E. State Transporter's ID [Reserved]					
9. Designated Facility Name and Site Address Ecology Control Industries 255 PARR BLVD RICHMOND CA 94801						G. State Facility's ID					
10. US EPA ID Number CA191009466392						H. Facility's Phone 510-235-1393					
11. US DOT Description (including Proper Shipping Name, Hazard Class, and ID Number) NON RCRA HAZARDOUS WASTE SOLID (EMPTY STORAGE TANK)						12. Containers		13. Total	14. Unit	I. Waste Number	
						No.		Type	Quantity		Wt/Vol
						0101		TP	00300		P
15. Special Handling Instructions and Additional Information Wear proper protective equipment while handling. Weights or volumes are approximate. 24 hour emergency number: SITE ADDRESS: ECI J/N 24 hour emergency contact: 8575						K. Handling Codes for Wastes Listed Above					
16. GENERATOR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by proper shipping name and are classified, packed, marked, and labeled, and are in all respects in proper condition for transport by highway according to applicable international and national government regulations. If I am a large quantity generator, I certify that I have a program in place to reduce the volume and toxicity of waste generated to the degree I have determined to be economically practicable and that I have selected the practicable method of treatment, storage, or disposal currently available to me which minimizes the present and future threat to human health and the environment; OR, if I am a small quantity generator, I have made a good faith effort to minimize my waste generation and select the best waste management method that is available to me and that I can afford.											
Printed/Typed Name Subador Mora			Signature <i>[Signature]</i>			Month Day Year 07/14/03					
17. Transporter 1 Acknowledgement of Receipt of Materials											
Printed/Typed Name Gina Johnson			Signature Gina Johnson			Month Day Year 07/14/03					
18. Transporter 2 Acknowledgement of Receipt of Materials											
Printed/Typed Name			Signature			Month Day Year					
19. Discrepancy Indication Space											
20. Facility Owner or Operator Certification of receipt of hazardous materials covered by this manifest except as noted in Item 19.											
Printed/Typed Name			Signature			Month Day Year					

DO NOT WRITE BELOW THIS LINE.

SERVICE ORDER #

244401 8375

52T0822

DATE: 7-14-03

CUSTOMER

Name: GOLDEN GATE TANK Job Location: ALAMEDA

Address (BILLING): _____ City: _____ Zip: _____

Ordered by: J. WILCOX #50 Company: _____ P.O. #: _____

DRIVER

Name (PRINT): G. JOHNSON Signed: _____

Truck #: 12038 Trailer #: _____ Size/Type: F550

SERVICES

Services performed: TAD 1500 GALLON TANK TO ECI-R
FORD DISPOSAL

TIME

MANIFEST #	DISPOSAL #	Start	Stop	Gross Time
# _____	# _____	8:30 ^{AM}	_____ ^{PM}	_____ Hrs
# _____	# _____	MEALS Start _____ ^{AM}	_____ ^{PM}	Less _____ Hrs
#Loads _____	Qty _____	Other Time _____	Add/Deduct _____	Total _____ Hrs
BBL _____	Gal _____	Tons _____	Yards _____	

SITE

Time In	Time In	Time In	Stop Miles
_____	_____	_____	_____
Time Out	Time Out	Time Out	Miles Driven
_____	_____	_____	52580

DESCRIPTION

	QTY	U.O.M.	RATE	EXT		QTY	U.O.M.	RATE	EXT
Vacuum Truck					Disposal				
End Dump					Washout				
Roll-off					Roper Pump				
Flat Bed					Bin Liner				
Tank Mover					Surcharge				
Driver Relief									
Subsistence									

Authorized & Approved by: _____

Title: CTR

TOTAL CHARGES: \$ _____

If invoice is not paid within 30 days, interest shall commence accruing at 1.5% per month. Should suit be commenced to collect any portion of this invoice, Ecology Control Industries shall be entitled to any costs deemed reasonable by the court, including attorney fees.

DAY OR NIGHT
TELEPHONE
(510) 285-1898

CERTIFICATE CERTIFIED SERVICES COMPANY

255 Parr Boulevard • Richmond, California 94801

NO. 38009

CUSTOMER
JOB NO. 52T0822
GOLDEN GATE TANK &

Site: 600 Central Ave
Alameda, CA

FOR: ECOLOGY CONTROL IND. TANK NO. 90823

LOCATION: RICHMOND, CA DATE: 7/14/2003 TIME: 4:40

TEST METHOD VISUAL GASTECH/1314 SMPN LAST PRODUCT HEATING OIL

This is to certify that I have personally determined that this tank is in accordance with the American Petroleum Institute and have found the condition to be in accordance with its assigned designation. This certificate is based on conditions existing at the time the inspection herein set forth was completed and is issued subject to compliance with all qualifications and instructions.

TANK SIZE 1,500 GAL CONDITION SAFE FOR FIRE

REMARKS: OXYGEN 20.9% LOWER EXPLOSIVE LIMIT LESS THAN 0.1% ECOLOGY CONTROL INDUSTRIES
HERBY CERTIFIES THAT THE ABOVE NUMBERED TANK HAS BEEN CUT OPEN, PROCESSED,
AND THEREFORE DESTROYED AT OUR PERMITTED HAZARDOUS WASTE FACILITY.
ECOLOGY CONTROL INDUSTRIES HAS THE APROPRIATE PERMITS FOR, AND HAS ACCEPTED
THE TANK SHIPPED TO US FOR PROCESSING.

In the event of any physical or atmospheric changes affecting the gas-free conditions of the above tanks, or if in any doubt, immediately stop all hot work and contact the undersigned. This permit is valid for 24 hours if no physical or atmospheric changes occur.

STANDARD SAFETY DESIGNATION

SAFE FOR MEN: Means that in the compartment or space so designated (a) The oxygen content of the atmosphere is at least 19.6 percent by volume; and that (b) Toxic materials in the atmosphere are within permissible concentrations; and (c) in the judgment of the inspector, the residues are not capable of producing toxic materials under existing atmospheric conditions while maintained as directed on the inspector's certificate.

SAFE FOR FIRE: Means that in the compartment so designated (a) The concentration of flammable materials in the atmosphere is below 10 percent of the lower explosive limit; and that (b) In the judgment of the inspector, the residues are not capable of producing a higher concentration that permitted under existing atmospheric conditions in the presence of fire and while maintained as directed on the inspector's certificate, and further, (c) All adjacent spaces have either been cleaned sufficiently to prevent the spread of fire, are satisfactorily inerted, or in the case of fuel tanks, have been treated as deemed necessary by the inspector.

The undersigned representative acknowledges receipt of this certificate and understands the conditions and limitations under which it was issued.

James Wilcox
REPRESENTATIVE

TRANS SUPERVISOR
TITLE

[Signature]
INSPECTOR

Keller Canyon Sanitary Landfill
 901 Bailey Road
 Pittsburg, CA 94565
 Phone (925) 458-9800
 Fax (925) 458-9891

Ox Mountain Sanitary Landfill
 12310 San Mateo Road
 Half Moon Bay, CA 94019
 Phone (650) 726-1819
 Fax (650) 726-9183

Newby Island Sanitary Landfill
 1601 Dixon Landing Road
 Milpitas, CA 95035
 Phone (408) 945-2800
 Fax (408) 262-2871

Forward Landfill
 9999 S. Austin Road
 Manteca, CA 95336
 Phone (209) 982-4298
 Fax (209) 982-1009

NON-HAZARDOUS WASTE MANIFEST

GENERATOR <i>GEORGE HALDEMAN</i>		WASTE ACCEPTANCE NO. <i>3550 -</i>	
MAILING ADDRESS <i>3886 JACKSON STREET</i>		REQUIRED PERSONAL PROTECTIVE EQUIPMENT	
CITY, STATE, ZIP <i>SAN FRANCISCO CA 94118</i>		<input checked="" type="checkbox"/> GLOVES <input type="checkbox"/> GOGGLES <input type="checkbox"/> RESPIRATOR <input type="checkbox"/> HARD HAT	
PHONE <i>(415) 567-6143</i>		<input type="checkbox"/> TY-VEK <input type="checkbox"/> OTHER	
CONTACT PERSON <i>GEORGE HALDEMAN</i>		SPECIAL HANDLING PROCEDURES:	
SIGNATURE OF AUTHORIZED AGENT / TITLE <i>[Signature] OWNER</i>		DATE <i>08-04-03</i>	
GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR Part 261 or title 22 of the California code of regulations, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations. AND, if the waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions, I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR Part 268 and is no longer a hazardous waste as defined by 40 CFR Part 261.		RECEIVING FACILITY	
WASTE TYPE: <input type="checkbox"/> DISPOSAL <input type="checkbox"/> SLUDGE <input type="checkbox"/> CONSTRUCTION <input type="checkbox"/> WOOD <input type="checkbox"/> DEBRIS <input type="checkbox"/> OTHER <input type="checkbox"/> SPECIAL WASTE			
GENERATING FACILITY <i>400 CENTRAL AVE JOB # 8375</i>			
TRANSPORTER <i>F.A. POLT TRUCKING</i>		NOTES:	VEHICLE LICENSE NUMBER <i>6602726</i>
ADDRESS <i>P.O. BOX 1624</i>		TRUCK NUMBER <i>1A29064</i>	
CITY, STATE, ZIP <i>SAN BRUNO, CA 94066-1624</i>		<i>F-77</i>	
PHONE <i>630-589-7529</i>		END DUMP <input type="checkbox"/> BOTTOM DUMP <input type="checkbox"/> TRANSFER <input checked="" type="checkbox"/>	
SIGNATURE OF AUTHORIZED AGENT OR DRIVER <i>[Signature]</i>		ROLL-OFF(S) <input type="checkbox"/> FLAT-BED <input type="checkbox"/> VAN <input type="checkbox"/> DRUMS <input type="checkbox"/>	
DATE <i>8-4-03</i>			
I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.		CUBIC YARDS	
REMARKS		DISPOSAL METHOD: (TO BE COMPLETED BY LANDFILL)	
FACILITY TICKET NUMBER		DISPOSE	
SIGNATURE OF AUTHORIZED AGENT <i>[Signature]</i>		OTHER	
DATE <i>[Signature]</i>		<input type="checkbox"/> SOIL	
		<input type="checkbox"/> CONSTRUCTION DEBRIS	
		<input type="checkbox"/> NON-FRIABLE ASBESTOS	
		<input type="checkbox"/> WOOD	
		<input type="checkbox"/> ASH	
		<input type="checkbox"/> SPECIAL OTHER	

SCHEDULING MUST BE MADE PRIOR TO 3:00 P.M. THE DAY PRIOR TO EXPECTED ARRIVAL • ANY UNSCHEDULED LOADS ARE SUBJECT TO REFUSAL UPON ARRIVAL. ONGOING DAILY DELIVERIES MUST BE SCHEDULED WITH THE LANDFILL THE DAY BEFORE.



FORWARD INCORPORATED

9999 South Austin Road/WEIGHING LOCATION P.O. Box 6336
 Manteca, CA 95336 Stockton, CA 95206
 Landfill: (209) 982-4298 / WEIGHING LOCATION Main Office: (209) 466-4482
 Resource Recovery: (209) 982-4936 Fax: (209) 465-0631

003550
 GOLDEN GATE TANK REMOVAL
 CATHY KELLER
 255 SHIPLEY STREET
 SAN FRANCISCO, CA 94107
 Contract: 3550#

SITE	TICKET	GRID
01	255339	
WEIGHMASTER		
NANCY		
DATE IN		TIME IN
4 August 2003		3:09 pm
DATE OUT		TIME OUT
4 August 2003		3:51 pm
VEHICLE		ROLL OFF
MASTER F77		
REFERENCE	ORIGIN	
	ALAMEDA	

00 Gross Weight 74,000.00 LB
 Tare Weight 30,340.00 LB
 Net Weight 43,660.00 LB 21.83 TN

Inbound - SCALE TICKET

QTY.	UNIT	DESCRIPTION	RATE	EXTENSION	TAX	TOTAL
21.83	TN	CLASS III COVER SOIL				

WEIGHMASTER CERTIFICATE - THIS IS TO CERTIFY that the following described commodity was weighed, measured, or counted by a weighmaster, whose signature is on this certificate, who is a recognized authority of accuracy, as prescribed by Chapter 7 (commencing with Section 12700) of Division 5 of the California Business and Professions Code, administered by the Division of Measurement Standards of the California Department of Food and Agriculture.

MANIFEST #50851

DRIVER'S SIGNATURE _____

NET AMOUNT
TENDERED
CHANGE
CHECK NO.

Keller Canyon
Sanitary Landfill

981 Bailey Road
Pittsburg, CA 94565
Phone (925) 458-9800
Fax (925) 458-9891

Ox Mountain
Sanitary Landfill

1230 San Mateo Road
Half Moon Bay, CA 94019
Phone (650) 726-1819
Fax (650) 726-9183


Newby Island
Sanitary Landfill

1601 Dixon Landing Road
Milpitas, CA 95035
Phone (408) 945-2800
Fax (408) 262-2871

Forward
Landfill

9999 S. Austin Road
Manteca, CA 95336
Phone (209) 982-4298
Fax (209) 982-1009

NON-HAZARDOUS WASTE MANIFEST


GENERATOR
 GEORGE HALDENMAN
MAILING ADDRESS
 3286 JACKSON STREET
CITY, STATE, ZIP
 SAN FRANCISCO, CA 94118
PHONE
 (415) 567-6143
CONTACT PERSON
 GEORGE HALDENMAN
SIGNATURE OF AUTHORIZED AGENT / TITLE
 *  **DATE**
 07-21-03

WASTE ACCEPTANCE NO.
 3550 -

REQUIRED PERSONAL PROTECTIVE EQUIPMENT
 GLOVES GOGGLES RESPIRATOR HARD HAT
 TY-VEK OTHER


SPECIAL HANDLING PROCEDURES:


GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR Part 261 or title 22 of the California code of regulations, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations. AND, if the waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions, I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR Part 268 and is no longer a hazardous waste as defined by 40 CFR Part 261.

RECEIVING FACILITY


WASTE TYPE:
 DISPOSAL SLUDGE
 CONSTRUCTION WOOD
 DEBRIS OTHER
 SPECIAL WASTE

GENERATING FACILITY:
 600 CENTRAL AVE # 8375

TRANSPORTER
 F.A. POUL TRUCKING
ADDRESS
 P.O. BOX 1624
CITY, STATE, ZIP
 SAN BRUNO, CA 94066-1624
PHONE
 (650) 589-7529
SIGNATURE OF AUTHORIZED AGENT OR DRIVER
 *  **DATE**


NOTES: **VEHICLE LICENSE NUMBER:** **TRUCK NUMBER:**


END DUMP **BOTTOM DUMP** **TRANSFER**
ROLL-OFF(S) **FLAT-BED** **VAN** **DRUMS**

I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.

REMARKS

FACILITY TICKET NUMBER

SIGNATURE OF AUTHORIZED AGENT
 *  **DATE**
 07/21/03

CUBIC YARDS

DISPOSAL METHOD: (TO BE COMPLETED BY LDFILL)

	DISPOSE	OTHER
<input type="checkbox"/> SOIL		
<input type="checkbox"/> CONSTRUCTION DEBRIS		
<input type="checkbox"/> NON-FRIABLE ASBESTOS		
<input type="checkbox"/> WOOD		
<input type="checkbox"/> ASH		
<input type="checkbox"/> SPECIAL OTHER		

SCHEDULING MUST BE MADE PRIOR TO 3:00 P.M. THE DAY PRIOR TO EXPECTED ARRIVAL - ANY UNSCHEDULED LOADS ARE SUBJECT TO REFUSAL UPON ARRIVAL. ONGOING DAILY DELIVERIES MUST BE SCHEDULED WITH THE LANDFILL THE DAY BEFORE.



FORWARD INCORPORATED

9999 South Austin Road/WEIGHING LOCATION
Manteca, CA 95336
Landfill: (209) 982-4288 / WEIGHING LOCATION
Resource Recovery: (209) 982-4936

P.O. Box 6336
Stockton, CA 95206
Main Office: (209) 466-4482
Fax: (209) 465-0631

003550
GOLDEN GATE TANK REMOVAL
CATHY KELLER
255 SHIPLEY STREET
SAN FRANCISCO, CA 94107
Contract: 3550#

SITE	TICKET	GRID
01	254851	
WEIGHMASTER		
NANCY		
DATE IN		TIME IN
2 August 2003		7:31 am
DATE OUT		TIME OUT
2 August 2003		7:53 am
VEHICLE		HOLD OFF
RAA 88		
REFERENCE	ORIGIN	
	ALAMEDA	

00 Gross Weight 58,420.00 LB
Tare Weight 29,680.00 LB
Net Weight 28,740/00 LB 14.37 TN

Inbound - SCALE TICKET

QTY	UNIT	DESCRIPTION	RATE	EXTENSION	TAX	TOTAL
14.37	TN	12 CLASS II COVER SOIL				

WEIGHMASTER CERTIFICATE THIS IS TO CERTIFY That the following described commodity was weighed, measured, or counted by a weighmaster, whose signature is on this certificate, who is a recognized authority of accuracy, as prescribed by Chapter 7 (commencing with Section 12700) of Division 5 of the California Business and Professions Code, administered by the Division of Measurement Standards of the California Department of Food and Agriculture.

MANIFEST #50852

DRIVER'S SIGNATURE

NET AMOUNT
TENDERED
CHANGE
CHECK NO.

ALAMEDA COUNTY HEALTH CARE SERVICES AGENCY
 ENVIRONMENTAL HEALTH SERVICES
 1131 HARBOR BAY PARKWAY, RM 250
 ALAMEDA, CA 94502-6577
 PHONE # 510/567-6700

ACCEPTED

Underground Storage Tank Closure Permit Application
 Alameda County Division of Hazardous Materials
 1131 Harbor Bay Parkway, Suite 250
 Alameda, CA 94502-6577

These closure/removal plans have been received and found to be acceptable and essentially meet the requirements of State and Local Health Laws. Changes to your closure plans indicated by this Department are to assure compliance with State and local laws. The project proposed permits is now released for issuance of any required building permits for construction/destruction.

One copy of the accepted plans must be on the job and available to all contractors and craftsmen involved with the removal.

Any changes or alterations of these plans and specifications must be submitted to this Department and to the Fire and Building Inspections Department to determine if such changes meet the requirements of State and local laws.

Notify this Department at least 72 hours prior to the following required inspections:

- Removal of Tank(s) and Piping
- Sampling
- Final Inspection

Issuance of a) permit to operate, b) permanent site closure, is dependent on compliance with accepted plans and all applicable laws and regulations.

THERE IS A FINANCIAL PENALTY FOR NOT OBTAINING THESE INSPECTIONS

Contact Specialist:

Robert Weston
 6-19-03
 SEE TABLE #2
 FOR ANALYSES
 OF SOIL AND GROUNDWATER

JOB SITE COPY



FO3-0031

*** Complete plan according to attached instructions ***

UNDERGROUND TANK CLOSURE PLAN

1. Name of Business Residential Apartment Building
 Business Owner or Contact Person (PRINT) Mr. George Haldeman
2. Site Address 600 Central Avenue
 City Alameda Zip 94501 Phone (415) 929-1367
3. Mailing Address 3286 Jackson Street
 City San Francisco Zip 94118 Phone (415) 929-1367
4. Property Owner Mr. George Haldeman
 Business Name (if applicable) N/A
 Address 3286 Jackson Street
 City, State San Francisco, CA Zip 94118
5. Generator name under which tank will be manifested
Mr. George Haldeman

JOB SITE COPY

EPA ID# under which tank will be manifested C A C 002566501 *rw*

rev. 1/01/96
 ust cl

06-17-2003

K Rankin 7/2/03

SR0004584

CITY OF ALAMEDA

2263 SANTA CLARA AVENUE, ROOM 190
ALAMEDA, CA 94501

(510) 748-4530
FAX (510) 748-4548

Fire Permit: F03-0031

Applicant Information

GOLDEN GATE TANK
REMOVAL
225 SHIPLEY STREET
SAN FRANCISCO, CA 94107
415-512-1555

Contractor Information

GOLDEN GATE TANK REMOVAL
225 SHIPLEY STREET
SAN FRANCISCO, CA 94107
415-512-1555

Owner Information

HALDEMAN GEORGE W &
MARGARET M TRS
3286 JACKSON ST
SAN FRANCISCO, CA 94118

Project Information

Status: **APPLIED**

Type: **Fire Permit**

Category: **NA**

Sub-Type: **NA**

Parcel Number: **074-1305-025-01**

Job Address: **600 CENTRAL AVE, ALAMEDA, CA 94501**

Work Description: **FIRE-REMOVAL OF ONE 1500 GALLON HEATING OIL TANK**

Applied: **06/30/2003**

Finalized:

Issued:

Expires: **06/29/2004**

Valuation: **\$10,000.00**

INSPECTIONS

Building: (510) 748-4564 (7:30-9:30 AM) **Electrical:** (510) 748-4634 (7:30-9:30 AM)
Plumbing & Mechanical: (510) 748-4563 (7:30-9:30 AM) **Fire:** (510) 749-5885
Design Review: (510) 748-4554

<u>ITEM #</u>	<u>FEE DESCRIPTION</u>	<u>ACCOUNT CODE</u>	<u>UNITS</u>	<u>FEE AMOUNT</u>	<u>PAID</u>
250	250-PERMIT FILING FEE (per activity)	4520-37450 (1050)	1	\$38.50	\$38.50
530	530-Tanks Remove Residential (each)	98512-37260 (6200)	1	\$142.50	\$142.50
620	620-Records Management Fee (each)	99409-37900 (1464)	17	\$56.10	\$56.10
2999	Permit Tracking Fee	4520-33063 (1051)	1	\$9.05	\$9.05

Total Fees: \$246.15

<u>RECEIPT #</u>	<u>PAYMENT METHOD</u>	<u>CHECK #</u>	<u>COMMENTS/PAYEE</u>	<u>RECEIPT DATE</u>	<u>RECEIPT AMT</u>
406368	Check	14250	GOLDEN GATE TANK	06/30/2003	\$246.15
Total Payments:					\$246.15
Balance Due:					\$0.00

UNDERGROUND STORAGE TANK UNAUTHORIZED RELEASE (LEAK) / CONTAMINATION SITE REPORT

EMERGENCY <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		HAS STATE OFFICE OF EMERGENCY SERVICES REPORT BEEN FILED? <input type="checkbox"/> YES <input type="checkbox"/> NO		FOR LOCAL AGENCY USE ONLY I HEREBY CERTIFY THAT I HAVE DISTRIBUTED THIS INFORMATION ACCORDING TO THE DISTRIBUTION SHOWN ON THE INSTRUCTION SHEET ON THE BACK PAGE OF THIS FORM.	
REPORT DATE 07.24.03		CASE #		SIGNED _____ DATE _____	
REPORTED BY	NAME OF INDIVIDUAL FILING REPORT CATHY KELLER		PHONE (415) 512-1555	SIGNATURE 	
	REPRESENTING <input type="checkbox"/> LOCAL AGENCY <input checked="" type="checkbox"/> OWNER/OPERATOR <input type="checkbox"/> REGIONAL BOARD <input type="checkbox"/> OTHER		COMPANY OR AGENCY NAME GOLDEN GATE TANK REMOVAL, INC.		
	ADDRESS 255 _____ STREET SHIPLEY STREET SAN FRANCISCO STATE CA 94107				
RESPONSIBLE PARTY	NAME GEDRUE HALDEMAN <input type="checkbox"/> UNKNOWN		CONTACT PERSON SAME	PHONE (415) 567-6143	
	ADDRESS 3286 _____ STREET JACKSON STREET SAN FRANCISCO STATE CA 94118				
SITE LOCATION	FACILITY NAME (IF APPLICABLE)		OPERATOR	PHONE ()	
	ADDRESS 600 CENTRAL AVENUE _____ CITY ALAMEDA COUNTY ALAMEDA 94501				
	CROSS STREET WEBSTER STREET				
IMPLEMENTING AGENCIES	LOCAL AGENCY ALAMEDA COUNTY ENVIRONMENTAL HEALTH		AGENCY NAME	CONTACT PERSON ROBERT WESTON	PHONE (510) 567-6781
	REGIONAL BOARD				
SUBSTANCES INVOLVED	(1) NAME HEATING OIL			QUANTITY LOST (GALLONS) <input checked="" type="checkbox"/> UNKNOWN	
	(2) _____ <input type="checkbox"/> UNKNOWN				
DISCOVERY/ABATEMENT	DATE DISCOVERED 07.15.03		HOW DISCOVERED <input type="checkbox"/> INVENTORY CONTROL <input type="checkbox"/> SUBSURFACE MONITORING <input type="checkbox"/> NUISANCE CONDITIONS <input checked="" type="checkbox"/> TANK TEST <input checked="" type="checkbox"/> TANK REMOVAL <input type="checkbox"/> OTHER		
	DATE DISCHARGE BEGAN _____ <input checked="" type="checkbox"/> UNKNOWN		METHOD USED TO STOP DISCHARGE (CHECK ALL THAT APPLY) <input checked="" type="checkbox"/> REMOVE CONTENTS <input checked="" type="checkbox"/> CLOSE TANK & REMOVE <input type="checkbox"/> REPAIR PIPING <input type="checkbox"/> REPAIR TANK <input type="checkbox"/> CLOSE TANK & FILL IN PLACE <input type="checkbox"/> CHANGE PROCEDURE <input type="checkbox"/> REPLACE TANK <input type="checkbox"/> OTHER		
	HAS DISCHARGE BEEN STOPPED? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO IF YES, DATE 07.15.03				
SOURCE/ CAUSE	SOURCE OF DISCHARGE <input type="checkbox"/> TANK LEAK <input checked="" type="checkbox"/> UNKNOWN <input type="checkbox"/> PIPING LEAK <input type="checkbox"/> OTHER		CAUSE(S) <input type="checkbox"/> OVERFILL <input type="checkbox"/> RUPTURE/FAILURE <input type="checkbox"/> SPILL <input type="checkbox"/> CORROSION <input checked="" type="checkbox"/> UNKNOWN <input type="checkbox"/> OTHER		
	CASE TYPE <input checked="" type="checkbox"/> UNDETERMINED <input type="checkbox"/> SOIL ONLY <input type="checkbox"/> GROUNDWATER <input type="checkbox"/> DRINKING WATER - (CHECK ONLY IF WATER WELLS HAVE ACTUALLY BEEN AFFECTED)				
CURRENT STATUS	CHECK ONE ONLY <input type="checkbox"/> NO ACTION TAKEN <input type="checkbox"/> PRELIMINARY SITE ASSESSMENT WORKPLAN SUBMITTED <input type="checkbox"/> POLLUTION CHARACTERIZATION <input checked="" type="checkbox"/> LEAK BEING CONFIRMED <input type="checkbox"/> PRELIMINARY SITE ASSESSMENT UNDERWAY <input type="checkbox"/> POST CLEANUP MONITORING IN PROGRESS <input type="checkbox"/> REMEDIATION PLAN <input type="checkbox"/> CASE CLOSED (CLEANUP COMPLETED OR UNNECESSARY) <input type="checkbox"/> CLEANUP UNDERWAY				
	REMEDIAL ACTION CHECK APPROPRIATE ACTION(S) (SEE BACK FOR DETAILS) <input type="checkbox"/> CAP SITE (CD) <input type="checkbox"/> EXCAVATE & DISPOSE (ED) <input type="checkbox"/> REMOVE FREE PRODUCT (FP) <input type="checkbox"/> ENHANCED BIO DEGRADATION (IT) <input type="checkbox"/> CONTAINMENT BARRIER (CB) <input type="checkbox"/> EXCAVATE & TREAT (ET) <input type="checkbox"/> PUMP & TREAT GROUNDWATER (GT) <input type="checkbox"/> REPLACE SUPPLY (RS) <input type="checkbox"/> VACUUM EXTRACT (VE) <input checked="" type="checkbox"/> NO ACTION REQUIRED (NA) <input type="checkbox"/> TREATMENT AT HOOKUP (HU) <input type="checkbox"/> VENT SOIL (VS) <input type="checkbox"/> OTHER (OT)				
COMMENTS					