

# Underground Tank Removal

Location: Monarch Property  
8638 Patterson Pass Rd.  
Livermore, CA 94550

Date of Removal - Aug. 31, 1998


Contractor: Pacific State Env. Contractors  
11555 Dublin Blvd.  
Dublin, CA.  
925-803-4333


Three underground tanks (1,000 gal, 550 gal, 550 gal) were removed from the ground after freezing with dry ice. LEI for all three tanks were 10% before they were removed. Alameda County Fire was not present during removal. Pete Timmerman, Proj. Manager of Pacific State and the performer of the removal site and time, but they could not show.

The two 550 gal. tanks had holes on the top <sup>and</sup> bottom due to corrosion. The 1,000 gal tank did not have any visible holes. The three tanks were placed next to each other.

There was no odor from the excavation. There was no soil discoloration. A soil sample was taken under the soil pipe of each 550 gal tank. Two soil samples were taken underneath the 1,000 gal tank. None of the soil samples exhibited an odor.

Soil samples were taken at a depth of 6.5' feet for the 550 gal tanks, and 8.0' for the 1,000 gal tank.

Contractor Representative  
  
Timmerman

County Env. Health Representative  
  
Larry Seto  
8-31-98

8/31/98

