

**From:** Cleet Carlton [CCarlton@waterboards.ca.gov]  
**Sent:** Monday, December 04, 2006 5:46 PM  
**To:** pmcgaw@archernorris.com  
**Cc:** Chan, Barney, Env. Health; JJohnsen@arcadis-us.com; d.ogreen@sbcglobal.net  
**Subject:** RE: 6335 and 6341 Scarlett Ct., Dublin

Hi Peter,

I spoke with Barney last week. I asked if he would review the UST report and I will review the CPT report, then we should get together to see what the best option is.

Some things to consider before assuming consolidation into one case include whether the UST might warrant closing, and whether the UST case would (as a separate entity) be eligible for the UST fund. I will consult our UST folks on the latter and get back to you soon.

Cleet

Cleet Carlton, P.G.  
Engineering Geologist  
San Francisco Bay Regional Water Quality Control Board  
1515 Clay Street, Suite 1400  
Oakland, California 94612  
(510) 622-2374

>>> "McGaw, Peter W" <pmcgaw@archernorris.com> 12/1/2006 11:56 AM >>>  
Hi Barney!

Nice to talk. We'll contact Cleet on Monday to initiate transfer of the Building 1 "UST site" to the Regional Board.

Peter

Peter W. McGaw  
ARCHER NORRIS  
2033 North Main Street, Suite 800  
PO Box 8035  
Walnut Creek, CA 94596-3728  
Ph (925) 930-6600  
Fx (925) 930-6620  
pmcgaw@archernorris.com  
www.archernorris.com

WALNUT CREEK . SACRAMENTO  
LOS ANGELES . NEWPORT BEACH

---

**From:** Chan, Barney, Env. Health [mailto:barney.chan@acgov.org]  
**Sent:** Thursday, November 30, 2006 2:49 PM  
**To:** d.ogreen@sbcglobal.net  
**Subject:** 6335 and 6341 Scarlett Ct., Dublin

Ms. Green: Please contact me at the number below so the County can sort out the environmental issues at these two sites.

Thank you

Barney M. Chan  
Hazardous Materials Specialist  
Alameda County Environmental Health  
510-567-6765

The information and any attachments contained in this email message may be privileged, confidential, and protected from disclosure. If you are not the intended recipient, any dissemination or copying is strictly prohibited. If you think that you may have received this email message in error, please notify the sender at the email address above. If you have received this email in error, you are instructed to delete all copies and discard any printouts without reading the information contained within.

# RAC

REC'D  
HAZMAT  
SI DEC 20 AM 7:37

Service since 1966

---

## ROBERT A. COOK & STAFF, INC.

12/13/94

In Reply Refer to: **San Jose**

**CO. OF ALAMEDA/ENVIRONMENTAL HEALTH  
DEPT.ATTN: ROBERT WESTON  
1311 HARBOR BAY, ROOM 250  
ALAMEDA, CA 94501**

Our File #: **SJS439552**

Case Name: **BUSICK GEARING PROPERTIES VS. PRECISION METAL FABRICATORS, ET AL.**

RE: Subpoena for the records of  
**BUSICK GEARING PROPERTIES VS. PRECISION METAL FABRICATORS,  
ET AL.**

Thank you for furnishing the above mentioned records. However, a signed affidavit did not accompany the records. Enclosed is the affidavit which was attached to the subpoena served on your office. Please sign, date and return it in the self-addressed envelope enclosed for your convenience.

Thank you for your cooperation.

Very truly yours,

**Client Services**  
Robert A. Cook & Staff, Inc.

Encls.

**CC: CARROLL, BURDICK & MCDONOUGH  
ATTORNEYS AT LAW  
1676 N. CALIFORNIA BLVD., #620  
WALNUT CREEK, CA 94596  
ELONA BAUM**

**Corporate Office:**

2025 Gateway Place, Ste. 330  
San Jose, CA 95110  
(408) 441-7000  
FAX (408) 441-7070

**Branch Offices:**

3750 Auburn Blvd., Ste. B  
Sacramento, CA 95821  
(916) 483-7030  
FAX (916) 483-7037

3438 Mendocino Ave., Ste. A  
Santa Rosa, CA 95403  
(707) 528-2300  
FAX (707) 528-6047

2507 West Shaw Ave., Ste. 101  
Fresno, CA 93711  
(209) 224-0909  
FAX (209) 224-1122

5730 Uplander Way, Ste. 203  
Culver City, CA 90230  
(310) 645-5557  
FAX (310) 645-1466

PATRICIA MADRID / RLET13P

**INSTRUCTIONS - PLEASE READ**

FILE NO. SJS439552

DEPOSITION DATE: 12/12/94

- \*1\* THIS SUBPOENA COMMANDS YOU TO PRODUCE ALL OF YOUR RECORDS DESCRIBED WITHIN IT, AT THE TIME AND DATE AS SHOWN ON THE SUBPOENA UNLESS THERE IS A COURT ORDER, WAIVER, OR STIPULATION WHICH WOULD RELEASE THE RECORDS IMMEDIATELY, INCLUDING X-RAYS, FILMS, AND BILLING RECORDS IF DIRECTED.
- \*2\* THIS SUBPOENA PROHIBITS YOU FROM WITHHOLDING OR OTHERWISE FAILING TO PRODUCE ANY RECORD OR DOCUMENT DESCRIBED IN THE SUBPOENA WITHOUT THE EXPRESS APPROVAL OF THE PARTY ISSUING THE SUBPOENA.
- \*3\* TO FULLY COMPLY WITH THIS SUBPOENA ALL REQUESTED MATERIAL(S) ARE DUE ON THE DATE OF DEPOSITION. THIS INCLUDES BILLING RECORDS AND X-RAYS WHEN REQUESTED.
- \*4\* THE AFFIDAVIT MUST BE SIGNED & DATED AND MUST ACCOMPANY YOUR RECORDS. PLEASE MARK APPROPRIATE BOXES.
- \*5\* IF NO RECORDS ARE FOUND, YOU MUST COMPLETE THE AFFIDAVIT AND RETURN IT TO ROBERT A COOK & STAFF, INC. THE AFFIDAVIT MUST BE SIGNED & DATED AND THE "CERTIFICATION OF NO RECORDS" BOX MUST BE MARKED.
- \*6\* IF CERTAIN PORTIONS OF YOUR RECORDS ARE UNAVAILABLE AT TIME OF DEPOSITION, (i.e. billing records) MAKE A NOTATION ON THE AFFIDAVIT THAT ADDITIONAL RECORDS WILL BE FORWARDED UNDER SEPARATE COVER. PLEASE ATTACH THIS SHEET TO YOUR ADDITIONAL RECORDS. THIS WILL AID US WITH IDENTIFICATION.

***IF YOU HAVE ANY QUESTIONS REGARDING THE COMPLIANCE OF THIS SUBPOENA OR IF YOU WOULD LIKE OUR OFFICE TO COPY YOUR RECORDS AT YOUR PLACE OF BUSINESS, PLEASE CONTACT:***

POST DATE: 11/21/94

REC.TYPE: FILL-IN DEC

CLIENT SERVICES DEPARTMENT  
ROBERT A. COOK & STAFF, INC.  
2025 GATEWAY PLACE SUITE 330  
SAN JOSE, CA. 95110  
(408) 441-7000

*To Juran 11/28/94 by S.*

# AFFIDAVIT

Check # 084117

READ - SIGN - DATE - ATTACH TO YOUR RECORDS - SUBMIT TO: **ROBERT A. COOK & STAFF, INC.**  
**2025 GATEWAY PLACE SUITE 330**  
**SAN JOSE, CA. 95110**  
**(408) 441-7000 (800) 800-6800**

Court: **THE SUPERIOR COURT OF THE STATE OF CALIFORNIA**  
**COUNTY OF ALAMEDA**  
**1225 FALLON, RM. 105**  
**OAKLAND, CA 94612**

Case #: **706508-2**

Date of Incident:

Title of Case:

**BUSICK GEARING PROPERTIES VS. PRECISION METAL FABRICATORS, ET AL.**

Attorney for Plaintiff:

**CARROLL, BURDICK & MCDONOUGH**

Attorney for Defendant:

**GOODWIN, TRUEBLOOD, BLOCK, ET AL.**

Other Attorneys of record: **COOLEY, GODWARD, CASTRO, HUDDLESON & TATUM;**

Records subpoenaed by:

**CARROLL, BURDICK & MCDONOUGH**

DATE OF DEPOSITION:

**MONDAY DECEMBER 12, 1994**

RECORDS PERTAINING TO:

**BUSICK GEARING PROPERTIES VS. PRECISION METAL FABRICATORS,  
ET AL.**

**AFFIDAVIT (Pursuant to Cal Evidence Code 1561)**

I, THE UNDERSIGNED, BEING THE DULY AUTHORIZED CUSTODIAN OF THE RECORDS AND HAVING THE AUTHORITY TO CERTIFY THE RECORDS DECLARE THE FOLLOWING; THE RECORDS WERE PREPARED BY THE PERSONNEL OF THE BUSINESS IN THE ORDINARY COURSE OF BUSINESS AT OR NEAR THE TIME OF THE ACT, CONDITION OR EVENT, AND IT IS THE REGULAR PRACTICE OF THE BUSINESS TO COMPILE SUCH RECORDS.

TRUE COPIES

The attached copy is a true, legible and durable copy of the records described in the Subpoena.

CERTIFICATION OF NO RECORDS

That a thorough search of our files revealed no documents, records or other materials called for in the Subpoena and that no such records exist with the information provided. Please attach an explanation if the requested records existed at some time but have since been purged.

ORIGINAL RECORDS

Pursuant to Evidence Code Section 1560(e) the original records described in the Subpoena were delivered to the attorney or the attorney's representative for copying at the witness' place of business.

I DECLARE UNDER PENALTY OF PERJURY UNDER THE LAWS OF THE STATE OF CALIFORNIA THAT THE FOREGOING IS TRUE AND CORRECT.

SIGNATURE \_\_\_\_\_

\_\_\_\_\_  
(PRINTED NAME)

Executed on \_\_\_\_\_ at \_\_\_\_\_, California

**IN**  
**REPLY** **CO. OF ALAMEDA/ENVIRONMENTAL HEALTH**  
**PLEASE** **DEPT.ATTN: ROBERT WESTON**  
**REFER** **(13) HARBOR BAY, ROOM 250**  
**TO** **ALAMEDA, CA 94501**



**AFFIDAVIT OF PROFESSIONAL PHOTOCOPIER**  
SECTION 22462 of Business and Professions Code.

I solemnly affirm that I am the attorney's representative and that I made true copies of all the original records delivered to me by the Custodian of Records of the within named location, and these records will be distributed to the authorized persons or entities.

Executed on \_\_\_\_\_

At \_\_\_\_\_

Signature \_\_\_\_\_

RAC Services  
San Jose, CA 95110

2025 Gateway Place, Suite 330  
Santa Clara County Registration #5

# AFFIDAVIT

ATTORNEY OR PARTY WITHOUT ATTORNEY (Name and Address): <b>CARROLL, BURDICK &amp; MCDONOUGH</b> <b>ATTORNEYS AT LAW</b> <b>1676 N. CALIFORNIA BLVD., #620</b> <b>WALNUT CREEK, CA 94596</b>	TELEPHONE NO.: <b>510-945-8579</b>	FOR COURT USE ONLY           CASE NUMBER: <b>706508-2</b>
ATTORNEY FOR (Name): <b>PLAINTIFF</b>		
NAME OF COURT: <b>THE SUPERIOR COURT OF THE STATE OF CALIFORNIA</b> STREET ADDRESS: <b>COUNTY OF ALAMEDA</b> MAILING ADDRESS: <b>1225 FALLON, RM. 105</b> CITY AND ZIP CODE: <b>OAKLAND, CA 94612</b> BRANCH NAME:		
PLAINTIFF/PETITIONER: <b>BUSICK GEARING PROPERTIES</b>  DEFENDANT/RESPONDENT: <b>PRECISION METAL FABRICATORS, DUBLIN MULTILAYER, INC., ET AL.</b>		

THE PEOPLE OF THE STATE OF CALIFORNIA, TO (name): **CUSTODIAN OF RECORDS FOR: CO. OF ALAMEDA/ENVIRONMENTAL HEALTH DEPT. ATTN: ROBERT WESTON**

1. YOU ARE ORDERED TO PRODUCE THE BUSINESS RECORDS described in item 3 as follows:


Deposition Officer (name): <b>ROBERT A. COOK &amp; STAFF</b>		
Date:	<b>12/12/94</b>	Time: <b>09:30 AM</b>
Address:	<b>2025 GATEWAY PLACE SUITE 330, SAN JOSE, CA. 95110</b>	

Do not release the requested records to the deposition officer prior to the date and time stated above.

- a.  by delivering a true, legible, and durable copy of the business records described in item 3, enclosed in a sealed inner wrapper with the title and number of the action, name of witness, and date of subpoena clearly written on it. The inner wrapper shall then be enclosed in an outer envelope or wrapper, sealed, and mailed to the deposition officer at the address in item 1.
  - b.  by delivering a true, legible, and durable copy of the business records described in item 3 to the deposition officer at the witness's address, on receipt of payment in cash or by check of the reasonable costs of preparing the copy, as determined under Evidence Code section 1563(b).
  - c.  by making the original business records described in item 3 available for inspection at your business address by the attorney's representative and permitting copying at your business address under reasonable conditions during normal business hours.
2. The records are to be produced by the date and time shown in item 1 (but not sooner than 20 days after the issuance of the deposition subpoena, or 15 days after service, whichever date is later). Reasonable costs of locating records, making them available or copying them, and postage, if any, are recoverable as set forth in Evidence Code section 1563(b). The records shall be accompanied by an affidavit of the custodian or other qualified witness pursuant to Evidence Code section 1561.
3. The records to be produced are described as follows:  
 See attachment 3 for details.

Continued on attachment 3.

**DISOBEDIENCE OF THIS SUBPOENA MAY BE PUNISHED AS CONTEMPT BY THIS COURT. YOU WILL ALSO BE LIABLE FOR THE SUM OF FIVE HUNDRED DOLLARS AND ALL DAMAGES RESULTING FROM YOUR FAILURE TO OBEY.**



Date issued: 11/21/94

*Robbie McIntosh*

(SIGNATURE OF PERSON ISSUING SUBPOENA)

(TYPE OR PRINT NAME)

(TITLE)

(See reverse for proof of service)

**RE: BUSICK GEARING PROPERTIES VS. PRECISION METAL FABRICATORS, ET AL.**

**ANY AND ALL DOCUMENTS PERTAINING TO ENVIRONMENTAL MATTERS  
AND USAGE OF HAZARDOUS MATERIALS AT THE SITE COMMONLY KNOWN AS  
6341 SCARLETT COURT DUBLIN, CALIFORNIA 94568 OPERATED BY,  
DUBLIN MULTILAYER, INC., PRECISION METAL FABRICATORS, INC.,  
AND/OR NUCLEAR SPECIALTIES, INC., INCLUDING WITHOUT LIMITATION  
ALL INFORMATION AND FILES KNOWN AS TANK FILES, STORM WATER  
FILES AND GENERATOR FILES.**

## (PROOF OF SERVICE BY MAIL - C.C.P. 1013A)

I am employed in the county of SANTA CLARA, my business address is 2025 GATEWAY PLACE #330, SAN JOSE, CA 95110, I am over the age of eighteen (18), and am not a party to the within action(s). I am readily familiar with the business practice for collection and processing of correspondence for mailing with the United States Postal Service, and that the correspondence described below will be deposited with the United States Postal Service today in the ordinary course of business. I am aware that on motion of party served, service is presumed invalid if postal cancellation date or postage meter date is more than one day after date of deposit for mailing affidavit. I served the within copy: DEPOSITION SUBPOENA - BUSINESS RECORDS

on the below listed entities in said actions by placing said documents in a sealed envelope with postage fully prepaid and addressed as follows:

**GOODWIN, TRUEBLOOD, BLOCK, ET AL.**  
**ATTORNEYS AT LAW**  
**770 "L" ST., SUITE 1000**  
**SACRAMENTO, CA 95814**  
**ATTN: THEODORE S. GOODWIN, ESQ.**


**COOLEY, GODWARD, CASTRO,**  
**HUDDLESON & TATUM**  
**ATTORNEYS AT LAW**  
**ONE MARITIME PLAZA, 20TH FLR.**  
**SAN FRANCISCO, CA 94111-3580**  
**ATTN: IRL S. BAREFIELD, ESQ.**

and that they were deposited on 11/21/94 for deposit in the United States Postal Service and that the envelope was sealed and placed for collection and mailing that date at ROBERT A. COOK & STAFF, INC. 2025 GATEWAY PLACE #330, SAN JOSE, CA 95110, following ordinary business practices.

**DATED: 11/21/94 AT SAN JOSE, CALIFORNIA**

I Declare under penalty of perjury that the foregoing is true and correct.

*This form was printed for  
all subpoenas in this series*

  
BENILDA BOWDEN



4:08  
4:55

**Alameda County Department of Environmental Health  
Hazardous Materials Division**  
80 Swan Way, Rm. 200, Oakland, CA 94621  
Ph: 510-271-4320

**BILLING FOR SERVICES**

STID# 697

A. Site Name DUBLIN MULTILAYER Phone N/A  
 Site Address 6341 SCARLETT CT, DUBLIN 94503  
(if no address, description of area) Number Street City Zip  
 Prior Business Name \_\_\_\_\_ Prior Owner's Name \_\_\_\_\_

B. Service Requestor JOSE NUNEZ, ROBERT A. COOK & STAFF (408) 441-7000  
Contact Person Company Name Phone  
 Billing Address 2025 GATEWAY PLACE, SUITE 330, SAN JOSE 95110  
Number Street City Zip

Category of Service	#Hours (Whole Hours Only)	x \$	Rate	Total
..... Site Search				
<input checked="" type="checkbox"/> File Search	<u>1</u>	x \$ <u>16</u> /Hr	\$ <u>16.00</u>	<u>15.95</u>
..... Other				
	#Copies _____	x \$ _____ /Copy	\$ <u>0</u>	
	Other _____	x \$ _____	\$ <u>0</u>	
TOTAL CHARGE:			\$ <u>16.00</u>	<u>PAID</u>

REMARKS: SEND BILLING TO RAC & STAFF AS INDICATED ABOVE.

You will receive an invoice in accordance with Article 11 of Chapter 6, Title 3 of the Ordinance Code of Alameda County

Service Requestor Jose H. Nunez Jr [Signature] Date 12/9/94 For RAC  
printed name signature  
 HazMat Specialist DONNA ERICKSON [Signature] Date 12/9/94  
printed name signature

2:45-3:45

Alameda County Department of Environmental Health  
Hazardous Materials Division  
80 Swan Way, Rm. 200, Oakland, CA 94621  
Ph: 510-271-4320

**BILLING FOR SERVICES**

STID# \_\_\_\_\_

A. Site Name DUBLIN MULTILAYER Phone N/A  
Site Address (if no address, description of area) 6341 SCARLETT DUBLIN 94503  
Number Street City Zip  
Prior Business Name \_\_\_\_\_ Prior Owner's Name \_\_\_\_\_

B. Service Requestor MICHAEL DONOVAN / MEREDITH (BOLI Assoc. 408) 451-3979  
Contact Person Company Name Phone  
Billing Address 2055 GATEWAY PLACE, STE 400, SAN JOSE 95110  
Number Street City Zip

Category of Service	#Hours (Whole Hours Only)	Rate	Total
..... Site Search	<u>1</u>	<u>\$ 16<sup>00</sup>/Hr</u>	<u>\$ 16<sup>00</sup></u>
<u>X</u> File Search	<u>12</u>	<u>\$ 112/Copy</u>	<u>\$ 1.20</u>
..... Other	_____	x \$ _____	<u>\$ 0</u>
TOTAL CHARGE:			<u>\$ 17<sup>20</sup></u>

REMARKS: HACIENDA OWNERS ASSOC, 4695 CHABOT, PLEASANTON  
EARL ADAMS TILE, 3675 OLD SANTA RITA RD., PLEASANTON

You will receive an invoice in accordance with Article 11 of Chapter 6, Title 3 of the Ordinance Code of Alameda County

Service Requestor Michael Donovan Michael Donovan Date 12/7/94  
printed name signature  
Hazard Specialist DONNA ERIKSON Donna Erikson Date 12/7/94  
printed name signature

9-15-10:00 A.M.  
12-5-94

Alameda County Department of Environmental Health  
Hazardous Materials Division

80 Swan Way, Rm. 200, Oakland, CA 94621  
Ph: 510-271-4320

**BILLING FOR SERVICES**

SHD# 697

A. Site Name DUBLIN MULTILAYER Phone N/A  
Site Address (if no address, description of area) 6341 SCARLETT CT. DUBLIN 94503  
Number Street City Zip  
Prior Business Name \_\_\_\_\_ Prior Owner's Name \_\_\_\_\_

B. Service Requestor ROBERT FINK ROBERT FINK & ASSOCIATES 904-1944  
Contact Person Company Name Phone  
Billing Address 404 WILLOW CREEK DR. FOLSOM 95630  
Number Street City Zip

Category of Service	#Hours (Whole Hours Only)	Rate	Total
..... Site Search	<u>1</u>	<u>\$ 16.00/Hr</u>	<u>\$ 16.00</u>
<input checked="" type="checkbox"/> File Search	<u>9</u>	<u>\$ .10/Copy</u>	<u>\$ .90</u>
..... Other	_____	<u>x \$ _____</u>	<u>\$ 0</u>
TOTAL CHARGE:			<u>\$ 16.90</u>

REMARKS: ALAMEDA COUNTY TO BILL ROBERT FINK ASSOCIATES.

You will receive an invoice in accordance with Article 11 of Chapter 6, Title 3 of the Ordinance Code of Alameda County

Service Requestor ROBERT FINK [Signature] Date 12/5/94  
printed name signature  
Hazardous Materials Specialist DONNA ERICKSON [Signature] Date 12/5/94  
printed name signature

**Alameda County Department of Environmental Health  
Hazardous Materials Division**

80 Swan Way, Rm. 200, Oakland, CA 94621  
Ph: 510-271-4320

**BILLING FOR SERVICES**

STID# .....

A. Site Name Dublin Multilayer Phone N/A  
 Site Address 6341 Scarlett Ct. Dublin 945  
(if no address, description of area) Number Street City Zip  
 Prior Business Name ..... Prior Owner's Name .....

B. Service Requestor Scott Osmus, SAKCO INS 510 277-8778  
Contact Person Company Name Phone  
 Billing Address 3000 Executive Pkwy #300, SAN RAMON 94583  
Number Street City Zip

<b>Category of Service</b>		#Hours	x \$	/Hr	\$
<input type="checkbox"/> Site Search		<u>1</u>	x \$	<u>16<sup>00</sup></u>	\$ <u>16<sup>00</sup></u>
<input type="checkbox"/> File Search		_____	x \$	_____/Copy	\$ _____
<input type="checkbox"/> Other		_____	x \$	_____	\$ _____
<b>TOTAL CHARGE:</b>					\$ <u>16<sup>00</sup></u>

REMARKS: PK dry ✓ # 64814 11/30/94  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

You will receive an invoice in accordance with Article 11 of Chapter 6, Title 3 of the Ordinance Code of Alameda County

Service Requestor Scott W. Osmus Scott W. Osmus Date 11/30/94  
printed name signature  
 HazMat Specialist Juliette Williams Juliette Williams Date 11/30/94  
printed name signature

REF. /  
A/C NO. *File Search*

COUNTY OF ALAMEDA  
OFFICE OF THE AUDITOR-CONTROLLER

DATE: *11/30/94*

MISCELLANEOUS RECEIPT

No 747020

\$ *16.00*  
DOLLARS


RECEIVED FROM:	<i>Scott Osmus/Safeco Ins. 3000 Executive Prkwy # 300.</i>		
FOR:	<i>Dublin Multilayer SA# Raman 94583.</i>		
<i>6341 Scarlett Ct Dublin CA 94550</i>			
RECEIVED BY:	<i>J. B. [Signature]</i>	DEPT. NO.:	<i>430/4530</i>

CASH  PERSONAL/CASHIER'S CHECK/M. O. # *64814*  OTHER: \_\_\_\_\_

110-1 (Rev 10/85) [0134E (08)] 3-Part

Distribution: White - Payor Yellow & Pink - Depart.

DO NOT CASH UNLESS BACKGROUND OF THIS CHECK PRINTED WITH RED AND GREEN BORDER ON WHITE PAPER

 SAFECO INSURANCE COMPANIES  
Home Office - SAFECO Plaza, Seattle, Washington 98185

16-77  
1220

PAY TO THE ORDER OF *Alameda County Environmental Protection* PSW 64814  
DATE *11/30/94*  
NOT VALID SIX MONTHS AFTER

The sum of *sixteen + 00/100 dollars* \$ *16.00*

AGS FIELD ACCOUNT.  
SAFECO INSURANCE COMPANY OF AMERICA

LOSS DATE	COVERAGE	AMOUNT	AE CODE	INSURED	POLICY NO.
				<i>Dublin Multilayer, Inc.</i>	<i>CP 8312526</i>
<i>19T 90260 889</i>	<i>AAE</i>	<i>16.00</i>	<i>1A</i>		<i>15-2423</i>

PAYABLE THROUGH  
UNION BANK  
LOS ANGELES, CA

AGENT \_\_\_\_\_  
ADJUSTER \_\_\_\_\_  
AGENCY LOCATION *NCB*  
OFFICE/UNIT

DO NOT CASH UNLESS BACKGROUND OF THIS CHECK PRINTED WITH RED AND GREEN BORDER ON WHITE PAPER

064814 12200077 070090118

LEGAL INVESTIGATIONS

TOXIC LITIGATION

# ROBERT FINK & ASSOCIATES

A Professional Corporation  
404 Willow Creek Drive  
Folsom, CA 95630

Tele: (916) 984-1944 Fax: (916) 984-1945

## FAX TRANSMITTAL

Date: 11/18/94

Time: 440 PM

Subject: FILE REVIEW

Recipient/Destination: JULIETTE BLAKE 510-337-9335

Number of Pages (including transmittal form): 1

Message: PER OUR TEL. CONVERSATION OF TODAY I AGREE TO  
A SUPPORT STAFF PERSON TO BE PRESENT DURING MY INITIAL  
REVIEW OF THE FILES IDENTIFIED TO YOU IN MY FAX OF 11/16/94  
@ 3:00 PM.

ROBERT FINK

**Robert A. Cook & Staff, Inc.**  
**Records Ready Fax Form**



**Faxing Instructions**

1. If you do not have the capability to copy these records you may fax this form to us and we will copy the records for you. (Refer to the attached subpoena for a description of the types of records you are to produce. Please include bills and x-ray films when indicated)
2. Complete the "Records Ready" section below and fax it to us at \* **(800) 270-7071** \*

( If you are unable to fax, please call (800) 800-6800 )

Records Pertaining To : DUBLIN MULTILAYER, 6341 SCARLETT RT, DUBLIN 94503  
 Date of Birth :  
 Social Security # :  
 Medical Records # :  
 File number : **SJS439552**

**» Records Ready «** • Please check the appropriate boxes below.

- ALL of the requested records are ready to be copied.     BILLS included     XRAYS included  
 SOME of the requested records are ready to be copied.     BILLS NOT included     XRAYS NOT included

• If you do not have the requested records you must execute, appropriately, the enclosed affidavit and mail (do not fax) to Robert A. Cook & Staff, Inc. (see blue instruction sheet for address)

• Approximately how many pages are to be copied?

- 1 - 50 pages     51 - 200 pages     200 - 500 pages     501 - 750 pages     751 + pages  
 (1/4 inch thick or less)    (1/4 to 1 inch thick)    (1 to 2 inches thick)    (2 to 3 inches thick)    (over 3 inches thick)

• What are your business hours ?

Monday 8:00 To 5:00    Tuesday 8 To 5    Wednesday 8 To 5    Thursday 8 To 5    Friday 8 To 5

Closed for lunch \_\_\_\_\_ To \_\_\_\_\_ Person to see: DONNA GRIFFINSON Phone: 510 567-6700

Signed: Robert Weston Print Name: ROBERT WESTON Date: 12-5-94

• Please confirm the address where the records are to be copied:

Records From:  
**CO. OF ALAMEDA/ENVIRONMENTAL HEALTH**  
**DEPT.ATTN: ROBERT WESTON**  
**1131 HARBOR BAY, ROOM 250**  
**ALAMEDA, CA 94501**

Address correction requested:

1131 HARBOR BAY PARKWAY RM 250  
ALAMEDA CA 94502-6577

**Alameda County Department of Environmental Health  
Hazardous Materials Division**

80 Swan Way, Rm. 200, Oakland, CA 94621  
Ph: 510-271-4320

**BILLING FOR SERVICES**


SID# 697

A. Site Name Dublin Multilayer, Inc. Phone N/A  
 Site Address 6341 Scarlett Ct, Dublin 945  
(If no address, description of area) Number Street City Zip  
 Prior Business Name Precision Metal Fabricator Prior Owner's Name \_\_\_\_\_



B. Service Requestor Scott Osmus, SAFECO (510) 277-8778  
Contact Person Company Name Phone  
 Billing Address 300 D EXECUTIVE Pkwy, Ste. 300, SAN RAMON 94583  
Number Street City Zip

<b>Category of Service</b>		#Hours	x \$	=	\$
<input checked="" type="checkbox"/> Site Search		<u>16</u>	x \$ <u>16/Hr</u>	=	\$ <u>16<sup>00</sup></u>
<input type="checkbox"/> File Search		_____	x \$ _____/Copy	=	\$ _____
<input type="checkbox"/> Other _____		_____	x \$ _____	=	\$ _____
				<b>TOTAL CHARGE:</b>	\$ <u>16<sup>00</sup></u>

REMARKS: \_\_\_\_\_

paid 11/17/94 Safe Co Ins Companies  
PSW # 64773.  


You will receive an invoice in accordance with Article 11 of Chapter 6, Title 3 of the Ordinance Code of Alameda County

Service Requestor Scott W. Osmus  Date 11-17-94  
printed name signature  
 HazMat Specialist Julietta D. Drake  Date 11-17-94  
printed name signature





SAFECO INSURANCE COMPANIES  
Home Office - SAFECO Plaza, Seattle, Washington 98185

16-77  
1220

PSW 64773  
NOT VALID SIX MONTHS AFTER

PAY TO THE ORDER OF

Alameda County Environmental Protection

DATE

The sum of

Sixteen dollars + 00/100

\$ 16.00

ACS FIELD ACCOUNT  
SAFECO INSURANCE COMPANY OF AMERICA

IN PAYMENT OF

LOSS DATE	COVERAGE	AMOUNT	AE CODE	INSURED	POLICY NO.
19T 90260 889	AAE		IA	Dublin Multilayer, Inc.	CP 8312526
PAYABLE THROUGH UNION BANK, LOS ANGELES, CA				AGENT	AGENCY LOCATION
				<i>[Signature]</i>	NCB

⑈064773⑈ ⑆122000771⑆ 07009⑈0118⑈

REF. / A/C NO. *Site Lock*

COUNTY OF ALAMEDA  
OFFICE OF THE AUDITOR-CONTROLLER

DATE: 11/17/94

MISCELLANEOUS RECEIPT

ST# 697  
Nº 740595

\$ 16.00  
DOLLARS

(510) 277-8778

RECEIVED FROM: *Scott Osmaus / 3000 EXECUTIVE PKWY, STE 300 SAN RAMON CA 94583*

FOR: *Dublin Multilayer, Inc. 12341 Scarlett Ct, Dublin Ca*

RECEIVED BY: *Juliette D. Blake* DEPT. NO.: *430-4530*

CASH  PERSONAL/CASHIER'S CHECK/M. O. # *64773*  OTHER:

LEGAL INVESTIGATIONS

TOXIC LITIGATION

**ROBERT FINK & ASSOCIATES**  
 A Professional Corporation HAZMAT  
 404 Willow Creek Drive  
 Folsom, CA 95630  
 Tele: (916) 984-1944 Fax: (916) 984-1945

96 NOV 18 PM 4: 10

FAX TRANSMITTAL

Date: 11-16-94

Time: 3:00 PM

Subject: FILE REVIEW

Recipient/Destination: JULIET BLAKE, ALAM. CO. ENV. HEALTH  
FAX - 510-337-9335

Number of Pages (including transmittal form): 1

Message: I AM INTERESTED IN TWO SITES:

STID

(1) BUSICK AIR CONDITIONING, 6335 SCARLETT COURT,  
94568  
DUBLIN, CA, ANY INFORMATION REGARDING A SEPTIC SYSTEM  
THAT MAY HAVE BEEN INSTALLED IN THE 70'S.

4321

697 (2) 6341 SCARLETT COURT, OCCUPIED BY NUCLEAR SPECIITIES  
INC. FR. 1971 -> 1979 AND DUBLIN MULTI-LAYER FR  
1980 -> 1990, ANY AND ALL INFORMATION.

PLEASE NOTIFY WHEN FILES READY FOR REVIEW:

LICENSE PI 13832

TELE: (916) 984-1944  
FAX: (916) 984-1945

ROBERT FINK  
INVESTIGATIVE TOXICOLOGIST

ROBERT FINK & ASSOCIATES  
A PROFESSIONAL CORPORATION  
404 WILLOW CREEK DRIVE  
FOLSOM, CA 95630

Dublin Multilayer  
Spill at 6341 Scarlett Court  
Dublin 94503



Dublin Multilayer  
6341 Scarlett Court



Dublin Multilayer  
6341 Scarlett Court



Dublin Multilayer  
6341 Scarlett Court

**Alameda County Department of Environmental Health  
Hazardous Materials Division**

80 Swan Way, Rm. 200, Oakland, CA 94621  
Ph: 510-271-4320

**BILLING FOR SERVICES**

STD# \_\_\_\_\_

A. Site Name DUBLIN MULTILAYER INC Phone 829-1956  
 Site Address 6341 SCARLET CT DUBLIN 94566  
(If no address, description of area) Number Street City Zip  
 Prior Business Name \_\_\_\_\_ Prior Owner's Name \_\_\_\_\_

B. Service Requestor JOAN WHITEBOOK, CARROLL, BURDICK + M'DONOUGH  
Contact Person Company Name Phone  
 Billing Address 1676 N. CALIF BLVD SUITE 620, WILMANT CREEK CA 94596  
Number Street City Zip

<u>Category of Service</u>		#Hours	x \$	/Hr	\$
<input checked="" type="checkbox"/> Site Search		<u>2</u>		<u>90</u>	<u>180</u>
<input type="checkbox"/> File Search		_____	x \$	_____/Copy	\$ _____
<input type="checkbox"/> Other _____		_____	x \$	_____	\$ _____
TOTAL CHARGE:					<u>\$ 180</u>

REMARKS: 15247 JOB#

TOTAL CHARGE PAID AT THE TIME OF SERVICE.

You will receive an invoice in accordance with Article 11 of Chapter 6, Title 3 of the Ordinance Code of Alameda County

Service Requestor Joan S. Whitebook Joan S. Whitebook Date 11-10-94  
printed name signature  
 HazMat Specialist ROBERT WESTON Robert Weston Date 11-10-94  
printed name signature

# SAFECO

SAFECO INSURANCE COMPANIES  
NORTHERN CALIFORNIA BRANCH OFFICE  
3000 EXECUTIVE PARKWAY, SUITE 300  
SAN RAMON, CA 94583-2300

TELEPHONE: (510) 277-8600  
FACSIMILE: (510) 277-8636  
MAILING ADDRESS: P.O. BOX 5152  
SAN RAMON, CA 94583-5152

11-17-94 e 10<sup>00</sup>  
Am  
B

November 7, 1994

Juliette Blake  
Alameda County Environmental Health Department  
Environmental Protection Division  
1131 Harbor Bay Parkway, Suite #250  
Alameda, CA 94502-6577

ALCO  
HAZMAT  
NOV-9 PM 2:21

RE: File review request for 6341 Scarlett Court, Dublin, CA

Dear Ms. Blake:

This letter serves to memorialize our telephone conversation today, November 7, 1994, and also as a follow-up to my correspondence to you dated October 20, 1994.

I called to inquire as to the status of my file review request for the site at the above-captioned address, per my October 20, 1994 correspondence. You conveyed to me that several parties have requested a review of this same file, but that you are having difficulty in locating the file.

You requested that I provide you with a list of the prior tenants at the Dublin site, in hope that this information may expedite your search. Based on the information in my possession, the tenant history is as follows:

Tenant:	Dublin Multilayer, Inc.
Occupancy:	12/79 to the present
Tenant:	Precision Metal Fabricators
Occupancy:	5/78 to 12/79
Tenant:	Nuclear Specialties
Occupancy:	3/71 to 5/78
Current Owner:	Busick-Gearing Properties, a California Partnership
Occupancy:	1971? to the present



SAFECO INSURANCE COMPANY OF AMERICA  
SAFECO LIFE INSURANCE COMPANY  
GENERAL INSURANCE COMPANY OF AMERICA  
FIRST NATIONAL INSURANCE COMPANY OF AMERICA  
SAFECO NATIONAL INSURANCE COMPANY  
SAFECO NATIONAL LIFE INSURANCE COMPANY  
SAFECO INSURANCE COMPANY OF ILLINOIS

Juliette Blake  
November 7, 1994  
page 2

Hopefully this information will assist you in your search.  
Please contact me at 510/277-8778 as soon as this file is  
located.

Thank you for your cooperation in this regard. I look forward  
to hearing from you soon.

Sincerely,

SAFECO INSURANCE COMPANY OF AMERICA

A handwritten signature in cursive script that reads "Scott Osmus".

Scott Osmus  
Environmental Claims

CARROLL, BURDICK & McDONOUGH

SAN FRANCISCO OFFICE:  
44 MONTGOMERY STREET  
SUITE 400  
SAN FRANCISCO, CALIFORNIA 94104  
(415) 989-5900  
FAX: (415) 989-0932

ATTORNEYS AT LAW  
1676 N. CALIFORNIA BLVD., SUITE 620  
WALNUT CREEK, CALIFORNIA 94596  
(510) 945-8579  
FAX: (510) 256-3110

SACRAMENTO OFFICE:  
WELLS FARGO CENTER  
400 CAPITOL MALL, SUITE 1400  
SACRAMENTO, CALIFORNIA 95814  
(916) 446-2222  
FAX: (916) 446-8954

November 7, 1994

VIA FAX AND SURFACE MAIL

Ms. Julliett Blake  
Alameda County  
Environmental Health Department  
Hazardous Materials Division  
1331 Harbor Bay Parkway  
Alameda, CA 94501

Dear Ms. Blake:

Pursuant to conversations with your office, we are submitting this written request to review files.

Site address: 6341 Scarlett Court  
Dublin, California 94568

Site Name: Dublin Multilayer, Inc.  
Precision Metal Fabricators, Inc.  
Nuclear Specialties, Inc.

Information Requested: All files pertaining to environmental matters and usage of hazardous materials at, around or in the area of the above site address and site names, including without limitation all information and files known as tank files, storm water files and generator files.

We understand that your office requires than an inspector be present during the review and that the charge is \$90.00 per hour which is not prorated and we agree to pay the fee. In addition, we understand that you charge \$1.00 per page for copying, but we may make arrangements to bring in a copy service.

As we discussed, please let us know the number and approximate size of the files which are available for review.

ALL INFORMATION  
IS UNCLASSIFIED  
DATE 05-07-99 BY 112


CARROLL, BURDICK & McDONOUGH

November 7, 1994  
Page 2

Your office stated that may take about 10 days until all of the files are available as some may be at the Regional Water Quality Board. We would appreciate your notifying us as soon as the files are ready for review.

Thank you for your cooperation.

Very truly yours,

  
Joan S. Whitebook



ALAMEDA COUNTY HEALTH CARE SERVICES AGENCY  
 DIVISION OF ENVIRONMENTAL HEALTH

MFR Sent \_\_\_\_\_ (date)

PURPOSE: Permit Application  Service  Update   
 TYPE OF ACTION: New  Change of Owner  Change of Name  Change of Status

Computer No.

Inactivate  Delete  Unincorp.   
 SUPV. DIST.  C.T.

Premises Name Dublin Multilayer

A. Premises Address: \_\_\_\_\_  
 Number Street City Zip Code Phone

Owner/Operator Peter E. Adler Phone 981-5252  
 If corporation, also show name of corporation president \_\_\_\_\_

B. Home Address One Maritime Plaza 20<sup>th</sup> floor San Francisco CA 94111-3580  
 Number Street City Zip Code

SEND BILLING TO ADDRESS: A, B (circle one)

Prior Business Name \_\_\_\_\_ Prior Owner's Name \_\_\_\_\_

Property Owner \_\_\_\_\_  
 If corporation, also show name of corporation president \_\_\_\_\_ Phone \_\_\_\_\_

Address \_\_\_\_\_  
 Number Street City Zip Code

<u>FOOD PREMISES</u>	SWEEPS CODE <input type="text"/>	E. U. NO. <input type="text"/>	<u>Waste Disposal</u>
<u>Bakery</u>	<u>Vending Machine</u>		<u>Sewage Transport Vehicle</u>
___ Under 2,000 sq. ft.	___ <u>Food Crop Growing &amp; Harvesting Oper.</u>		<u>Discrete Sewerage Facility</u>
___ 2,000 - 6,000 sq. ft.	___ <u>Ice Plant/Distributor</u>		<u>Private Waste Disposal</u>
___ Over 6,000 sq. ft.	___ <u>Other Food</u>		___ <u>Hog Farm</u>
<u>Food Market, Retail</u>			___ <u>Animal Feed Lot</u>
___ Under 3,000 sq. ft.			___ <u>Septic Tank</u>
___ 3,000 - 10,000 sq. ft.			___ Site Evaluation
___ Over 10,000 sq. ft.			___ Plan Review
<u>Confectionary</u>			___ Percolation Test
<u>Food Vehicle</u>			___ Installation
___ Industrial Catering			___ <u>Holding Tank</u>
___ Mobile Food Prep. Unit			___ Site Evaluation
___ Itinerant			___ Installation
<u>Restaurant</u>			___ Inspection
___ Temporary (1-45 days)	<u>GENERAL CATEGORIES</u>		<u>Water Supply-Utility</u>
___ Tavern, Cocktail lounge	___ <u>Public Swimming Area</u>		___ Community System
___ Snack Bar	___ <u>Wiping Rag Business</u>		___ Non-Community System
___ Drive-In, Take Out	___ <u>Mobilehome Park</u>		___ State Small Water System
___ Catering Commissary	___ No. Spaces _____		___ Local Small Water System
___ Under 26 seats	___ <u>Plan Review</u>		<u>Private Water Supply</u>
___ 26 - 50 seats	___ <u>Home Quarantine of Biting Animals</u>		___ Flow, Bacti. & Chem. Anal.
___ 51 - 75 seats			<u>Drinking Water Analysis</u>
___ Over 75 seats			___ Bacterial
			___ Chemical
			<u>Other</u>

Number of Units/Hrs. 1 1/2 Fee Per Unit/Hr. \$ 67.<sup>00</sup> Total Fee \$ 101.<sup>00</sup>

REMARKS: Site search : 1 1/2 hours x 67.<sup>00</sup> = 101.<sup>00</sup>  
Photocopying : 93 pages x 1.<sup>00</sup> = 93.<sup>00</sup>  
194.<sup>00</sup>

YOU WILL RECEIVE A BILL IN ACCORDANCE WITH ARTICLE 11 OF CHAPTER 6, TITLE 3 OF THE ORDINANCE CODE OF ALAMEDA COUNTY

Owner/Operator or Authorized Representative Peter Adler Date 6/28/91  
 Sanitarian R. Arulamanian Phone \_\_\_\_\_ Date 6/28/91

Cooley Godward Castro Huddleson & Tatum

*Appt for 6/28/91  
at 8:30 AM*

91 JUN 24 PM 1:17

Attorneys at Law

Northern California

Five Palo Alto Square

4th Floor

Palo Alto CA 94306

(415) 494-7622

Telex: 380816

COOLEY PA  
FAX: (415) 857-0663

San Francisco

(415) 981-5252

Menlo Park

(415) 494-7622

Southern California

Newport Beach

(714) 476-5252

June 21, 1991

Dr. Ravi Arulanantham  
Alameda County Health/  
Hazardous Materials  
80 Swan Way, Room 200  
Oakland, CA 94621

re: Dublin Multilayer Site  
6341 Scarlett Court  
Dublin, CA 94568

Dear Dr. Arulanantham:

This firm represents Mr. John Chan, President of Dublin Multilayer, Inc. in relation to the above-referenced site. This letter constitutes a formal request to review and copy the County's files relating to the site.

Please contact me at your earliest convenience so that we may schedule a mutually acceptable time for someone from my office to review and copy these files. I understand there is a \$67.00 charge for reviewing and copying these documents.

Sincerely,

*Kimberly S. Gawlik*

Kimberly S. Gawlik

CARROLL, BURDICK & McDONOUGH

SAN FRANCISCO OFFICE  
44 MONTGOMERY STREET  
SUITE 400  
SAN FRANCISCO, CALIFORNIA 94104  
(415) 989-5900  
FAX: (415) 989-0932

ATTORNEYS AT LAW  
1676 N. CALIFORNIA BLVD., SUITE 620  
WALNUT CREEK, CALIFORNIA 94596  
(415) 945-8579  
FAX: (415) 256-3110

SACRAMENTO OFFICE  
1303 "J" STREET  
SUITE 500  
SACRAMENTO, CALIFORNIA 95814  
(916) 446-2222  
FAX: (916) 446-6954

91 JUN 10 1991  
June 3, 1991

Ravi Arulanantham, Ph.D.  
Alameda County Health Agency  
Division of Hazardous Materials  
80 Swan Way, Room 200  
Oakland, CA 94621

Re: 6341 Scarlet Court, Dublin

Dear Dr. Arulanantham:

Enclosed please find the recent well sampling analysis performed by Clayton Environmental Consultants. They are currently in the process of preparing a work plan for the location of two additional borings and monitor wells and we will forward that report to you as soon as it is received.

If you have any questions, please give me a call.

Very truly yours,

CARROLL, BURDICK & McDONOUGH

*Lydia A. Faulkner*  
Lydia A. Faulkner

Dictated but not read.

LAF:jac  
Enclosure  
jac\15247-2.1tr

CARROLL, BURDICK & McDONOUGH

SAN FRANCISCO OFFICE  
44 MONTGOMERY STREET  
SUITE 400  
SAN FRANCISCO, CALIFORNIA 94104  
(415) 989-5900  
FAX: (415) 989-0932

ATTORNEYS AT LAW  
1676 N. CALIFORNIA BLVD., SUITE 620  
WALNUT CREEK, CALIFORNIA 94596  
(415) 945-8579  
FAX: (415) 256-3110

SACRAMENTO OFFICE  
1303 "J" STREET  
SUITE 500  
SACRAMENTO, CALIFORNIA 95814  
(916) 446-2222  
FAX: (916) 446-6964

May 30, 1991

Ravi Arulanantham, Ph.D.  
Alameda County Health Agency  
Division of Hazardous Materials  
80 Swan Way, Room 200  
Oakland, CA 94621

Re: 634 Scarlett Court  
Dublin, California

Dear Ravi:

This letter will provide you with the current status of the property located at 6341 Scarlet Court in Dublin, California.

As I indicated in our previous telephone conversation, Clayton Environmental Consultants provided an addendum to Busick Air Conditioning outlining the fees associated with establishing four additional bore holes and two additional monitoring wells on the property.

The information provided to Busick Air Conditioning by Clayton Environmental does not constitute a work plan. It is a bid proposal only. I understand that you must specifically review and authorize a proposed work plan.

I have requested that Clayton Environmental immediately prepare a work plan for your review and authorization before we proceed with additional work on the property.

I also requested that Clayton provide an additional sample from the monitoring well that is currently in place on the property. The well sample was obtained on May 24, 1991 and results of that sample will be available on June 7, 1991. As soon as the results of that sample are obtained, they will be forwarded to your office for review.

CARROLL, BURDICK & McDONOUGH


Dr. Ravi Arulanantham  
May 30, 1991  
Page 2

I expect to have the work plan for the location of the additional monitoring wells and bore holes no later than June 7, 1991. As soon as I receive that work plan, I will forward it to you for review and authorization so that we can commence further sampling on the property.

If you have any further questions, please do not hesitate to contact me.

Very truly yours,

CARROLL, BURDICK & McDONOUGH



Lydia A. Faulkner

LAF:jac  
cc: Doreen Green  
jac\15247-2.1tr

DEPARTMENT OF ENVIRONMENTAL HEALTH

MFR Sent \_\_\_\_\_ (date)

APPLICATION FORM

PURPOSE: Permit Application  Service  Renewal

Computer No. \_\_\_\_\_

TYPE OF ACTION: New Premises  Change of Owner  Change of Name  Change of Status  Change of Mailing Address  Inactivate  Delete  Unincorp.

Premises Name: Dublin Multi Layer  
A. Premises Address: 6341 Scarlett Court Dublin CA 94568  
Number Street City Zip Code Phone

Owner/Applicant: Scott Osmus  
B. Mailing Address: 3000 Executive Parkway #300 San Ramon CA 94583  
Number Street City Zip Code Phone

SEND BILLING TO ADDRESS: A, B (circle one)

Prior Business Name \_\_\_\_\_ Prior Owner's Name \_\_\_\_\_

Property Owner \_\_\_\_\_  
If corporation, also show name of corporation president \_\_\_\_\_ Phone \_\_\_\_\_

Address \_\_\_\_\_  
Number Street City Zip Code

E.U. NO. \_\_\_\_\_ C.P. CODE \_\_\_\_\_

FOOD CATEGORIES

- Bakery**
- \_\_\_ Under 2,000 sq. ft. (130)
- \_\_\_ 2,000 - 6,000 sq. ft. (131)
- \_\_\_ Over 6,000 sq. ft. (132)
- Food Market, Retail**
- \_\_\_ Under 3,000 sq. ft. (120)
- \_\_\_ 3,000 - 10,000 sq. ft. (121)
- \_\_\_ Over 10,000 sq. ft. (122)
- \_\_\_ Confectionary (125)
- Restaurant**
- \_\_\_ Tavern, Cocktail lounge (104)
- \_\_\_ Snack Bar (105)
- \_\_\_ Drive-In, Take Out (110)
- \_\_\_ Catering Commissary (111)
- \_\_\_ Under 26 seats (100)
- \_\_\_ 26 - 50 seats (101)
- \_\_\_ 51 - 75 seats (102)
- \_\_\_ Over 75 seats (103)
- \_\_\_ In Plant Feeding (114)
- \_\_\_ Bed & Breakfast (Cont.) (115)
- \_\_\_ Bed & Breakfast (Reg.) (116)

- Temporary Food Operation**
- \_\_\_ Special Event Facility (113) (not to exceed 3 days)
- \_\_\_ Temporary Food Facility (108) (not to exceed 21 days)
- \_\_\_ Seasonal Food Facility (129) (not to exceed 45 days)
- Food Vehicle**
- \_\_\_ Vehicle Application Fee
- \_\_\_ Mobile Food Prep. Unit (107)
- \_\_\_ Stationary M.F.P.U. (117)
- \_\_\_ Retail Food Vehicle (112)
- \_\_\_ Itinerant Vehicle (128)

- Private Waste Disposal**
- \_\_\_ Site Evaluation
- \_\_\_ Percolation Test
- \_\_\_ Plan Review
- \_\_\_ Installation
- Holding Tank**
- \_\_\_ Site Evaluation
- \_\_\_ Installation
- \_\_\_ Inspection
- Water Supply-Utility**
- \_\_\_ Community System
- \_\_\_ Non-Community System
- \_\_\_ State Small Water System
- \_\_\_ Local Small Water System
- Private Water Supply**
- \_\_\_ Flow, Bacti. & Chem. Anal.
- Drinking Water Analysis**
- \_\_\_ Bacterial
- \_\_\_ Chemical
- \_\_\_ Flow Rate

GENERAL CATEGORIES

- \_\_\_ Vending Machine
- Other Food**
- \_\_\_ Plan Review
- \_\_\_ Special Service
- \_\_\_ Public Swimming Area
- \_\_\_ Commercial Spa
- \_\_\_ Mobilehome Park
- \_\_\_ No. Spaces

Other \_\_\_\_\_

Number of Units/Hrs. \_\_\_\_\_ Fee Per Unit/Hr. \$ 67.<sup>00</sup> Total Fee \$ 95.<sup>00</sup>

REMARKS: Site Search

You will receive a BILL in accordance with Article 11 of Chapter 6, Title 3 of the Ordinance Code of Alameda County

Owner/Applicant: Scott Osmus Date: \_\_\_\_\_  
Sanitarian: A.R. Arunathan Phone: \_\_\_\_\_ Date: 5/21/91

CARROLL, BURDICK & McDONOUGH

SAN FRANCISCO OFFICE:  
44 MONTGOMERY STREET  
SUITE 400  
SAN FRANCISCO, CALIFORNIA 94104  
(415) 989-5900  
FAX: (415) 989-0932

ATTORNEYS AT LAW  
1876 N. CALIFORNIA BLVD., SUITE 620  
WALNUT CREEK, CALIFORNIA 94596 53  
(415) 945-8579  
FAX: (415) 256-3110

SACRAMENTO OFFICE:  
1303 "J" STREET  
SUITE 500  
SACRAMENTO, CALIFORNIA 95814  
(916) 446-2222  
FAX: (916) 446-6954

May 16, 1991

Ravi Arulanantham, Ph.D.  
Alameda County Health Agency  
Division of Hazardous Materials  
80 Swan Way, Room 200  
Oakland, CA 94621

Re: 6341 Scarlet Court, Dublin

Dear Dr. Arulanantham:

The California Department of Health Services recently initiated a policy regarding site mitigation as set forth in their management memo no. 90-11. I enclose a copy for your review.

As you can see, the state has decided not to pursue cost recovery or enforcement actions against property owners who did not themselves contribute or aggravate ground water contamination. We were simply wondering whether the Alameda County Health Agency subscribes to the same policy. If so, it would seem inappropriate for Busick Air to be required to continue site investigation and ground water remediation at the above property.

We are, of course, always happy to cooperate and assist the Alameda County Health Agency in their efforts to implement site mitigation against those parties who are actually responsible for the contamination. In this regard, we enclose copies of letters we have recently written to those parties responsible for the ground water contamination which has been discovered at the Busick property.

CARROLL, BURDICK & McDONOUGH

Dr. Ravi Arulanantham  
Re: 6341 Scarlet Court, Dublin  
May 16, 1991  
Page 2

Please call when you have had a chance to review these materials. We would hope we can inform Busick that Alameda County will permit occupancy of the building without further action on Busick's part.

Please let us know your thoughts.

Very truly yours,

CARROLL, BURDICK & McDONOUGH

  
Lydia A. Faulkner

LAF:jac  
Enclosures  
jac\15247-1.1tr





SAFECO INSURANCE COMPANIES  
NORTHERN CALIFORNIA BRANCH OFFICE  
3000 EXECUTIVE PARKWAY, SUITE 300  
SAN RAMON, CA 94583-2300

TELEPHONE: (415) 277-8600  
FACSIMILE: (415) 277-8636  
MAILING ADDRESS: P.O. BOX 5152  
SAN RAMON, CA 94583-5152

May 9, 1991

Ravi Arulanantham <sup>5/16</sup>  
c/o Division of Hazardous Materials  
80 Swan Way, Suite 200  
Oakland, CA 94621

Subject: Alleged contamination at 6341 Scarlett Court,  
Dublin, California 94566

Dear Mr. Arulanantham:

I am the claims adjuster who is handling a claim submitted to  
SAFECO Insurance Company by Dublin Multilayer, Inc.

I am requesting that I be allowed to review your file concerning  
this matter, as this will be beneficial to my investigation.

Please contact me as soon as you have had an opportunity to  
consider my request. Your expediency in this matter is  
appreciated.

If you have any questions or require any additional information,  
please do not hesitate to call me at 415/277-8778.

Sincerely,

SAFECO INSURANCE COMPANY OF AMERICA

Scott Osmus  
Environmental Claims  
rp/th2/1.9

*appointment set for  
05/18/91 at 10:30 AM  
with Scott.*



SAFECO INSURANCE COMPANY OF AMERICA  
SAFECO LIFE INSURANCE COMPANY  
GENERAL INSURANCE COMPANY OF AMERICA  
FIRST NATIONAL INSURANCE COMPANY OF AMERICA  
SAFECO NATIONAL INSURANCE COMPANY  
SAFECO NATIONAL LIFE INSURANCE COMPANY  
SAFECO INSURANCE COMPANY OF ILLINOIS

CARROLL, BURDICK & McDONOUGH

SAN FRANCISCO OFFICE:  
44 MONTGOMERY STREET  
SUITE 400  
SAN FRANCISCO, CALIFORNIA 94104  
(415) 989-6900  
FAX: (415) 989-0932

ATTORNEYS AT LAW  
1676 N. CALIFORNIA BLVD., SUITE 620  
WALNUT CREEK, CALIFORNIA 94596  
(415) 945-8579  
FAX: (415) 256-3110

SACRAMENTO OFFICE:  
1303 "J" STREET  
SUITE 600  
SACRAMENTO, CALIFORNIA 95814  
(916) 446-2222  
FAX: (916) 446-6954

March 29, 1991

Ravi Arulanantham, Ph.D.  
Alameda County Health Agency  
Division of Hazardous Materials  
80 Swan Way, Room 200  
Oakland, CA 94621

Dear Dr. Arulanantham:

This letter will confirm our telephone conversation of March 27, 1991, wherein I indicated that our firm would be representing Busick-Gearing Properties in regard to all insurance issues associated with the hazardous materials cleanup of property located at 6341 Scarlet Court in Dublin, California.

There are a number of insurance policies that should provide insurance coverage to Busick for the damages associated with the current soil and water contamination condition. We are in contact with those carriers and entities that should provide coverage to Busick for this loss and would request a short delay in the requirement of drilling additional wells on the property for monitoring purposes.

We hope to have some conclusive information regarding the availability of insurance proceeds to cover this loss within the next 60-90 days and will continue to keep you advised of all developments in this regard.

We would appreciate very much being kept informed of any contact you have with Busick Properties or Dublin Multilayer particularly in regard to your anticipated closing of the investigation in regard to Dublin Multilayer. Please carbon copy us on all correspondence in this regard.

I would also like to review your investigative file regarding Dublin Multilayer, inasmuch as your findings regarding Dublin Multilayer will be very critical in securing insurance coverage for Busick-Gearing Properties for this loss. Please contact me so that we can make arrangements to review your file.


CARROLL, BURDICK & McDONOUGH

Ravi Arulanantham, Ph.D.  
March 29, 1991  
Page 2

If you have any further questions or I can be of any assistance at any time, please do not hesitate to contact me. We will continue to keep you advised on a regular basis regarding our progress in this matter.

Very truly yours,

CARROLL, BURDICK & McDONOUGH

  
Lydia A. Faulkner

LAF:jac  
cc: Doreen Green  
jac\busick.ltr

CARROLL, BURDICK & McDONOUGH

SAN FRANCISCO OFFICE  
44 MONTGOMERY STREET  
SUITE 400  
SAN FRANCISCO, CALIFORNIA 94104  
(415) 989-5900  
FAX: (415) 989-0932

ATTORNEYS AT LAW  
1676 N. CALIFORNIA BLVD., SUITE 620  
WALNUT CREEK, CALIFORNIA 94596  
(415) 945-8579  
FAX: (415) 256-3110

SACRAMENTO OFFICE  
1303 "J" STREET  
SUITE 500  
SACRAMENTO, CALIFORNIA 95814  
(916) 446-2222  
FAX: (916) 446-0954

March 29, 1991

Via Registered Mail

Charles F. Miller  
As Registered Agent for  
Precision Metal Fabricators  
575 Menlo Drive, Suite 1  
Rocklin, CA 95677

Dear Mr. Miller:

Between 1971 until December 1, 1979, Precision Metal Fabricators (Nuclear Specialties, Inc.) was a tenant of 6341 Scarlet Court in Dublin, California. This property was owned by Busick-Gearing Properties and was leased to Nuclear Specialties, Inc.

NSI merged with Precision Metal Fabricators on April 28, 1978 and vacated the premises on December 1, 1979.

The subsequent tenant of that property was Dublin Multilayer, a manufacturer of circuit boards. A fire occurred on the premises of Dublin Multilayer in January 15, 1990. The investigation and cleanup of that fire revealed that the toxic chemicals, Trichloroethene (TCE) and Dichloroethene (DCE) had been found in the water and soil under the sump located on the premises.

Dublin Multilayer has never used TCE or DCE in its operations.

Our own investigation has revealed that an escape of TCE and DCE into the sump probably occurred at the time that Precision Metal Fabricators vacated the premises. As a result, we believe that Precision Metal Fabricators is responsible for this loss to Busick-Gearing Properties which includes all costs expended in relation to the clean-up and continued monitoring of ground water and soil on the property. The Alameda County Department of Environmental Health will not permit reoccupation of the premises until such time as the water and soil levels of TCE and DCE are within acceptable limits.

Charles F. Miller  
March 29, 1991  
Page 2

We are requesting at this time that you immediately place your current insurance carrier on notice regarding this claim against Precision Metal Fabricators. We are also requesting that you notify all previous insurance carriers for Precision Metal Fabricators, in particular, those insurance companies which provided insurance to Precision Metal Fabricators in 1979.

The lease agreement between Busick-Gearing Properties and Precision Metal Fabricators required under Section 12, Busick-Gearing Properties be indemnified and held harmless from and against all liability, damages, costs, and expenses arising out of Precision Metal Fabricator's occupancy of the premises.

Section 13 of that same lease agreement required Busick-Gearing to be named as an additional insured under Precision's policy of insurance. Please contact your insurance company to determine whether a certificate of insurance was ever issued to Busick-Gearing Properties in this regard.

Please notify us as soon as you have placed your insurance companies on notice of this loss. If you have any further questions, please do not hesitate to contact me.

Very truly yours,

CARROLL, BURDICK & McDONOUGH

  
Lydia A. Faulkner

LAF:jac  
cc: Doreen Green  
jac\busick-2.1tr

## TOXIC SUBSTANCES CONTROL DIVISION

## MANAGEMENT MEMO

MANAGEMENT MEMO #90-11

PROGRAM MANAGEMENT MANUAL VOLUME: Site Mitigation

TITLE: RP - Ownership of Property Over Contaminated Ground Water.

Determining Whether to Pursue Cost Recovery or Enforcement Actions Against Property Owners Whose Land Overlies Contaminated Ground Water Solely on the Basis of Land Ownership

**AFFECTED PROGRAMS:**

Site Mitigation, Cost Recovery, Toxics Legal Office

**BACKGROUND:**

State and federal laws regarding site mitigation (Comprehensive Environmental Response, Compensation and Liability Act of 1980/Superfund Amendments and Reauthorization Act (42 United States Code 9607 (a)(1)) and Chapter 6.8 of the Health and Safety Code (H&SC)) provide that persons owning property where "...hazardous substances have come to be located..." may be liable for response costs and may be subject to various orders. This definition is clear, and is without regard to the origin of the hazardous substance. Thus such land owners, according to the law, are responsible parties. The statutes also provide certain defenses to liability. In some cases, ground water flow carries contaminants in the subsurface under property owned by a person having no relationship to the original release, except ownership of property over contaminated ground water.

**POLICY:**

As a general policy, the Toxic Substances Control Program will not pursue or enforce action against a person who is a responsible party solely on the basis of ownership of land overlying contaminated ground water. Exceptions to the general policy may be made, however, if approved by the Deputy Director. If, however, the person has caused or contributed to the release in some way, or if the person's activities significantly spread the contamination or exacerbate the problem, then this policy does not apply. The following are examples of activities to consider under this policy: (1) extraction, injection, and other operations that affect ground water hydraulics; (2) improper construction or operation of wells connecting contaminated and uncontaminated aquifers; and (3) pumping from a well that increases the rate of flow of contaminated ground water.

An example of where this policy should be applied is in the case of a person who owns a residence lying over contaminated ground water. If the owner has not caused or contributed to the contamination in any way, the Department of Health Services (Department) will not pursue cost recovery against the owner or issue any order to the owner requiring the owner to undertake remedial action.

Another example is a water company owning land and/or wells that extract water from a contaminated aquifer. If the water company has not caused or contributed to the contamination in any way, and its drilling and pumping activities have not and will not exacerbate the problem or interfere with remedial action, the Department will not pursue cost recovery against the water company or issue any order to the water company requiring it to undertake remedial action. If, however, the water company has drilled a well improperly, connected a contaminated aquifer with an uncontaminated aquifer, or if the water company's pumping from a well causes the plume of contaminated ground water to spread significantly more rapidly, then the Department will consider cost recovery or enforcement action against the water company to the extent necessary under the circumstances within the law.


Generally, cost recovery or enforcement action will be taken only when actions to exacerbate the ground water are implemented or continued after the discovery of the ground water contamination, and notification by the Department that such actions should be terminated or curtailed has been given.

CONTACT:

Stan Phillippe, Chief  
Site Mitigation Branch  
(916) 324-3773  
ATSS 8-454-2443

Michael Shepard  
Toxics Legal Office  
(916) 323-4910  
ATSS 8-473-4910

12/7/90  
\_\_\_\_\_  
Date

  
\_\_\_\_\_  
John J. Kearns  
Deputy Director  
Toxic Substances  
Control Program

white -env.health  
yellow -facility  
pink -files

# ALAMEDA COUNTY, DEPARTMENT OF ENVIRONMENTAL HEALTH

80 Swan Way, #200  
Oakland, CA 94621  
(415) 271-4320

## Hazardous Materials Division Inspection Form

Site ID# \_\_\_\_\_ Site Name Dublin Multi-layer Inc Today's Date 03/1/91  
 Site Address 6341 Scarlett court EPA ID# \_\_\_\_\_  
 City Dublin Zip 94566 Phone 829-1956

MAX Amt. Stored > 500lbs/55g/200cf?  Y  N  
 Hazardous Waste generated per month? \_\_\_\_\_

### Inspection Categories:

- I. Haz. Mat/Waste GENERATOR/TRANSPORTER
- II. Business Plans, Acute Hazardous Materials
- III. Underground Tanks

The marked items represent violations of the Calif. Administration Code (CAC) or the Health & Safety Code (HS&C)

### IA GENERATOR (Title 22)

Manifest	<input type="checkbox"/> 1. Waste ID	* 66471
	<input type="checkbox"/> 2. EPA ID	66472
	<input type="checkbox"/> 3. > 90 days	66508
	<input type="checkbox"/> 4. Label dates	66508
	<input type="checkbox"/> 5. Biennial	66493
Manifest	<input type="checkbox"/> 6. Records	66492
	<input type="checkbox"/> 7. Correct	66484
	<input type="checkbox"/> 8. Copy sent	66492
	<input type="checkbox"/> 9. Exception	66484
	<input type="checkbox"/> 10. Copies Rec'd	66492
Misc.	<input type="checkbox"/> 11. Treatment	66371
	<input type="checkbox"/> 12. On-site Disp. (H.S.&C.)	26189.5
	<input type="checkbox"/> 13. Ex Haz. Waste	66570
Prevention	<input type="checkbox"/> 14. Communications	67121
	<input type="checkbox"/> 15. Aisle Space	67124
	<input type="checkbox"/> 16. Local Authority	67126
	<input type="checkbox"/> 17. Maintenance	67120
Prevention	<input type="checkbox"/> 18. Training	67105
	<input type="checkbox"/> 19. Prepared	67140
Conf. Agency	<input type="checkbox"/> 20. Name List	67141
	<input type="checkbox"/> 21. Copies	67141
	<input type="checkbox"/> 22. Emg. Coord. Trng.	67144
Containers, Tanks	<input type="checkbox"/> 23. Condition	67241
	<input type="checkbox"/> 24. Compatibility	67242
	<input type="checkbox"/> 25. Maintenance	67243
	<input type="checkbox"/> 26. Inspection	67244
	<input type="checkbox"/> 27. Buffer Zone	67246
	<input type="checkbox"/> 28. Tank Inspection	67259
	<input type="checkbox"/> 29. Containment	67245
	<input type="checkbox"/> 30. Safe Storage	67261
	<input type="checkbox"/> 31. Freeboard	67257

### Comments:

I sat with Mr. Jon Krain and page by page reviewed the final closure report which describes the investigation and cleanup activities that I have been overseeing over a year.

Based on the report and my past inspections it appears to me that further investigation and cleanup is not necessary for this site.

However, further work could be required if conditions change or any additional contamination is discovered at the site.

Remediation of the halogenated solvents contaminated soil and ground water (found underneath the former "wet floor area") is now being undertaken by Busick Properties.

If you need any further help or information please contact me at 271-4320.

### IB TRANSPORTER (Title 22)

Manifest	<input type="checkbox"/> 32. Applic./Insurance	66428
	<input type="checkbox"/> 33. Comp. Cert./CHP Insp.	66448
	<input type="checkbox"/> 34. Containers	66465
Manifest	<input type="checkbox"/> 35. Vehicles	66465
	<input type="checkbox"/> 36. EPA ID #s	66531
	<input type="checkbox"/> 37. Correct	66541
	<input type="checkbox"/> 38. HW Delivery	66543
	<input type="checkbox"/> 39. Records	66544
Conf's	<input type="checkbox"/> 40. Name/ Covers	66545
	<input type="checkbox"/> 41. Recyclables	66800

Rev 6/88

Contact: John P. Chan

Title: PRESIDENT

Signature: [Signature]

Inspector: R. Arslan

Signature: [Signature]



565679

WELLS COUNTY HEALTH CARE SERVICES  
HAZARDOUS MATERIALS PROGRAM/ENVIRONMENTAL HEALTH SERVICES

SERVICE REQUESTED: Remediation  
 NAME OF SITE : Dublin Multi-layer  
 ADDRESS : 6341 SCARLET COURT  
Dublin 99568  
 CONTRACTOR : Dublin Multi-layer  
 ADDRESS : 6341 SCARLET COURT  
Dublin PHONE # \_\_\_\_\_  
 CONTACT PERSON : \_\_\_\_\_ PHONE # \_\_\_\_\_  
 DATE OF DEPOSIT : 2-27-90 AMOUNT OF DEPOSIT \$500.<sup>00</sup>

DATE	ACTION TAKEN	IN	OUT	HRS.	<del>X60</del> X56	SUB/TOT	BALANCE
2/20/90	review of proposed plan			1		60.00	440. <sup>00</sup>
2/27/90	inspection of clean up work			1 1/2		90.00	350. <sup>00</sup>
3/8/90	inspection of floor clean up			.45		45.00	305. <sup>00</sup>
3/21/90	inspection of clean up			1		60. <sup>00</sup>	245. <sup>00</sup>
5/7/90	inspection of site			1/2		30. <sup>00</sup>	215. <sup>00</sup>
6/6/90	inspection of site			1/2		30. <sup>00</sup>	185. <sup>00</sup>
7/11/90	on site inspection			2		120. <sup>00</sup>	65. <sup>00</sup>
8/28/90	on site meeting			1		60. <sup>00</sup>	5. <sup>00</sup>
3/1/91	new deposit						268. <sup>00</sup>
3/1/91	plan review / inspection / closure			4 hours			
	3/15/91						

Site Close

PROJECT COMPLETED BY : A.R. Arulanantham  
 DATE OF COMPLETION : 03/01/91 DATE SENT TO BILLING: \_\_\_\_\_  
 TOTAL COST OF PROJECT: 768.<sup>00</sup> REFUND AMOUNT : None

TO BE REPORTED WEEKLY TO THE ACCOUNTING DEPARTMENT FOR CASHFLOW ADJUSTMENT

white -env.health  
 yellow -facility  
 pink -files

ALAMEDA COUNTY, DEPARTMENT OF ENVIRONMENTAL HEALTH

80 Swan Way, #200  
 Oakland, CA 94621  
 (415) 271-4320

Hazardous Materials Division Inspection Form

Site ID# \_\_\_\_\_ Site Name Dublin Multilayer Inc Today's Date 08/27/90  
 Site Address 6341 Scarlett Court EPA ID# \_\_\_\_\_  
 City Dublin Zip 94566 Phone 829-1956

MAX Amt. Stored > 500lbs/55g/200cf?  Y  N  
 Hazardous Waste generated per month? \_\_\_\_\_

- Inspection Categories:**  
 I. Haz. Mat/Waste GENERATOR/TRANSPORTER  
 II. Business Plans, Acute Hazardous Materials  
 III. Underground Tanks

The marked items represent violations of the Calif. Administration Code (CAC) or the Health & Safety Code (HS&C)

- I.A GENERATOR (Title 22)**
- 1. Waste ID \* 66471
  - 2. EPA ID 66472
  - 3. > 90 days 66508
  - 4. Label dates 66508
  - 5. Biennial 66493
- 
- Manifest**
- 6. Records 66492
  - 7. Correct 66484
  - 8. Copy sent 66492
  - 9. Exception 66484
  - 10. Copies Rec'd 66492
- 
- Misc.**
- 11. Treatment 66371
  - 12. On-site Disp. (H.S.&C.) 26189.5
  - 13. Ex Haz. Waste 66570
- 
- Prevention**
- 14. Communications 67121
  - 15. Aisle Space 67124
  - 16. Local Authority 67126
  - 17. Maintenance 67120
  - 18. Training 67105
- 
- Contingency**
- 19. Prepared 67140
  - 20. Name List 67141
  - 21. Copies 67141
  - 22. Emg. Coord. Trng. 67144
- 
- Containers, Tanks**
- 23. Condition 67241
  - 24. Compatibility 67242
  - 25. Maintenance 67243
  - 26. Inspection 67244
  - 27. Buffer Zone 67246
  - 28. Tank Inspection 67259
  - 29. Containment 67245
  - 30. Safe Storage 67251
  - 31. Freeboard 67257
- 
- I.B TRANSPORTER (Title 22)**
- 32. Applic./Insurance 66428
  - 33. Comp. Cert./CHP Insp. 66448
  - 34. Containers 66465
- 
- Manifest**
- 35. Vehicles 66465
  - 36. EPA ID #s 66531
  - 37. Correct 66541
  - 38. HW Delivery 66543
  - 39. Records 66544
- 
- Cont'rs**
- 40. Name/ Covers 66545
  - 41. Recyclables 66800

**Comments:**

This is a follow up inspection.  
 Mr. Jon Karin informed me that the water samples had 5000 PPb of TCE and 110 PPb of TCA and 440 PPb of Tetrachloroethene.  
 Please submit a ~~complete~~ work plan in accordance with the Tri Regional recommendation as to how this water contamination is to be remediated.  
 The report should be submitted to this office in 30 days.  
 If adequate number of monitoring wells are to be installed the current pit can be closed now until future work.

Rev 6/88

Contact: Jon Karin  
 Title: RAZ-MAN Inspector: R. Ambramant  
 Signature: [Signature] Signature: Rain

white -env.health  
 yellow -facility  
 pink -files

ALAMEDA COUNTY, DEPARTMENT OF ENVIRONMENTAL HEALTH

80 Swan Way, #200  
 Oakland, CA 94621  
 (415) 271-4320

Hazardous Materials Division Inspection Form

page 1 of 2

Site ID# \_\_\_\_\_ Site Name Dublin Multi Layer Inc. Today's Date 07/11/90  
 Site Address 6341 Scarlett Court EPA ID# \_\_\_\_\_  
 City Dublin Zip 94566 Phone 829-1956.

MAX Amt. Stored > 500lbs/55g/200cf?  Y  N  
 Hazardous Waste generated per month? \_\_\_\_\_

- Inspection Categories:**  
 I. Haz. Mat/Waste GENERATOR/TRANSPORTER  
 II. Business Plans, Acute Hazardous Materials  
 III. Underground Tanks

The marked items represent violations of the Calif. Administration Code (CAC) or the Health & Safety Code (HS&C)

<b>LA GENERATOR (Title 22)</b>		
	1. Waste ID	* 66471
	2. EPA ID	66472
	3. > 90 days	66508
	4. Label dates	66508
	5. Biennial	66493
Manifest	6. Records	66492
	7. Correct	66484
	8. Copy sent	66492
	9. Exception	66484
	10. Copies Rec'd	66492
Misc.	11. Treatment	66371
	12. On-site Disp. (H.S.&C.)	26189.5
	13. Ex Haz. Waste	66570
Prevention	14. Communications	67121
	15. Aisle Space	67124
	16. Local Authority	67126
	17. Maintenance	67120
	18. Training	67105
Contn. Agency	19. Prepared	67140
	20. Name List	67141
	21. Copies	67141
	22. Emg. Coord. Tmg.	67144
Containers, Tanks	23. Condition	67241
	24. Compatibility	67242
	25. Maintenance	67243
	26. Inspection	67244
	27. Buffer Zone	67246
	28. Tank Inspection	67259
	29. Containment	67245
	30. Safe Storage	67261
	31. Freeboard	67257
	<b>LB TRANSPORTER (Title 22)</b>	
	32. Applic./Insurance	66428
	33. Comp. Cert./CHP Insp.	66448
	34. Containers	66465
Manifest	35. Vehicles	66465
	36. EPA ID #s	66531
	37. Correct	66541
	38. HW Delivery	66543
	39. Records	66544
Cont're	40. Name/ Covers	66545
	41. Recyclables	66800

**Comments:**

I had a meeting with Mr. Jon Karvin today. Mr. Jon Karvin explained to me the cleanup activities done so far.  
 \* On March 27th 5 samples (soil) were taken. Samples # 2 had 6200 ppm Cu and sample # 3 had 480 ppm Cu. As a result about 40 yrd<sup>3</sup> of soil was removed. The soil is now being profiled and Jon informed me that it will be disposed as hazardous waste.  
 on sample # 5 (where above level Cu was observed), during excavation the workers noticed a powerful solvent odour. When soil was analysed Trichloroethene was found to be present. In one sample it was above the permissible level. (I have checked all Lab results)  
 \* After further investigation it was found that the previous ~~op~~ operator (Nuclear Specialist) had discharged the solvent. The Owners of the property have now assumed responsibility for this part of cleanup. (The soil samples are taken today for this

Rev 6/88

Contact: NON KRAIN  
 Title: FAC. MGR  
 Signature: [Signature]

Inspector: AR. Arulananth  
 Signature: Ravi

white -env.health  
 yellow -facility  
 pink -files

ALAMEDA COUNTY, DEPARTMENT OF ENVIRONMENTAL HEALTH

80 Swan Way, #200  
 Oakland, CA 94621  
 (415) 271-4320

Hazardous Materials Division Inspection Form

page 2 of 2

Site ID# \_\_\_\_\_

Site Name Dublin Multi Layer.

Today's Date 07/11/90

Site Address \_\_\_\_\_

EPA ID# \_\_\_\_\_

City \_\_\_\_\_

Zip 94

Phone \_\_\_\_\_

MAX Amt. Stored > 500lbs/55g/200cf? **Y N**  
 Hazardous Waste generated per month?  
 \_\_\_\_\_

Inspection Categories:

- I. Haz. Mat/Waste GENERATOR/TRANSPORTER
- II. Business Plans, Acute Hazardous Materials
- III. Underground Tanks

The marked items represent violations of the Calif. Administration Code (CAC) or the Health & Safety Code (HS&C)

I.A GENERATOR (Title 22)

- |                   |                                 |         |
|-------------------|---------------------------------|---------|
| ___               | 1. Waste ID                     | * 66471 |
| ___               | 2. EPA ID                       | 66472   |
| ___               | 3. > 90 days                    | 66508   |
| ___               | 4. Label dates                  | 66508   |
| ___               | 5. Biennial                     | 66493   |
| <hr/>             |                                 |         |
| Manifest          | ___ 6. Records                  | 66492   |
|                   | ___ 7. Correct                  | 66484   |
|                   | ___ 8. Copy sent                | 66492   |
|                   | ___ 9. Exception                | 66484   |
|                   | ___ 10. Copies Rec'd            | 66492   |
| <hr/>             |                                 |         |
| Misc.             | ___ 11. Treatment               | 66371   |
|                   | ___ 12. On-site Disp. (H.S.&C.) | 26189.5 |
|                   | ___ 13. Ex Haz. Waste           | 66570   |
| <hr/>             |                                 |         |
| Prevention        | ___ 14. Communications          | 67121   |
|                   | ___ 15. Aisle Space             | 67124   |
|                   | ___ 16. Local Authority         | 67126   |
|                   | ___ 17. Maintenance             | 67120   |
|                   | ___ 18. Training                | 67105   |
| <hr/>             |                                 |         |
| Contn. Agency     | ___ 19. Prepared                | 67140   |
|                   | ___ 20. Name List               | 67141   |
|                   | ___ 21. Copies                  | 67141   |
|                   | ___ 22. Emg. Coord. Tmg.        | 67144   |
| <hr/>             |                                 |         |
| Containers, Tanks | ___ 23. Condition               | 67241   |
|                   | ___ 24. Compatibility           | 67242   |
|                   | ___ 25. Maintenance             | 67243   |
|                   | ___ 26. Inspection              | 67244   |
|                   | ___ 27. Buffer Zone             | 67246   |
|                   | ___ 28. Tank Inspection         | 67259   |
|                   | ___ 29. Containment             | 67245   |
|                   | ___ 30. Safe Storage            | 67261   |
|                   | ___ 31. Freeboard               | 67257   |

Comments:

(purpose.)

\*Mr. Jon Karin is preparing a Complete report as to how & where the soil will be disposed, and how the holes will be refilled.  
 \* Mr. Jon thinks it will take another month for all necessary activities to be completed.

Note:

Please submit to this office a complete documentation of all Clean up activities.

I.B TRANSPORTER (Title 22)

- |          |                           |       |
|----------|---------------------------|-------|
| ___      | 32. Applic./Insurance     | 66428 |
| ___      | 33. Comp. Cert./CHP Insp. | 66448 |
| ___      | 34. Containers            | 66465 |
| <hr/>    |                           |       |
| Manifest | ___ 35. Vehicles          | 66465 |
|          | ___ 36. EPA ID #s         | 66531 |
|          | ___ 37. Correct           | 66541 |
|          | ___ 38. HW Delivery       | 66543 |
|          | ___ 39. Records           | 66544 |
| <hr/>    |                           |       |
| Cont'n's | ___ 40. Name/ Covers      | 66545 |
|          | ___ 41. Recyclables       | 66800 |

Rev 6/88

Contact: Jon Karin

Title: Fac Mgr

Signature: [Signature]

Inspector: R. Arulmanth

Signature: Ravi

**DUBLIN MULTILAYER, INC.**  
 6341 Scarlett Court  
 DUBLIN, CA 94568

# PURCHASE ORDER

**(415) 829-1956**  
 Resale #SR CHA 21-690797

Show this Purchase Order Number  
 on all correspondence, invoices,  
 shipping papers and packages.

## 8254

TO ALAMEDA CO. HEALTH AGENCY  
DEPT OF COMMUN. HEALTH

DATE <u>2-24-90</u>	REQUISITION NO.
SHIP TO <u>DECAO PROJECT</u>	

REQUISITIONED BY	WHEN SHIP	SHIP VIA	F.O.B. POINT	TERMS
<u>KNAIN</u>				
			<u>\$500 DEPOSIT</u>	
			<u>DEDUCT \$50/wk from</u>	
			<u>DAD'S TIME.</u>	
			<u>BALANCE TO DN AT</u>	
			<u>CLOSE OF PROJECT</u>	

- Please send \_\_\_\_\_ copies of your invoice.
- Order is to be entered in accordance with prices, delivery and specifications shown above.
- Notify us immediately if you are unable to ship as specified.

AUTHORIZED BY \_\_\_\_\_

ORIGINAL

DUBLIN MULTILAYER, INC.

6341 Scarlett Court  
Dublin, California 94566

February 24, 1990

Alameda County Health Agency  
Division of Hazardous Materials  
Department of Environmental Health  
80 Swan Way, Room 200  
Oakland, California 94621


Attention: Ravi Arulanantham

Dear Ravi,

Please accept the enclosed work schedule for the decontamination of Dublin Multilayer's fire damaged wet process area. All of the contractors we have retained for this project are trained and experienced in hazardous materials operations. They and all of us at Dublin Multilayer are determined to proceed in a manner that is safe, responsible, in full compliance with all applicable codes and with the guidance of your department and the Dublin San Ramon Water Services Department.

We have attached a check for \$500.00 payable to the Division of Hazardous Materials. It is our understanding that charges for your services will be deducted at the rate of \$50.00 per hour and the balance refunded to us at the close of this project. Please reference our purchase order number 8254 for these transactions.

Respectfully,



Jon Krain  
Facilities Manager

DUBLIN MULTILAYER, INC.

6341 Scarlett Court  
Dublin, California 94566

February 24, 1990

WORK SCHEDULE FOR DECONTAMINATION OF THE WET PROCESS AREA  
SUBSEQUENT TO FIRE OF JANUARY 15, 1990:

1. Remove all liquid hazardous materials from tanks, equipment, sumps and wet floor and store for future batch treatment.

Completed by International Technology Corporation; 2/2/90.

2. Remove all non-contaminated equipment from the area to trash roll-off bin or to secure holding area pending disposition by insurance companies.

Completed by employees of Dublin Multilayer trained and experienced in working in a hazardous wet process area and in the proper use of safety equipment; 2/22/90.

3. Remove collapsed mezzanine to trash roll-off bin.

Completed by employees of Dublin Multilayer; 2/21/90.

4. Remove wet floor and existing containment area to solid hazardous waste bins. Remove contaminated equipment to secure area for future decontamination and storage pending insurance company disposition.

CKC Incorporated placed two hazardous waste bins on site; 2/23/90.

CKC Incorporated, with assistance from employees of Dublin Multilayer, will begin on Monday 2/26/90 and complete within one week.

5. Exposed concrete floor, sumps and contaminated equipment will be hydroblasted and effluent stored for future batch treatment.

Delta Tech Service, Inc. will begin on Thursday 3/1/90 and complete within one week.

6. The wet process area and sumps will be tested for formal closure; if remediation is necessary a plan of action will be submitted for approval by The Alameda County Health Agency.

Steven L. Williams will supervise this process beginning by 3/8/90 and completing within two weeks.

7. All hazardous liquids on site will be batch treated and treated water will be discharged into the sanitary sewer system in accordance with the directives of the Dublin San Ramon Water Services Department. Solid filter cake generated from this process will be stored in bins provided by Chemical Waste Management, Inc. for future off-site metal reclamation.

Decon Environmental Services, Inc. began staging this step on 2/23/90 and will finish within three weeks.

8. All hazardous and non-hazardous solid and liquid waste will be removed on an on-going basis as required to maintain free access to the work site.
9. Dublin Multilayer, Inc will report and document all work done and the disposition of all materials within one week of the completion of the above. March 26, 1990 is our target date.



**DUBLIN MULTILAYER**  
 6341 SCARLETT CT.  
 DUBLIN, CALIFORNIA 94568  
 (415) 829-1956

DATE	INVOICE	AMOUNT
	DEPOSIT FOR	
	SERVICE	
	10 Hours @ 50 <sup>00</sup>	

11-24/232  
 1210 (8)

10662

PAY FIVE HUNDRED DOLLARS DOLLARS

DATE	TO THE ORDER OF	CHECK NO.	ACCTS. PAYABLE	DISCOUNT	CHECK AMOUNT
2-26-90	ALAMEDA COUNTY HEALTH AGENCY DEPT OF ENVIRONMENT	10662			500 -

*Wells Fargo Bank*  
NATIONAL ASSOCIATION  
 MENLO PARK OFFICE  
 735 SANTA CRUZ AVENUE  
 MENLO PARK, CA 94025

*Malvina J. [Signature]*

⑈010662⑈ ⑆121000248⑆0232 077347⑈



**ACTERON CORPORATION**  
**ACTERON METAL FINISHERS**

851 Shasta St., Redwood City, CA 94063  
FAX: (415) 364-9748

Jon KRAIN

HIGH TECHNOLOGY ELECTROPLATING

F A X T R A N S M I T T A L

Date: 2/20/90

Time:

From: FAX # 415-364-9748

Name: JON KRAIN

Jon →

Number of pages (including this sheet):

6

To FAX #: 415/568-3706

Name: RAVI ARULANANTHAM

Company: ALAMEDA COUNTY HEALTH

Subject: PROPOSED WORK PLAN

Note: If any of these fax copies are illegible, or you do not receive the same number of pages as stated above, please

ALAMEDA COUNTY  
HEALTH CARE SERVICES



AGENCY  
DAVID J. KEARS, Agency Director

DEPARTMENT OF ENVIRONMENTAL HEALTH  
Hazardous Materials Program  
80 Swan Way, Rm. 200  
Oakland, CA 94621  
(415) 271-4320

FACSIMILE TRANSMITTAL

TO:

(408) 295-0743  
Fax Phone Number

Floor/Room # \_\_\_\_\_

Name: Steve Frank

Title/Section \_\_\_\_\_

Agency: EMA

Address: \_\_\_\_\_

Phone #: (408) 295-3957

FROM:

(415) 568-3706  
Fax Phone Number

Floor/Room # \_\_\_\_\_

Date: 1/29/90

Time Sent: \_\_\_\_\_

Sender: Gil Wistar

Title/Section \_\_\_\_\_

Phone #: ( )

Number of Pages Including Transmittal Sheet: 2

Special Instructions/Comments:

Copy of a letter sent to Mr. Chan 6/89;  
note highlighted section of text. I have requested  
from the D.A. a copy of the 1987 settlement  
involving a \$10,000 fine, since it was not in our  
files as I'd thought.

# CALIFORNIA HAZARDOUS MATERIAL INCIDENT REPORT

FIVE COPY 9/15/89  
 CHANGE 1   
 DELETE 2

<b>A</b> AGENCY NAME Alameda County	AGENCY ID NO. 01715	AGENCY INCIDENT NO.	AGENCY PHONE NO. (415) 271-4320	OES CONTROL NO. 091724	
<b>B</b> INCIDENT DATE 10/11/90	MO DAY YEAR	TIME NOTIFIED 12/10	TIME COMPLETED on going at time of report	DATE COMPLETED (IF DIFFERENT)	
<b>C</b> INCIDENT ADDRESS/LOCATION 6341 Scarlett Court	CITY/COMMUNITY Dublin	COUNTY Alameda	ZIP 94568		
<b>D</b> WEATHER (CHECK BEST DESCRIPTORS) 1 CLEAR 5 HAIL 8 HIGH WIND 2 RAIN 6 ELECTRICAL STORM 9 OTHER 4 SNOW 7 FOG 0 UNKNOWN		PROPERTY USE (USE CODES ON REVERSE) PROPERTY USE 700 SURROUNDING AREA 500			
ESTIMATED TEMPERATURE 55 (Deg. F)		PROPERTY MANAGEMENT FEDERAL STATE COUNTY CITY <input checked="" type="checkbox"/> PRIVATE UNKNOWN			
<b>E</b> RELEASE FACTORS (CHECK BEST DESCRIPTORS) 11 INTENTIONAL ACT 70 OPERATIONAL DEFICIENCY 21 SUSPICIOUS ACT 71 COLLISION/OVERTURN 30 FAILURE TO CONTROL HAZMAT 80 NATURAL CONDITION 31 ABANDONED 90 UNKNOWN 40 MISUSE OF HAZMAT 95 FIRE/EXPLOSION 50 MECHANICAL FAILURE 98 NO RELEASE 60 DESIGN, CONSTRUCTION, INSTALLATION DEFICIENCY 99 OTHER		TYPE OF EQUIPMENT INVOLVED 10 HEATING SYSTEMS ? 30 AIR CONDITION/REFRIG 77 CHEM PROCESSING EQUIP 78 WASTE RECOVERY EQUIP 96 HAZMAT TRANSFER EQUIP 98 NO EQUIP INVOLVED 99 OTHER		MOBILE PROPERTY TYPE 10 PASSENGER VEH/ROAD 20 FREIGHT VEH/ROAD 30 RAIL TRANSPORT VEH 40 WATER TRANS VESSEL 50 AIR TRANSPORT VEH 60 HEAVY EQUIP/INDUST/AGRI 99 OTHER NA	
<b>F</b> ACTIONS TAKEN (CHECK ONE OR MORE) 31 RESCUE, REMOVE FROM HARM 41 REMOVE HAZARD 47 DECON-AREA 78 SHUT DOWN SYSTEM 32 EXTRICATION, DISENTANGLEMENT 42 ID/ANALYSIS OF HAZMAT 61 CROWD CONTROL 82 SECURE PROPERTY 33 EMERGENCY MEDICAL SERVICES 43 EVACUATION 62 TRAFFIC CONTROL 92 REFER TO PROPER AUTHORITY 35 SEARCH 44 ESTABLISH SAFE AREA 63 NOTIFY OTHER AGENCY 98 NO ACTION TAKEN 36 TRANSPORT 45 MONITOR 64 PROVIDE PUBLIC INFO 99 OTHER put out fire 46 DECON-PERSON/EQUIP 71 INVESTIGATE					
<b>G</b> CHEMICAL OR TRADE NAME (PRINT OR TYPE) Sulfuric Acid		DOT ID NO. 1830	DOT HAZARD CLASS 8	CAS NO. 7664-93-9	
PHYSICAL STATE STORED 1 SOLID 2 LIQUID 3 GAS	PHYSICAL STATE RELEASED 1 SOLID 2 LIQUID 3 GAS	QUANTITY RELEASED 1 lb. 2 gal. 3 cu.ft.	ENVIRONMENTAL CONTAMINATION 1 AIR 2 GROUND 3 WATER 9 OTHER	(USE CODES ON REVERSE) EXTENT OF RELEASE 6,7	
CONTAINER DESCRIPTION 1 FIXED 2 PORTABLE 3 MOBILE		CONTAINER TYPE 1 ARMORED 2 INSULATED 3 PRESSURIZED		CONTAINER CAPACITY 1 lb. 2 gal. 3 cu.ft.	
CHEMICAL OR TRADE NAME (PRINT OR TYPE) Hydrochloric Acid		DOT ID NO. 1789	DOT HAZARD CLASS 8	CAS NO. 7647-01-0	
PHYSICAL STATE STORED 1 SOLID 2 LIQUID 3 GAS	PHYSICAL STATE RELEASED 1 SOLID 2 LIQUID 3 GAS	QUANTITY RELEASED 1 lb. 2 gal. 3 cu.ft.	ENVIRONMENTAL CONTAMINATION 1 AIR 2 GROUND 3 WATER 9 OTHER	(USE CODES ON REVERSE) EXTENT OF RELEASE 6,7	
CONTAINER DESCRIPTION 1 FIXED 2 PORTABLE 3 MOBILE		CONTAINER TYPE 1 ARMORED 2 INSULATED 3 PRESSURIZED		CONTAINER CAPACITY 1 lb. 2 gal. 3 cu.ft.	
CHEMICAL OR TRADE NAME (PRINT OR TYPE) Ammonium bifluoride		DOT ID NO. 2817	DOT HAZARD CLASS	CAS NO.	
PHYSICAL STATE STORED 1 SOLID 2 LIQUID 3 GAS	PHYSICAL STATE RELEASED 1 SOLID 2 LIQUID 3 GAS	QUANTITY RELEASED 1 lb. 2 gal. 3 cu.ft.	ENVIRONMENTAL CONTAMINATION 1 AIR 2 GROUND 3 WATER 9 OTHER	(USE CODES ON REVERSE) EXTENT OF RELEASE 6,7	
CONTAINER DESCRIPTION 1 FIXED 2 PORTABLE 3 MOBILE		CONTAINER TYPE 1 ARMORED 2 INSULATED 3 PRESSURIZED		CONTAINER CAPACITY 1 lb. 2 gal. 3 cu.ft.	
<b>H</b> MORE THAN 3 SUBSTANCES INVOLVED <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO (LIST ADDITIONAL INFORMATION ON REVERSE SIDE)					
<b>I</b> SPECIAL STUDIES LOCAL USE _____ STATE USE _____					
<b>J</b> HAZMAT IDENTIFICATION SOURCES (CHECK BEST DESCRIPTORS) 19 ON-SITE FIRE SERVICES 75 MSDS 29 OFF-SITE FIRE SERVICES 76 PLACARDS/SIGNS 40 ON-SITE NON-FIRE SERVICES 77 SHIPPING PAPERS 60 OFF-SITE NON-FIRE SERVICES 85 CONTRACT INFO SOURCES 54 CHEMIST 86 COMPUTER SOFTWARE 58 TOX CENTER 99 OTHER flag, hat, Plan of Business 71 DOT MANUAL		HAZMAT CASUALTIES NO. OF DECONTAMINATED 3 NO. OF INJURIES NO. OF FATALITIES RESPONDING AGENCY PERSONNEL Dublin fire Dept. OTHERS			
VEHICLE MAKE/YEAR	VEHICLE LICENSE NO.	STATE	VEHICLE ID NO. (VIN)	ICC/DOT/PUC NO.	COMPANY NAME
<b>L</b> REPORTING OFFICER NAME/ID NO. (PRINT OR TYPE) Katherine Chesick			DATE 1/16/90	COMMENTS ON BACK? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	

**CODES**

PROPERTY USE and SURROUNDING AREA TYPE			EXTENT OF RELEASE
100 Public assembly	700 Manufacturing	946 Lake/Pond/River	1 Confined to vehicle/equipment
200 Educational	762 Hazmat chem mfg	950 Railroad	3 Confined to room of origin
300 Health care	767 Petroleum refinery	961 Freeway	4 Confined to floor of origin
400 Residential	800 Storage	962 County/City road	5 Confined to structure of origin
500 Mercantile, Business	936 Vacant lot	963 Private road	6 Confined to property use of origin
600 Industrial, Utility	941 Open sea	099 Other - explain in comments section	7 Release beyond property use of origin
650 Agricultural	942 Harbor/Port		8 NO RELEASE
			9 Other - explain in comments
CONTAINER TYPE		LEVEL OF CONTAINER	CONTAINER MATERIAL
01 Tank	08 Sump/Pit/Pond	11 Ground Level	1 Iron and iron alloys
02 Drum/Barrel	09 Well	10 Above Ground	2 Aluminum and aluminum alloys
03 Cylinder	10 Machinery/Processing Equipment	40 Below Ground	3 Copper and copper alloys
04 Can/Bottle	11 Pipe		4 Plastic (includes fiberglass), rigid
05 Carboy	18 NO CONTAINER		5 Plastic, flexible
06 Boxes/Cartons	19 Other - explain in comments section		6 Wood, paper, and cellulose products
07 Bags			7 Glass
			8 NO CONTAINER
			9 Other - explain in comments
			0 Unknown

**COMMENTS:**

Fire in plating shop area of a circuit board prototype ~~is~~ manufacturing business (Dublin Multilayer Inc., 6341 Scartlett Court). At time of response, the cause of the fire was unknown and the amounts and types of any chemicals involved were ~~also~~ <sup>is</sup> unknown. However there ~~was~~ <sup>is</sup> a complete listing of chemicals used at the business along with a floor plan showing storage/use locations. Battalion Chief T.J. Welch of Dublin Fire Dept. the incident commander, has a chemical list. At time of this report writing (1/16/90, 11:30am) the fire was still going although IT and DFD were on scene cleaning up and controlling the fire.

**IMPORTANT INSTRUCTIONS**

- Incidents that involve the following shall not be reported:
1. Petroleum spills of less than 42 gallons from vehicular fuel tanks.
  2. Sewage overflows.
  3. Leaks in low-pressure fuel lines to residential properties.

Fish and Game had been notified. Water run off was bermed to prevent entry into the storm sewer; some apparently had entered the sewer however. Businesses east of the fire were evacuated.

**CHANGE:** If the information on a previously submitted form needs to be changed mark the CHANGE box and submit form with the correct information.

**DELETE:** If a certain report needs to be deleted from the database mark the DELETE box, complete sections A, B, C, and L, and submit form.

**NOTE:** IF ALL SECTIONS CONTAINING SHADED BOXES  ARE NOT COMPLETED, THE FORM WILL BE RETURNED FOR COMPLETION

**SECTION**

- A OES Control No. is assigned when making phone notification to OES Warning Center. [Phone 1-800-852-7550 or (916) 427-4341].
- B Enter the date (month, day and year), notification and completion time of the incident (use 2400 hr clock).
- C Enter completion date, if different from incident date.
- D Check the appropriate weather descriptor(s) at the time of the incident and indicate the approximate temperature in ° F.
- E Enter property use and surrounding area code(s) as appropriate. Indicate the agency responsible for property management.
- F Check the item(s) that describe(s) the cause of the incident, the type of equipment involved in the incident, and the mobile property type, if any.
- G Check the item(s) that indicate(s) which action(s) you took as a responder to the incident.
- H List the chemical or the trade name(s) of the hazardous material(s) involved in the incident. Include information required in the boxes. Check the information in the box(es) that describe(s) the hazardous material. Use the appropriate codes for Extent of Release, Container Type, Level of Container, and Container Material.
- I If more than three (3) hazardous materials were involved check YES and enter the information in the comments section.
- J This section is used for special studies. The first three numbers are for your agency's use; the last three are for state use. Leave blank unless otherwise directed.
- K Check item(s) describing how the material was identified. Enter number of hazardous material casualties suffered by responding agency personnel and others (including the public) in spaces provided.
- L If vehicle/mobile property was involved in the incident, enter information about that vehicle.
- M Print your full name or your ID number and enter the date of report. Mark Yes or No to indicate whether there are additional comments.

(415) 829-2333



DUBLIN SAN RAMON SERVICES DISTRICT  
PRETREATMENT PROGRAM  
WASTEWATER DISCHARGE PERMIT

# 3672-101

IN ACCORDANCE WITH ALL TERMS AND CONDITIONS OF THE:

X D.S.R.S.D. CODE (CHAPTER 7 ARTICLE 3)

       CITY OF PLEASANTON CODE (CHAPTER 8 ARTICLES 5 & 7)

AND ALSO WITH ANY APPLICABLE PROVISION OF FEDERAL OR STATE  
LAWS OR REGULATIONS;

PERMISSION IS HEREBY GRANTED TO:

Dublin Multilayer, Inc.

Name of Company

6341 Scarlett Court, Dublin, CA 94568

Mailing Address

CLASSIFIED BY S.I.C. NO. 3672 (printed circuit boards)

FOR THE CONTRIBUTION OF treated process wastewater INTO

THE DSRSD SEWER LINES AT:

6341 Scarlett Court, Dublin, CA

Address of Discharger

EFFECTIVE: 1 October 1989

EXPIRES ON: 30 September 1991

John Chan

PRINT NAME OF PERMITTEE

*Robert D. Whitley*  
DISTRICT ENGINEER

*John Chan*  
SIGNATURE OF PERMITTEE

ENVIRONMENTAL MANAGEMENT ASSOCIATES

12 South First Street, Suite 903 - San Jose - California 95113  
Telephone (408) 295-3957 FAX (408) 295-0743

*R*

6/28/89

*NSW*  
AREA SQ FT: 10,000  
# of Materials: 13  
GALS: 1805  
lbs: 1000

Mr. Gil Wistar  
ALAMEDA COUNTY HEALTH AGENCY  
Division Of Hazardous Materials  
80 Swan Way Rm 200, Oakland, CA 94621

Dear Gil:

*6341 Scarlett Ct.  
Dublin, CA 94568*

Here are the copies of the Hazardous Waste and Hazardous Materials Inventory Statements for Dublin Multilayer that you requested of us. I apologize for the delay in getting them to you. If you have any further question or requisitions please call.

Thank You,  
Environmental Management Associates

Kort Jackson

*Kort W. Jackson*

cc: File

ALAMEDA COUNTY  
DEPT. OF ENVIRONMENTAL HEALTH  
HAZARDOUS MATERIALS

*6/29*

**ENVIRONMENTAL  
MANAGEMENT  
ASSOCIATES**

**HWIS**  
**HAZARDOUS WASTE  
INVENTORY STATEMENT**

**COMPANY NAME:** DUBLIN MULTILAYER Date 4/27/89

**ADDRESS:** 3641 Scarlett Court Dublin, CA Page 1 of 1

HAZ. CLASS	UN/NA #	DOT SHIPPING NAME	CHEMICAL CONSTITUENTS AND PERCENTAGE BY VOLUME	(L)(S)(G)	NFPA HAZARD ID NUMBERS				STATE WASTE ID NUMBER	EPA WASTE ID NUMBER	RQ VALUE	MAX QTY ON SITE	QTY GEN PER MONTH	DATE OF LAST PROFILE ANALYSIS
					H	F	R	S/N						
ORM-E	9109	RQ Cupric Sulfate Waste (417a)	Copper Sulfate 35-40% NaOH 50% - 10-15% Formaldehyde 10-15% D-Tartaric Acid 5-10%	L	-	-	-	-	121	D002	25#	110 gal.	35 gal.	
COR-L	1760	Waste Corrosive Liquid n.o.s. (417b)	NaOH 10-15% Tartaric Salts 10-15% Sodium Acetate 1-5% Sodium Carbonate 1-5%	L	-	-	-	-	123	D002	1000#	110 gal	35 gal.	
COR-S	9189	RQ Hazardous Waste Solid n.o.s.	Treated Plating Sludge pH 10 Water 72%; Copper 4%	S	-	-	-	-	171	F006	100			
COR-L	2672	Waste Ammonium Hydroxide Solution	Ammonium Hydroxide 10-20% Ammonium Chloride 13-20% Ammonium Carbonate 1-3%	L	-	-	-	-	123	D002	1000	385 ga	385 gal.	
												605		



**ENVIRONMENTAL  
MANAGEMENT  
ASSOCIATES**

**H M I S**  
**HAZARDOUS MATERIALS  
INVENTORY STATEMENT**

COMPANY NAME: DUBLIN MULTILAYER INC. Date 4/27/89

ADDRESS: 3641 Scarlett Court Dublin, CA Page 1 of 1

HAZARD CLASS	UN/NA NUMBER	TRADE NAME OR CHEMICAL NAME	CHEMICAL CONSTITUENTS AND PERCENTAGE BY VOLUME	M S D S	(L) (S) (G)	NFPA HAZARD ID NUMBERS				U G R N D	MAX QTY ON SITE	QTY USED PER MONTH	THRESHOLD PLANNING QUANTITY (SARA Title III)	REGULATORY CROSS-REFERENCE
						H	F	R	S/N					
IRR-L	1693	Endura-Plate Pre-Activator 202 (Olin Hunt)	Sodium Chloride -20-25%	X	L	-	-	-	-	N	55 gal.		N/A	N/A
IRR-L	1693	Endura-Plate Electroless Copper #427	Non Regulated Proprietary Material "Quadrol"	X	L	-	-	-	-	N				
CORR-L	1824	Liquid Caustic Soda	NaOH 50%	X	L	3	0	1	-	N	210 gal.	210 gal.		
CORR-L	2672	High Speed AC-CU-Guard Replenisher	Ammonium Hydroxide -14-25%	X	L	1	0	0	-	N	550 gal.	550 gal.		
ORM-E	9125	Ferrous Sulfate		X	S	-	-	-	-	N	1000*	800*		
ORM-E COR-L	9085 1789	High Speed Finishing Solution	Ammonium Chloride HCl Thiourea	X	L	3	0	0	-	N	55 gal.	20 gal.		
COR-L	1789	Hydrochloric Acid		X	L	3	0	0	-	N	55 gal.			
OXY	2041	Hydrogen Peroxide		X	L	2	0	1	OXY	N	55 gal.	10 gal.		
OXY	2031	Nitric Acid		X	S	3	0	0	OXY	N	90*	90*		
COR-L	1830	Sulfuric Acid		X	L	3	0	2	-	N	110 gal.	110 gal.		
IRR-L	1760	Oxit	Acid Nitrates 5% Additives 1% Water 94%	X	L	-	-	-	-	N	55 gal.	10 gal.		
COR-L	1760	SNP Solder Stripper	Nitric Acid	X	L	3	0	0	-	N	55 gal.	25 gal.		

ALAMEDA COUNTY  
HEALTH CARE SERVICES

AGENCY

DAVID J. KEARS, Agency Director



Certified Mailer # P 833 981 452

June 14, 1989

Mr. John Chan  
Dublin Multilayer  
6341 Scarlett Ct.  
Dublin, CA 94568

DEPARTMENT OF ENVIRONMENTAL HEALTH  
Hazardous Materials Program  
80 Swan Way, Rm. 200  
Oakland, CA 94621  
(415) 271-4320

NOTICE OF VIOLATION

Dear Mr. Chan:

As you're aware, every California business that handles hazardous materials and wastes in excess of specified thresholds must file a business plan according to the provisions of Chapter 6.95 of the California Health and Safety Code. The Alameda County Department of Environmental Health, Hazardous Materials Division, is the implementing agency for business plans in Alameda County. On March 10, 1989, Gil Wistar of my staff notified you by telephone that Dublin Multilayer had not submitted a hazardous materials/wastes inventory as required by state law. At that time, you stated that this information would be submitted by March 24. Soon afterwards, Steve Frank of EMA Consultants contacted Mr. Wistar, indicating that he was preparing the inventory and that he'd send it to this office by the first week of April 1989. As of the date of this letter, we have not received the required hazardous material and hazardous waste inventories.

Please submit your chemical inventory to this office as soon as possible, but not later than June 23, 1989, to complete your business plan filing. According to Sec. 25514(b) of the California Health and Safety Code, any company that fails to provide any part of a business plan after being given reasonable notice is liable for a civil penalty of up to \$5,000 for every day in which the violation continues.

If you have any question about this letter, please contact Gil Wistar, Hazardous Materials Specialist, at 271-4320.

Sincerely,

Rafat A. Shahid, Chief  
Hazardous Materials Division

c: Steve Frank, EMA  
Gil Jensen, Alameda County District Attorney, Consumer and  
Environmental Protection Division  
files

P 833 981 452

RECEIPT FOR CERTIFIED MAIL

NO INSURANCE COVERAGE PROVIDED  
NOT FOR INTERNATIONAL MAIL  
(See Reverse)

Sent to <i>Mr. John Chan</i>	
Street and No.	
P.O., State and ZIP Code	
Postage	\$
Certified Fee	
Special Delivery Fee	
Restricted Delivery Fee	
Return Receipt showing to whom and Date Delivered	
Return Receipt showing to whom, Date, and Address of Delivery	
TOTAL Postage and Fees	\$
Postmark or Date	

June 1985

Put your address in "RETURN TO" space on the reverse side. Failure to do so will prevent this card from being returned to you. The return receipt fee will provide you the name of the person delivered to and the date of delivery. For additional fees the following services are available. Consult postmaster for fees and check box(es) for additional service(s) requested.

1.  Show to whom delivered, date, and addressee's address: (Extra charge)      2.  Restricted Delivery (Extra charge)

3. Article Addressed to: <i>Mr. John Chan Dublin Multilayer 6341 Scarlett Ct. Dublin, CA 94568</i>	4. Article Number <i>P 833 981 452</i>
5. Signature - Address <i>Shina Dent</i>	Type of Service: <input type="checkbox"/> Registered <input type="checkbox"/> Insured <input checked="" type="checkbox"/> Certified <input type="checkbox"/> COD <input type="checkbox"/> Express Mail <input type="checkbox"/> Return Receipt for Merchandise
6. Signature - Agent <i>Shina Dent</i>	Always obtain signature of addressee or agent and DATE DELIVERED.
7. Date of Delivery <i>6-21-89</i>	8. Addressee's Address (ONLY if requested and fee paid)



Certified Mailer # P 833 981 452

June 14, 1989

DEPARTMENT OF ENVIRONMENTAL HEALTH  
Hazardous Materials Program  
30 Swan Way, Rm. 200  
Oakland, CA 94612  
415/ 271-4320

Mr. John Chan  
Dublin Multilayer  
6341 Scarlett Ct.  
Dublin, CA 94568

NOTICE OF VIOLATION


Dear Mr. Chan:

As you're aware, every California business that handles hazardous materials and wastes in excess of specified thresholds must file a business plan according to the provisions of Chapter 6.95 of the California Health and Safety Code. The Alameda County Department of Environmental Health, Hazardous Materials Division, is the implementing agency for business plans in Alameda County. On March 10, 1989, Gil Wistar of my staff notified you by telephone that Dublin Multilayer had not submitted a hazardous materials/wastes inventory as required by state law. At that time, you stated that this information would be submitted by March 24. Soon afterwards, Steve Frank of EMA Consultants contacted Mr. Wistar, indicating that he was preparing the inventory and that he'd send it to this office by the first week of April 1989. As of the date of this letter, we have not received the required hazardous material and hazardous waste inventories.

Please submit your chemical inventory to this office as soon as possible, but not later than June 23, 1989, to complete your business plan filing. According to Sec. 25514(b) of the California Health and Safety Code, any company that fails to provide any part of a business plan after being given reasonable notice is liable for a civil penalty of up to \$5,000 for every day in which the violation continues.

If you have any question about this letter, please contact Gil Wistar, Hazardous Materials Specialist, at 271-4320.

Sincerely,

  
Rafat A. Shahid, Chief  
Hazardous Materials Division

c: Steve Frank, EMA  
Gil Jensen, Alameda County District Attorney, Consumer and  
Environmental Protection Division  
files

ALAMEDA COUNTY  
HEALTH CARE SERVICES

DAVID J. KEARS AGENCY  
Agency Director



Department of Environmental Health  
Hazardous Materials Division  
80 Swan Way, Room 200  
Oakland, CA 94621

FACSIMILE TRANSMITTAL

TO:

408 295-0743  
Fax Phone Number

Floor/Room # 1209

Name: Steve Frank  
Title/Section

Agency: EMA

Address: 12 South 1st St. San Jose 95113

Phone #: (408) 295-3957

FROM:

415 568-3706  
Fax Phone Number

Floor/Room # 200

Date: 3/16/89

Time Sent: 4:30 p.m.

Sender: Gil Wistar  
Title/Section Haz. Mat. Spec.

Phone #: (415) 271-4320

Number of Pages Including Transmittal Sheet: 3

Special Instructions/Comments:

Hazardous material/waste inventory sheets for  
Dublin multilayer - to be ~~now~~ returned  
to this office by 3/31/89

ALAMEDA COUNTY HEALTH CARE SERVICES AGENCY  
MEMORANDUM

TO File FROM Sehnam DATE 10/26/87  
SUBJECT Problem Multi Layer - Discussion w/ M. Princeville  
of AEC Construction

- ① Submit 3rd party sample collection & analysis of skin tissue sediment
- ② Submit construction plan w/d in letter of 9/30

# Firm to pay \$10,000 in dump case

By Mike Myslinski  
Staff writer

DUBLIN — A local electronics company has agreed to pay \$10,000 in civil fines to settle a lawsuit stemming from its alleged violations of state and city hazardous waste disposal laws over a three-year period.

But the company, Dublin Multilayer Inc., did not admit any wrongdoing in the settlement approved Wednesday by Alameda County Superior Court Judge Mark Eaton.

The agreement settles a lawsuit filed by the consumer and environmental protection division of the Alameda County district attorney's office.

It comes three days after an accidental leak of iron and copper-laced water from the plant into a local storm drain — and just after the company was taken off a one-year probation period instituted by the Dublin San Ramon Services District.

The settlement forbids the firm from "violating the provisions of the California Hazardous Waste Control Act and from discharging or causing to be discharged into the waters of the state . . . or any municipal sewerage system any hazardous substance or waste in excess of those permitted by law."

Both John Chan, the company's executive vice president, and Gil Jensen, the county prosecutor on the case, called the settlement a fair one.

"We felt that was appropriate," Jensen said.

He said the alleged violations between 1983 and 1986 involved the storage and disposal of wastes from the plant at 6341 Scarlett Court. Far greater fines could have been sought, but Jensen said \$10,000 was adequate because Dublin Multilayer has spent about \$200,000 on waste-control equipment and has shown it wants to comply with all laws.

"The cooperation has been forthcoming," he said.

Chan said the \$200,000 went for an on-site waste water treatment plant that will assure wastes released into the city sewers are not far below legal thresholds.

"We have spent a great deal of money," he said of the firm's good intentions.

He said the company, which makes printed circuit boards for the semiconductor industry, employs 27 people and had about \$2 million in sales last year.

Chan said a spill detected Sunday by a passer-by was caused by a broken hose in the firm's water treatment plant. He said company tests showed only non-toxic, iron-laced ferrous sulfate mixed with the water flowed into a parking lot storm drain.

But new test results show otherwise.

A sample of the leaked water showed it contained 5.6 parts per million of copper, said Lowell Miller, an Alameda County senior hazardous materials specialist.

He said the tests did not show any traces of arsenic, lead or nickel.

But Miller didn't know if the 5.6 ppm level of copper exceeded state laws, and state and local officials could not be reached late Wednesday afternoon.

Miller and other officials have doubted the spill posed a health threat, but Miller said his investigation is continuing.

This month, Dublin Multilayer was taken off a one-year probation put in place by the Dublin San Ramon Services District, said Bob Whitley, the district's engineer.

He said the probation stemmed from the company's disposal in the sewer system of wastes laced with illegal amounts of copper and lead.

But district tests showed the firm has had an excellent disposal record during its probation, Whitley said.

DAILY BUSINESS, P. 10, 07/24/17

# Iron-laced water leaks into Dublin drain

By Jaxon Van Derbeken  
Staff writer

DUBLIN — Water laced with iron and possibly heavy metals overflowed into a storm drain from a Dublin electronics firm's treatment tank Sunday, a county hazardous materials official said.

Firefighters discovered brown water streaming from under a door at Dublin Multilayer's plant at 6341 Scarlett Court shortly after 11 a.m.

The polluted water flowed at 2 gallons per minute into a parking lot drain until the main water valve was shut off, said Robert Eaton, a Dublin San Ramon Services District

firefighter.

The water contained mostly iron but also may contain traces of arsenic, nickel and copper, said Alameda County senior hazardous materials specialist Lowell Miller. Such toxic heavy metals cannot legally be discharged into storm drains, he said.

Dublin Multilayer Inc., which manufactures printed circuit boards for electronic components, could be fined up to \$25,000 for the discharge, Miller said.

But Miller said more tests are needed to determine exactly what was in the water. "The real question

is: How long had it been going?"

A malfunctioning pump caused the tank to overflow.

Ed Wong, president of Multilayer, dismissed any hazard, describing the discharge as "water and junk." He told firefighters the leak may have started Saturday night.

"We don't know what we're dealing with here, but I don't consider it an imminent hazard," Miller said. He said that since the storm drains are dry now, the brown sludge will likely evaporate and not travel very far.

Miller said that storm drain maps

See Leak, back of section

## Leak

Continued from page 1

where not available Sunday, so officials will check the drain system today to see how far the water traveled. Miller added that metals usually get trapped in soil and don't seep into ground water supplies.

The Zone 7 water district and the state Department of Fish and Game will be notified, Miller said.

Dublin Multilayer violated the le-

gal limit for dumping copper and lead in the sewage system for more than three years until March 1986, before installing \$200,000 worth of new equipment to treat its effluent.

In another incident last year, the company also was ordered to move hazardous waste stored outside in barrels, a violation of local hazardous substance control laws.



1 JOHN J. MEEHAN  
2 District Attorney  
3 County of Alameda  
4 GILBERT A. JENSEN  
5 Senior Deputy District Attorney  
6 Consumer & Environmental Protection Division  
7 24405 Amador Street  
8 Hayward, CA 94544  
9 (415) 670-5150

**ENDORSED  
FILED**

JUL 20 1987

RENE C. DAVIDSON, County Clerk  
By Cathy Green, Deputy

6 Attorneys for Plaintiff

8 SUPERIOR COURT OF THE STATE OF CALIFORNIA

9 COUNTY OF ALAMEDA

10 THE PEOPLE OF THE STATE OF CALIFORNIA, )  
11 )  
12 Plaintiff, )  
13 v. )  
14 DUBLIN MULTILAYER, INC., a California )  
15 Corporation, )  
16 Defendant. )

No. H126432-2

CONSENT JUDGMENT

17 It appearing to the Court that the Court has jurisdiction of the  
18 subject matter herein and the parties hereto, that plaintiff has filed a  
19 Complaint; that defendants have been served with a copy of the Complaint and  
20 have appeared; that plaintiff has appeared through its attorney John J. Meehan,  
21 District Attorney by Gilbert A. Jensen, Senior Deputy District Attorney and  
22 defendant DUBLIN MULTILAYER, INC., appearing through its attorney Steven V.  
23 Nelson, Esq., and that plaintiff and defendants have stipulated to entry of this  
24 Judgment without the taking of proof, without trial or adjudication of any facts  
25 or issues of law herein, and without this Judgment constituting evidence or  
26 admission by defendants of any act or thing or of any allegations of the  
27 Complaint, now therefore:

28 //

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31

IT IS ORDERED, ADJUDGED AND DECREED, that defendants, their agents, officers, employees, and all persons acting in concert with defendant, with actual or constructive notice of this Judgment, are ordered restrained and enjoined as provided for in the Stipulation attached hereto and incorporated herein.

Dated: JUL 20 1987

**MARK L. EATON**

---

Judge of the Superior Court

1 JOHN J. MEEHAN  
2 District Attorney  
3 County of Alameda  
4 GILBERT A. JENSEN  
5 Senior Deputy District Attorney  
6 Consumer & Environmental Protection Division  
7 24405 Amador Street  
8 Hayward, CA 94544  
9 (415) 670-5150

**ENDORSED  
FILED**

JUL 20 1997

RENE C. DAVIDSON, County Clerk  
By Cathy Green, Deputy

Attorneys for Plaintiff

SUPERIOR COURT OF THE STATE OF CALIFORNIA  
COUNTY OF ALAMEDA

10 THE PEOPLE OF THE STATE OF CALIFORNIA, )  
11 )  
12 Plaintiff, )  
13 v. )  
14 DUBLIN MULTILAYER, INC., a California )  
15 Corporation, )  
16 Defendant. )

No. H126432-2

STIPULATION FOR ENTRY  
OF CONSENT JUDGMENT

17 Plaintiff, THE PEOPLE OF THE STATE OF CALIFORNIA, appearing through  
18 its attorneys, John J. Meehan, District Attorney of the County of Alameda, by  
19 Gilbert A. Jensen, Senior Deputy District, and defendant DUBLIN MULTILAYER,  
20 INC., appearing through its attorney, Steven Nelson, esq., without the taking of  
21 proof, and without a trial and adjudication of any facts or law herein, hereby  
22 stipulate in compromise and settlement of this action that:

23 I. This Consent Judgment shall settle and conclude for all time  
24 all claims, whether known or unknown, between plaintiff and defendant arising  
25 out of the acts, failures to act and/or occurrences alleged, and for the period  
26 of time alleged, in the complaint on file herein.

27 II. Defendant hereby acknowledges that the Superior Court, County  
28 of Alameda, has personal jurisdiction of the defendant.

1 III. The Superior Court of the State of California, County of  
2 Alameda, has jurisdiction of the subject matter hereto.

3 IV. Defendant, and its agents, employees and representatives, and  
4 any and all of them, are permanently restrained and enjoined from violating the  
5 provisions of the California Hazardous Waste Control Act and from discharging or  
6 causing to be discharged into the waters of the State of California, any  
7 tributary leading thereto or any municipal sewerage system, any hazardous  
8 substance or waste in excess of those permitted by law.

9 V. Defendant will pay to plaintiff, The People of the State of  
10 California, through John J. Meehan, District Attorney of the County of Alameda,  
11 costs and civil penalties, in the total amount of Ten Thousand Dollars  
12 (10,000.00), One Thousand Dollars (\$1,000.00) of said sum shall be payable to  
13 the City of Dublin and Four Thousand Dollars (\$4,000.00) of said sum shall be  
14 payable to the Treasurer of Alameda County as reimbursement for the costs of  
15 this action and Five Thousand Dollars (\$5,000.00) shall be payable to the  
16 Treasurer of Alameda County in payment of civil penalties stipulated herein.  
17 Defendant will pay said Ten Thousand Dollars (\$10,000.00), payable in ten (10)  
18 equal installments of One Thousand Dollars (\$1,000.00) by check or money order  
19 first made payable to the City of Dublin and followed by nine (9) installments  
20 made payable to the Treasurer of Alameda County, commencing fifteen (15) days  
21 from the date of the issuance of a judgment herein and continuing on the 30th of  
22 each successive month thereafter for ten (10) months. All payments shall be  
23 sent to the District Attorneys' Office, Consumer and Environmental Protection  
24 Division for disbursement. Said installments shall bear no interest unless and  
25 until defendant defaults on any of such installments when they become due. Upon  
26 such event, interest shall immediately accrue from the original date of the

27 //

28 //


1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28

Judgment issued pursuant to this stipulation until full payment of all of said installments, at the rate of ten percent per annum, and the entire balance remaining to be paid on said date shall become due and payable forthwith.

VI. Judgment may be entered by the Court in this action, pursuant to this stipulation, on request of any party without formal notice to the other parties.


Dated: July 15, 1987

JOHN J. MEEHAN  
District Attorney

By:   
\_\_\_\_\_  
Gilbert A. Jensen  
Senior Deputy District  
Attorney


Dated: July 4, 1987

DUBLIN MULTILAYER, INC.

By:   
\_\_\_\_\_  
John Chan, Vice President

Dated: July 8, 1987

NELSON & WARNLOF

By:   
\_\_\_\_\_  
Steven V. Nelson  
Attorney for Defendant  
Dublin Multilayer, Inc.



October 21, 1987

RECEIVED  
NOV 7 1987

Mr. Norm Goranson, Senior Hazardous Materials Specialist  
Alameda County Health Services Agency, Environmental Division  
470 Twenty-Seventh Street  
Oakland, CA 94612

RE: Dublin Multilayer Spill Report (July 19, 1987)

ADDENDUM FOR STORM DRAIN SAMPLE TAKEN JULY 20, 1987

- 1) On Sunday, July 19, 1987, there had been no recent rain and the storm drains were dry. There continued to be no rain July 19th through October 21, 1987.
- 2) The small puddle in the storm drain, which was sampled on the morning of July 20, was a remnant of what entered the storm drain on Sunday, July 19, 1987.
- 3) The water released in the spill traveled about 250 feet over blacktop, around the building, before reaching the storm drain.
- 4) Most of the rust (metal hydroxides) in the water were observed to settle out onto the blacktop before they reached the storm drain. This material was removed and vacuumed into a tank truck by Erickson Inc. on Sunday evening, July 19, 1987.
- 5) Sediment present in the storm drain became stirred up while the storm drain sample was being taken. The sediment present in the original storm drain sample consisted of small hairs, sand, gravel, insect parts, and plant material.
- 6) The original sample was stirred and the gravel allowed to settle for a few seconds before a 10 ml bottle was filled with the original sample. The 10 ml bottle which contained almost no gravel was sent to an outside laboratory for analysis.
- 7) The laboratory analysis was done according to EPA Methods and showed no violation of DSRSD Wastewater Discharge Provisions.

Sincerely,

Karl A. Sauter  
QC Manager

cc: Lydia Huang, Regional Water Quality Control Board  
Dwight Hoenig, Department of Health Services  
Gil Jensen, Alameda County District Attorney  
Michael Princevalle, Applied Earth Consultants Inc.  
John Mauck, Dublin San Ramon Services District (DSRSD)

ALAMEDA COUNTY  
HEALTH CARE SERVICES



DAVID KEARS AGENCY  
XXXXXXXXXXXX MICHAEL FEATY, Agency Director

Certified Mailer #P 241 310 275

470-27th Street, Third Floor  
Oakland, California 94612  
(415) 874-7237

September 30, 1987

John Chan, President  
Dublin Multilayer, Inc.  
6341 Scarlett Court  
Dublin, CA 94568

\*\*\* NOTICE OF VIOLATION \*\*\*

Dear Mr. Chan:

On July 19, 1987, a spill of water and sludge mixture from a waste water treatment system at your facility occurred. The spilled material also went off-site into a nearby storm drain.

A sample of this material was taken by Lowell Miller and analysis indicated that total chromium, copper and lead levels exceeded the Total Threshold Limit Concentration (TTLC) listed in Title 22 of the California Administrative Code (CAC). This is a violation of the California Health and Safety Code, Chapter 6.5, Section 25189.5.

According to Mr. Karl Santer, Quality Control Manager of Dublin Multilayer, Inc., the spilled material in the parking lot area was cleaned up on July 19, 1987 by Erickson, Inc. However, our file shows no documentation regarding the extent of contamination that occurred in the storm drain and what measures have been taken to clean up this area.


In accordance with CAC, Title 22, Division 4, Chapter 30, Sec. 66328, a Plan of Correction must be submitted to this office within 30 days of the receipt of this letter. The plan should specify the actions to be taken to address the above violation and expected dates of completion. It is recommended that you expedite clean up of the storm drain in order to minimize further contamination should wet weather occur.

John Chan, President  
Dublin Multilayer, Inc.  
6341 Scarlett Court  
Dublin, CA 94568  
Page 2

Your attention is directed to Sections 25184, 25189 and 25191 of the California Health and Safety Code which provides for civil and criminal penalties of up to \$25,000 per day, per violation for violation of its regulations.

If you have any questions concerning this matter, please contact Lowell Miller, Senior Hazardous Materials Specialist at 874-7237.

Sincerely,



Rafat A. Shahid, Chief  
Hazardous Materials Division

RAS:mam

cc: Lydia Huang, RWQCB  
Dwight Hoenig, DOHS  
Gil Jensen, Alameda County District Attorney, Consumer and  
Environmental Protection Agency



PS Form 3871, July 1982

**SENDER: Complete items 1, 2, 3 and 4.**


Put your address in the "RETURN TO" space on the reverse side. Failure to do this will prevent this card from being returned to you. The return receipt fee will provide you the name of the person delivered to and the date of delivery. For additional fees the following services are available. Consult postmaster for fees and check box(es) for service(s) requested.

- Show to whom, date and address of delivery.
- Restricted Delivery.

3. Article Addressed to:  
**JOHN CHAN, PRES  
 DUBLIN MULTILAYER INC  
 6341 SCARLETT CT  
 DUBLIN CA 94568**

4. Type of Service:      Article Number  
 Registered       Insured  
 Certified       COD      **P241 310 275**  
 Express Mail

Always obtain signature of addressee or agent and **DATE DELIVERED.**

5. Signature - Addressee  
 X 

6. Signature - Agent  
 X

7. Date of Delivery  
**10-5-87**

8. Addressee's Address (ONLY if requested and fee paid)

DOMESTIC RETURN RECEIPT

P 241 310 275

**RECEIPT FOR CERTIFIED MAIL**

NO INSURANCE COVERAGE PROVIDED  
NOT FOR INTERNATIONAL MAIL

(See Reverse)

\* U.S.G.P.O. 1984-446-014

Sent to <b>JOHN CHAN DUBLIN MULTILAYER</b>	
Street and No. <b>6341 SCARLETT CT</b>	
P.O., State and ZIP Code <b>DUBLIN CA 94568</b>	
Postage	\$
Certified Fee	
Special Delivery Fee	
Restricted Delivery Fee	
Return Receipt Showing to whom and Date Delivered	
Return receipt showing to whom, Date, and Address of Delivery	
TOTAL Postage and Fees	\$
Postmark or Date <b>OCT. 1, 1987</b>	

PS Form 3800, Feb. 1982

ALAMEDA COUNTY  
HEALTH CARE SERVICES



David J. Kears, AGENCY  
~~XXXXXXXXXX~~ Agency Director

*LAP -  
LJM Dublin Multilayer  
94568*

To: Emile Kattan  
Dublin San Ramon Services District  
7051 Dublin Blvd  
Dublin, CA 94568

470-27th Street, Third Floor  
Oakland, California 94612  
(415) 874-7237

From: Lowell Miller  
Sr. Hazardous Material Specialist  
Alameda County Department of Health

Subject: Spill from Dublin Multilayer, 6341 Scarlett Ct.  
Dublin, CA 94568

Date: July 23, 1987

I have enclosed for your information our spill report concerning the above mentioned incident. Also attached is a copy of our laboratory results.

Sample LJM 71987-1 was taken from a puddle in the parking lot where the overflow occurred. Sample LJM 71987-2 was also taken from the parking lot but divided into two portions at our laboratory, filtered liquid and filtered sludge.

Please determine whether these concentrations violate any of your permit conditions and take appropriate action. You may also wish to investigate the placement of the hose in the wastewater treatment tank for any potential cross-connection or backflow device code violations.

cc: Rafat Shahid, Chief  
Hazardous Materials Division

Gil Jensen, Senior District Attorney  
Consumer and Environmental Protection Division

DATALAB, INC.  
2171 Del Franco St.  
SAN JOSE, CA 95131  
(408) 943-1888

RECEIVED  
AUG 5 1987  
DUBLIN MULTILAYER, INC.


Lab. Report #10880-1  
August 04, 1987

Dublin Multilayer  
Attn: John Chan  
6341 Scarlet Court  
Dublin, CA 94568


Subject: Chemical Analysis of Effluent  
Sample Received: 07/20/1987 17:36:03

Storm Drain Sample	Found,
Chromium	0.20 mg/l
Copper	0.90 mg/l
Nickel	0.17 mg/l
Lead	0.36 mg/l
Arsenic	0.80 mg/l

Datalab, Inc.

  
Holly Ham

HH:hh



DATE: 7/21/87  
LOG NO.: 4988  
DATE SAMPLED: 7/20/87  
DATE RECEIVED: 7/20/87


CUSTOMER: Dublin Multilayer, Inc.  
REQUESTER: John Chan  
PROJECT: Tank Overflow

RECEIVED  
JUL 22 1987  
DUBLIN MULTILAYER, INC.

Sample Type: Water

<u>Method and Constituent</u>	<u>Units</u>	<u>Detection Limit</u>	<u>Rinse Water</u>
			<u>Concentration</u>
EPA Method 7061:			
As	mg/l	0.0005	0.0026
EPA Method 7130:			
Cd	mg/l	0.04	< 0.04
EPA Method 7190:			
Cr	mg/l	0.03	< 0.03
EPA Method 7210:			
Cu	mg/l	0.05	2.4
EPA Method 7420:			
Pb	mg/l	0.2	< 0.2
EPA Method 7520:			
Ni	mg/l	0.07	< 0.07
EPA Method 236.1			
Fe	mg/l	0.06	0.64
EPA Method 9010:			
Cyanide	mg/l	0.01	< 0.01

Trace Analysis Laboratory is certified by the California Department of Health Services under Hazardous Waste Testing Laboratory Certificate No. 122.

  
Ronald H. Ming Chew  
Supervisory Chemist

ALAMEDA COUNTY HEALTH CARE SERVICES AGENCY  
 470-27th Street, Oakland, CA 94612  
 (415) 874-6434

OCCUPATIONAL HEALTH SERVICES  
 LABORATORY SERVICE REQUEST

Plant or Place Dublin Multilayer

Address 6341 Scarlett Dr

Sample Submitted to B. Chan Date Submitted 7/20/87

Send Analytical Report to: Alameda County Health Care Services Agency/  
 Occupational Health  
 470-27th Street, Room 324, Oakland, CA 94612  
 Attn:

Send Invoice To: \_\_\_\_\_

Item No.	Date Coll.	Type of Sample (Air, Material)	Volume/Weight	Field Observation	Analysis Requested
LJM	7/19/87-1	water	1 liter		As, Cd,
LJM	7/19/87-2	water + sludge	60 ml		Total Cr F, Pb, Hg Ag, Zn

Chain of Custody:

1.	<u>Louise J. Miller</u> Signature	<u>S. H. ...</u> Title	<u>7/20/87</u> Inclusive Dates
2.	<u>B. Chan</u> Signature	<u>Chemist III</u> Title	<u>7/20/87</u> Inclusive Dates
3.	_____ Signature	_____ Title	_____ Inclusive Dates

FORMAL AUTHORIZATION FOR THE REMOVAL AND DISPOSAL OF A HAZARDOUS MATERIAL SPILL

TO: Alameda County Health Care Services Agency  
Division of Environmental Health

Regarding the following described incident:

- a) Date and time: Initially occurred 7/18/87; called Street 7/19/87
- b) Location: 6341 Scarlet Court  
Dublin, CA 94568
- c) Description: overflowing filter treatment tank for  
printed circuit board manufacturer  
Name: Dublin Multilayer  
clean-up will be done by Erickson, Inc. 235-1393

I hereby authorize the Alameda County Health Care Services Agency, Division of Environmental Health, to be my agent for the purpose of engaging:

(e.g., I. T. Corporation) Erickson, Inc.

(hereinafter referred to as "Removal Operator") to take corrective action with respect to the above-described incident.

I promise and agree:

- a) To sign any contract or other written authorization required by the Removal Operator;
- b) To pay the cost of the corrective action taken by the Removal Operator; and
- c) That the County of Alameda and the Alameda County Health Care Services Agency, Division of Environmental Health, shall not be responsible for the costs of the Removal Operator's corrective action.

Dated: 7/19/87

Name: Mr. Edward ~~Chan~~ Wong

Address: 6341 Scarlet  
Dublin, CA

Phone: 829-1956

Signature: X Edward C. Wong

Witnessed by: \_\_\_\_\_ on \_\_\_\_\_

at \_\_\_\_\_

(Signature of Witness)

HAZARDOUS MATERIAL UNIT SPILL REPORT

To: Rafat Shahid

From: Lowell Miller

Date of Incident: July 19, 1987, 1:00 P.M.

Agency initially reporting incident: Dublin Fire Department, Chief Swanson  
829-2393

Location of Spill: 6341 Scarlett Court, Dublin, CA 94568

Responsible party: Dublin Multilayer 829-1956  
6341 Scarlett Court  
Dublin, CA

Clean-up performed by: Erickson & Co., San Jose, CA

Description of Incident:

A hose used to supply fresh water to a waste treatment tank developed a leak some time after 2:00 P.M. on July 16, 1987. This allowed excess water into a secondary containment system (capacity 2370 gal) tank used to treat wastes from the processing units in the plant. The primary tanks within the unit apparently floated and were not affected by the excess water although some of the sludge at the bottom of the secondary unit was carried out with the overflow water. The sludge consisted mostly of iron sulfate, iron oxide, and lesser amounts of oxides of nickel, lead and chromium.

The spill appeared rust colored and registered a neutral pH. After checking the sewer discharge permit and other information it was determined that the spilled material did not constitute an imminent hazard and most likely contained only small amounts of heavy metals. Mr. Edward Chan, the president of the company, was instructed to have the spilled material in the parking lot cleaned. Further clean-up of the storm drains might be required pending analysis of sludge and water samples collected during the incident.

cc Alf Jensen

ZONE 7  
484-2600

5997 Parkside  
Piacentini  
Dennis Gurnea  
Vince Wong

DUBLIN MULTILAYER, INC.  
SPILL.207

SPILL REPORT FOR JULY 19, 1987

RECEIVED

HAZARDOUS MATERIALS  
WASTE PROGRAM  
PERMIT

TIME PROBLEM NOTED: 11:06 AM BY DUBLIN  
11:50 AM BY MR. ED WONG, PERMIT

TIME DISCHARGE CEASED: APPROXIMATELY 12:15 PM

PROBLEM: HOSE WITH NOZZLE WHICH WAS CONNECTED TO CITY WATER LINE  
SPRUNG A LEAK. THE SECONDARY CONTAINMENT AREA (EFFECTIVE  
VOLUME 70 CUBIC FEET) THEN FILLED WITH CITY WATER AND OVER-  
FLOWED. WATER FLOWED FROM UNDER THE BACK BAY DOOR THROUGH  
PARKING LOT TO STORM DRAIN. ACCORDING TO WATER METER ABOUT  
160 CUBIC FEET (1200 GALLONS) HAD OVERFLOWED. BASED ON 2 GPM  
OVERFLOW RATE THE LEAK STARTED BETWEEN 2:00 AM AND 2:30 AM ON  
JULY 19TH AND CONTINUED FOR ABOUT TEN HOURS.

IMMEDIATE CORRECTIVE ACTION TAKEN:

MAIN CITY WATER VALVE WAS TURNED OFF AT 12:15 PM. AT 5:00 PM  
THE MEMTEK WASTE TREATMENT SYSTEM WAS TURNED ON AND WATER IN  
THE SECONDARY CONTAINMENT AREA WAS SAMPLED AND PUMPED TO THE  
WASTE TREATMENT SYSTEM. AT 7:00 PM ERICKSON INC. BEGAN  
CLEANING UP RUST STAINS (NON-HAZARDOUS FERROUS IRON RESIDUE)  
LEFT BY THE OVERFLOW THROUGH THE PARKING AREA TO THE STORM  
DRAIN, AND COMPLETED THE JOB BY 11:30 PM. THE RUST CLEANUP  
WAS REQUIRED BY MR. MILLER OF THE ALAMEDA HEALTH DEPARTMENT  
WHO VISITED THE LOCATION AT 2:30 PM.

LONG-TERM CORRECTIVE ACTION TAKEN:

- 7/20
- 1) REPLACED HOSE, NOZZLE, AND PIPE WITH SCHEDULE 80 PIPE.
  - 2) PLANT MEETING AND PLANT-WIDE MAINTENANCE CHECK DONE  
WITH WET-FLOOR AREA SHUT DOWN. MEMTEK AREA CLEANED.
  - 3) CANCELLED SECOND SHIFT.
  - 4) DISCUSSION WITH APPLIED EARTH (CONSULTANTS).
    - A) REFRIGERATE 5 GALLON SAMPLE OF OVERFLOW.
    - B) SAMPLE STORM DRAIN.
    - C) SEND SAMPLES TO STATE CERTIFIED LAB FOR ANALYSIS.
    - D) AEC TO CONTACT PRESS, COUNTY HEALTH DEPARTMENT, AND  
LOCAL WATER DISTRICT REGARDING INCIDENT.
- 7/21
- 1) ERICKSON INC. PUMPS RUST CLEANUP WATER TO MEMTEK WASTE  
TREATMENT SYSTEM FOR TREATMENT.
  - 2) LAB RESULTS SHOW BOTH OVERFLOW SAMPLE ( $Cu = 2.4$  PPM)  
AND STORM DRAIN SAMPLE ( $Cu = 0.9$  PPM) WERE WITHIN  
EFFLUENT LIMITS OF LOCAL WATER DISTRICT (DSRSD).
  - 3) PLANT SHUTDOWN PROCEDURE REVISED TO INCLUDE SHUTOFF  
OF MAIN CITY WATER VALVE.

SIGNATURE: Karl A. Sauter TITLE: QC Manager

CC: MR. JOHN MAUCK, DUBLIN SAN RAMON SERVICES DISTRICT (DSRSD)  
MR. LOWELL MILLER, ALAMEDA COUNTY HEALTH DEPARTMENT  
MR. GILBERT JENSEN  
MR. TOM HATHCOCK, DUBLIN FIRE DEPARTMENT  
MS. L. HUANG, REGIONAL WATER QUALITY CONTROL BOARD



DUBLIN MULTILAYER INC.  
SPILL REPORT FOR JULY 19, 1987

TIME PROBLEM NOTED: 11:06 AM BY DUBLIN POLICE DEPARTMENT  
11:50 AM BY MR. ED WONG, PRESIDENT

TIME DISCHARGE CEASED: APPROXIMATELY 12:15 PM

PROBLEM: HOSE WITH NOZZLE WHICH WAS CONNECTED TO CITY WATER LINE SPRUNG A LEAK. THE SECONDARY CONTAINMENT AREA (EFFECTIVE VOLUME 70 CUBIC FEET) THEN FILLED WITH CITY WATER AND OVERFLOWED. WATER FLOWED FROM UNDER THE BACK BAY DOOR THROUGH PARKING LOT TO STORM DRAIN. ACCORDING TO WATER METER ABOUT 160 CUBIC FEET (1200 GALLONS) HAD OVERFLOWED. BASED ON 2 GPM OVERFLOW RATE THE LEAK STARTED BETWEEN 2:00 AM AND 2:30 AM ON JULY 19TH AND CONTINUED FOR ABOUT TEN HOURS.

IMMEDIATE CORRECTIVE ACTION TAKEN:

MAIN CITY WATER VALVE WAS TURNED OFF AT 12:15 PM. AT 5:00 PM THE MEMTEK WASTE TREATMENT SYSTEM WAS TURNED ON AND WATER IN THE SECONDARY CONTAINMENT AREA WAS SAMPLED AND PUMPED TO THE WASTE TREATMENT SYSTEM. AT 7:00 PM ERICKSON INC. BEGAN CLEANING UP RUST STAINS (NON-HAZARDOUS FERROUS IRON RESIDUE) LEFT BY THE OVERFLOW THROUGH THE PARKING AREA TO THE STORM DRAIN, AND COMPLETED THE JOB BY 11:30 PM. THE RUST CLEANUP WAS REQUIRED BY MR. MILLER OF THE ALAMEDA HEALTH DEPARTMENT WHO VISITED THE LOCATION AT 2:30 PM.

LONG-TERM CORRECTIVE ACTION TAKEN:

- 7/20
- 1) REPLACED HOSE, NOZZLE, AND PIPE WITH SCHEDULE 80 PIPE.
  - 2) PLANT MEETING AND PLANT-WIDE MAINTENANCE CHECK DONE WITH WET-FLOOR AREA SHUT DOWN. MEMTEK AREA CLEANED.
  - 3) CANCELLED SECOND SHIFT.
  - 4) DISCUSSION WITH APPLIED EARTH (CONSULTANTS).
    - A) REFRIGERATE 5 GALLON SAMPLE OF OVERFLOW.
    - B) SAMPLE STORM DRAIN.
    - C) SEND SAMPLES TO STATE CERTIFIED LAB FOR ANALYSIS.
    - D) AEC TO CONTACT PRESS, COUNTY HEALTH DEPARTMENT, AND LOCAL WATER DISTRICT REGARDING INCIDENT.
- 7/21
- 1) ERICKSON INC. PUMPS RUST CLEANUP WATER TO MEMTEK WASTE TREATMENT SYSTEM FOR TREATMENT.
  - 2) LAB RESULTS SHOW BOTH OVERFLOW SAMPLE (Cu = 2.4 PPM) AND STORM DRAIN SAMPLE (Cu = 0.9 PPM) WERE WITHIN EFFLUENT LIMITS OF LOCAL WATER DISTRICT (DSRSD).
  - 3) PLANT SHUTDOWN PROCEDURE REVISED TO INCLUDE SHUTOFF OF MAIN CITY WATER VALVE.

SIGNATURE:

*Karl A. Suter*

TITLE:

*QC Manager*

CC: MR. JOHN MAUCK, DUBLIN SAN RAMON SERVICES DISTRICT (DSRSD)  
MR. LOWELL MILLER, ALAMEDA COUNTY HEALTH DEPARTMENT  
MR. TOM HATHCOCK, DUBLIN FIRE DEPARTMENT  
MS. L. HUANG, REGIONAL WATER QUALITY CONTROL BOARD  
MS. D. RUCHONNET, APPLIED EARTH CONSULTANTS INC.

*8/7/87*



Alameda County  
District Attorney's Office  
John J. Meehan, District Attorney

*JEM*

RECEIVED  
MAR 21 1987

HAZARDOUS MATERIALS/  
WASTE PROGRAM

March 18, 1987

John Chan  
President  
Dublin Multilayer, Inc.  
6341 Scarlett Court  
Dublin, CA 94568

Dear Mr. Chan:


This office has received referrals of a series of violations of numerous environmental laws from a number of state, county and local agencies dating back to 1983. An investigation by this office has determined that there is sufficient evidence to bring a civil action seeking civil penalties for a variety of violations. You should be informed that such a suit will be filed.

While you have the right to await the filing of an action and contest it in court, it is often useful in appropriate cases to offer the responsible party the opportunity to discuss the matter prior to the filing of a complaint. Since we are informed by the Alameda County Department of Environmental Health Hazardous Materials Management Division that your company has been responsive to their requests for compliance since their inspection in April 1986, this approach is appropriate and could avoid costly litigation.

To that end, we have scheduled a meeting in our office at the below listed address on March 25, 1987 at 2:00p.m.

Very truly yours,

JOHN J. MEEHAN  
District Attorney

By:   
Gilbert A. Jensen  
Senior Deputy District Attorney

JJM:GAJ:ih

cc: Edgar B. Howell III  
Alameda County  
Department of Environmental Health



# APPLIED EARTH CONSULTANTS, INC

ENGINEERING - GEOLOGY - HYDROLOGY

910 Bern Court, Suite 150, San Jose, California 95112  
(408) 298-0806

September 10, 1986  
Job. No. 60747L4

Mr. Edgar B. Howell III  
Senior Hazardous Materials Specialist  
Alameda County Health Care Services  
470 27th Street, Third Floor  
Oakland, CA 94612

RECEIVED  
SEP 15 1986

HAZARDOUS MATERIALS/  
WASTE PROGRAM

Dear Mr. Howell:

Dublin Multilayer, Inc. would like to modify the plan it submitted and you approved for providing storage for the hazardous wastes it produces. Due to changes in its processes not involving hazardous materials, Dublin Multilayer has found that it requires the space currently holding the Cake Sludge for production purposes. Dublin Multilayer would like to store this Cake Sludge in another room in the facility. Please refer to Attachment 1 for the exact location and relevant sizes of the proposed location. The type of containment would be the same in the new location as was proposed for the present location.

The relocation of the Cake Sludge will involve some relocation of equipment and therefore Dublin Multilayer would like to ask for a two month extension for the completion date of the secondary containment for the Cake Sludge. In the meantime, the weekly inspections of the area containing the sludge cake will be maintained as required.

If you have any questions please do not hesitate to call me.

Thank you.

Sincerely

APPLIED EARTH CONSULTANTS, Inc.

Danielle Ruchonnet  
Senior Environmental Manager


DR/dr

encl.

Copies: Addressee (1)  
Mr. John Chan, Dublin Multilayer, Inc. (1)

Diagram 1

Secondary Containment Design for Areas 1 and 2



ALAMEDA COUNTY  
HEALTH CARE SERVICES

AGENCY

CARL N. LESTER, Agency Director



470-27th Street, Third Floor  
Oakland, California 94612  
(415) 874-7237

HAZARDOUS WASTE GENERATOR  
INSPECTION AND COMPLIANCE REPORT

EPA I.D. # CAT 060031537

DATE 7-22-86

GENERATOR NAME/ADDRESS

CONTACT PERSON Karl Sauter

Dublin MultiLayer  
6341 Scarlett Ct  
Dublin, 94568

PHONE NUMBER 829-1906

PERSONS PRESENT \_\_\_\_\_

AVERAGE GENERATION RATE (MONTHLY) \_\_\_\_\_

OBSERVATIONS:

Signs for haz. waste storage areas are at  
Treatment System + Drum Storage  
Sign at process line NOT needed  
Inspection guidelines + form on file with inspectors  
weekly noted.

Samples Taken<sup>1</sup>: Yes  No  Plan of correction necessary: Yes  Due Date \_\_\_\_\_ No

Authorized Representative of Firm:

Name Karl A. Sauter  
Title QC Manager  
Signature Karl A. Sauter  
Date 7-22-86

Authorized Representative of Alameda County:

Name Edgar B. Howell III  
Phone Number 874-7237  
Signature E. B. Howell  
Date 7-22-86

<sup>1</sup>All samples will be taken in accordance with Section 25185, California Administrative Code, Division 20, Chapter 6.5

PS Form 3800, Apr. 1976

1.  Special Delivery and address of delivery.

2.  Restricted Delivery.

3. Addressee:  
 Mr. Karl Sauter  
 Dublin News-Examiner  
 6341 Scarlett Court  
 Dublin, CA 94568

4. Type of Service:  Registered  Registered Certified  Registered Express Mail  Registered Mail  Registered Parcel  Registered Parcel Return Receipt  Registered Parcel Return Receipt with Restricted Delivery

Article Number: 314 212 222

Signature: *W. J. Turpin*

7/3/86

P 314 212 222  
 RECEIPT FOR CERTIFIED MAIL

NO INSURANCE COVERAGE PROVIDED—  
 NOT FOR INTERNATIONAL MAIL  
 (See Reverse)

SENT TO		Karl Sauter
STREET AND NO.		6341 Scarlett Ct
P.O., STATE AND ZIP CODE		Dublin, CA 94568
POSTAGE		\$ .22
CONSULT POSTMASTER FOR FEES	<input checked="" type="checkbox"/> CERTIFIED FEE	.70 c
	<input type="checkbox"/> SPECIAL DELIVERY	c
	<input type="checkbox"/> RESTRICTED DELIVERY	c
	<input checked="" type="checkbox"/> RETURN RECEIPT SERVICE	.75 c
	<input type="checkbox"/> RETURN RECEIPT SERVICE WITH RESTRICTED DELIVERY	c
<input type="checkbox"/> RETURN RECEIPT SERVICE WITH RESTRICTED DELIVERY	c	
TOTAL POSTAGE AND FEES		\$ 1.67
POSTMARK OR DATE		

PS Form 3800, Apr. 1976

ALAMEDA COUNTY  
HEALTH CARE SERVICES

DAVE KEARS AGENCY  
~~XXXXXXXXXX~~ Agency Director



470-27th Street, Third Floor  
Oakland, California 94612  
(415) 874-7237

June 30, 1986

Mr. Karl Sauter  
Quality Control Manager  
Dublin Multilayer  
6341 Scarlett Court  
Dublin, CA 94568

Dear Mr. Sauter,

We are in receipt of your plan of correction prepared by Applied Earth Consultants, Inc.. The plan as presented is acceptable. Please call us for inspections on the dates of completion as presented in the plan.

If you have any questions please contact Edgar B. Howell, Senior Hazardous Materials Specialist, at 874-7237.


Sincerely,

Rafat A. Shahid, Manager  
Hazardous Materials Unit

RAS:bjb

cc: D. Hoenig, DOHS  
G. Jensen, DA

Dublin Multilayer  
Spill at 6341 Scarlett Court  
Dublin 94503



Dublin Multilayer  
6341 Scarlett Court



Dublin Multilayer  
6341 Scarlett Court



Dublin Multilayer  
6341 Scarlett Court



ALAMEDA COUNTY  
HEALTH CARE SERVICES

DAVE KEARS

AGENCY

Agency Director



470-27th Street, Third Floor  
Oakland, California 94612  
(415) 874-7237

May 5, 1986

Mr. Karl Sauter  
Quality Control Manager  
Dublin Multilayer  
6341 Scarlett Ct  
Dublin, CA 94568

Dear Mr. Sauter:

On April 28, 1986, an inspection of the above subject facility disclosed the following:


1. The 55 gallon drums of hazardous waste, sludge from the pretreatment plant were not labeled as required in sec 66504(c), Title 22, California Administrative Code.
2. Each of the drums were not labeled with the date accumulation began, as required by sec 66508(2), Title 22, California Administrative Code.
3. There was no berm around the Haz waste storage area, as required by sec 67245, Title 22, California Administrative Code.
4. The 23 to 25 drums of hazardous waste were not secured inside a building or fence with signs in both English and Spanish "Danger - Hazardous Waste Area - Unauthorized Personnel Keep Out", as required by sec 67103, Title 22, California Administrative Code.

Section 66328(d), Title 22, California Administrative Code states that, if corrections are needed, the operator shall provide to the department, a written plan of correction, which states the actions to be taken and the expected dates of completion. Pursuant to this section, we request that you submit a plan of correction to this office within 15 days.

Page 2 of 2  
May 5, 1986  
Mr. Karl Sauter  
Dublin Multilayer

If you have any questions, please contact Edgar B. Howell, III,  
Senior Haz Mat Specialist, at 874-7237.

Sincerely,



Rafat A. Shahid, Manager  
Hazardous Materials Program

RAS:mn-c

cc: Dwight Hoenig, DOHS  
Gil Jensen, DA



AGENCY

CARL N. LESTER, Agency Director

470-27th Street, Third Floor  
Oakland, California 94612  
(415) 874-7237

HAZARDOUS WASTE GENERATOR  
INSPECTION AND COMPLIANCE REPORT

EPA I.D. # CAT060031537

DATE 4-28-86

GENERATOR NAME/ADDRESS

CONTACT PERSON

Dublin Multi Layer  
6341 SCARLETT CT  
Dublin

PHONE NUMBER 829-1956

PERSONS PRESENT KARL SAUTER

AVERAGE GENERATION RATE (MONTHLY) 17 drums Month

OBSERVATIONS:

1. Hazardous Waste Drums must be labeled with appropriate label and dated for the beginning of storage.
2. Hazardous Waste Storage area must be secure from public and bermed.

Liquid taken by Solvent Server last 8/29/85  
All waste since has been collected after pre-treatment and is sludge  
stored since March as sludge.

Samples Taken<sup>1</sup>: Yes  No  Plan of correction necessary: Yes  Due Date \_\_\_\_\_ No

Authorized Representative of Firm:  
Name Karl Sauter  
Title QC Manager  
Signature Karl A. Sauter  
Date April 28, 1986

Authorized Representative of Alameda County:  
Name Edgar B. Howell III  
Phone Number 874-7237  
Signature Edgar B. Howell  
Date 4-28-86

<sup>1</sup>All samples will be taken in accordance with Section 25185, California Administrative Code, Division 20, Chapter 6.5

Charlene Williams  
RECORD OF TELEPHONE  
COMMUNICATION

919

DATE: 4/25/86

TO  FROM:

Paul Stovall

TIME: 1430

TELEPHONE #:

846-4565

SITE:

Dublin Multilayer

ADDRESS:

6341 Scarlett Ct.

SUBJECT:

violation of  
pretreatment permit

Dublin 94568

SUMMARY:

Dublin Multilayer dumping heavy metals  
in municipal sewer.

toxic in ~~bars~~ drums being  
stored more than 90 days

improper storage of toxics

RECORDED BY:

CA

COMPLAINT/EVALUATION

DATE: 4-22-86

TIME: 0900

No: 186

COMPLAINT RECEIVED BY: EBA

NAME OF COMPLAINANT: Paul Scovill

CITY: Dublin

PHONE: 846-9525

ADDRESS:

SUBJECT OF COMPLAINT: Springs of pre-treat sludge on site  
28 drums at present.

ADDRESS OF FACILITY (SUBJECT OF COMPLAINT): 6341 SCARLETT CT.  
PHONE:

NAME: Dublin Multi Layer

CONTACT PERSON:

ACTIONS TAKEN: Inspected 4/28/86 see folder

INVESTIGATED BY:

DATE: 4-28-86

APPLIED TIME: 90

SIGNATURE: Edgar Brown

1051 - 5/12

CODE # 811020301

DEPARTMENT OF HEALTH SERVICES  
OFFICE OF ENFORCEMENT

Waste Alert Hotline

Date of Call: 4/18/86

Taken by: Burke  
Time of Call: 3:30

Type of Incident:

- haul/transport
- abandoned site
- dumping activity
- spill/leak
- other: Storage

Incident Location:

Name of operation (if known) Dublin Multilayer  
 Location of incident 6341 Scarlett Court  
Dublin, CA (Alameda County)  
94568

Proprietor (if known) \_\_\_\_\_

Phone ( ) \_\_\_\_\_

Date(s) and Time(s) of suspicious activity \_\_\_\_\_

Is this activity/problem apparent at "regular intervals"?

- Yes - give time of day/day of week \_\_\_\_\_
- No

Vehicles:

Type of vehicle (make, model, year, markings): \_\_\_\_\_

License Number (if known) \_\_\_\_\_ Owner (if known) \_\_\_\_\_

Phone: \_\_\_\_\_

Chemical/Substance data:

Name of chemical/substance/description of waste: leaving residue -

heavy metals copper, chromium, lead & zinc

Type of operation: print - circuit boards

Type of containers visible: 55 gallons

Emergency Response: Barrels have a cake like material in them.

Is there a need to notify an emergency response unit? yes no

Other Comments:

There are 28 - 55 gal barrels being stored outside of this establishment. (approx 90 days) Most do not have covers, are subject to leaks, & can overflow.

Believes they are suppose to be manifested w/ IT Corp. Also indicates they have nitric acid & caustic soda stored on top of each other. Also not secondary containment.

Feb 11 had 18 barrels so they are slowly accumulating.

Recommended Action: Barrels are there because the city requires for pretreatment don't permit the disposal of the above constituents.

Informant:

[ ] wished to remain anonymous.

can be contacted:

Name: Paul Stovall

Phone: (415) 846-4565

Address: 7419 Tamarack Dr. Dublin, 94568





SECTION C  
HAZARDOUS SUBSTANCES

C1. Please check if any of the following categories of hazardous substances is used or handled by your firm:

TOXIC  CORROSIVE   
FLAMMABLE OR IGNITABLE  REACTIVE

C2. Please check the attached list for any of the chemical substances you receive, store, mix, treat, formulate, generate, manufacture, transport or dispose of, and enter each by the number identified on the list in the spaces below:

~~Sample:~~

<del>11311</del>							
11918	12124	121313	141919	161717	171015	171913	
101310	131916	131414	131811	131815	141016	151410	

CERTIFICATION

I hereby certify that the information on this form is to the best of my knowledge, true and complete

Karl A. Sauter  
Signature

Karl A. Sauter  
Typed or Printed Name

Quality Manager  
Title

April 16th, 1986  
Date

Please return completed form to:

Alameda County Division of Environmental Health  
470-27th Street, Room 322  
Oakland, CA 94612  
(415) 874-7237

DUBLIN SAN RAMON SERVICES DISTRICT

PRETREATMENT PROGRAM

WASTEWATER DISCHARGE PERMIT

828-0515  
Emile Kathan  
7051 Dublin Blvd  
Dublin 94568

PERMIT NO. 3629-101

IN ACCORDANCE WITH ALL TERMS AND CONDITIONS OF THE:

x D.S.R.S.D. CODE, CHAPTER 7 ARTICLE 3

       CITY OF PLEASANTON CODE, CHAPTER 8 ARTICLES 5,7

AND ALSO WITH ANY APPLICABLE PROVISIONS OF FEDERAL OR STATE LAW OR REGULATION;

PERMISSION IS HEREBY GRANTED TO Dublin Multilayer, Inc.

6341 Scarlett Court, Dublin, California

CLASSIFIED BY SIC NO. 3679

FOR THE CONTRIBUTION OF Wastewater Flows

INTO THE D.S.R.S.D. SEWER LINES AT       

6341 Scarlett Court, Dublin, California

EFFECTIVE THIS 1st DAY OF Oct. , 1985

TO EXPIRE 30th DAY OF Sept. , 1987

  
\_\_\_\_\_  
DIRECTOR OF PUBLIC WORKS

Maximum Conc.  
(mg/l) - 24 Hour  
Flow Proportional  
Composite Sample

PARAMETERS (mg/l)

— Arsenic (As)		1.0
— Cadmium (Cd)	Max. 1.2	Ave 0.7
— Chromium-total (Cr)	Max. 5.0	Ave 4.0
— Copper (Cu)	Max 4.5	Ave 2.7
Cyanide (CN)	Max 1.9	Ave 1.0

Fluoride (F) 5.0

— Lead (Pb) Max 0.6 Ave 0.4

— Mercury (Hg) 0.5

— Nickel (Ni) Max 4.1 Ave 2.6

Phenols 5.0

— Silver (Ag) 2.0

— Zinc (Zn) Max 4.2 Ave 2.6

PCBs 0.01

Total Identifiable  
Chlorinated Hydrocarbons 0.02

Oil & Grease  
(Freon Extractable) 200

Total Dissolved Solids 1000

Temperature-Maximum  
(Degrees C) 51°

pH-Maximum (pH Units) 9.0

pH-Minimum (pH Units) 6.0

Biochemical Oxygen Demand 400

Chemical Oxygen Demand 1500

Suspended Solids 350

Flow - (MGD) 0.001

Total Toxic Organics 2.13

Total Metals Max 10.5 Ave 6.8

(Cu, Ni, Zn, total Cr)