



**CHIPS**  
**Environmental**  
**Consultants, Inc.**

RECEIVED BY  
HAZARDOUS MATERIALS OFFICE

718 E. Evelyn Avenue  
Sunnyvale, CA 94086

AUG 23 1990

(408)736-1380  
FAX (408)736-0887

HAYWARD FIRE DEPARTMENT

August 15, 1990

D s k 1 6 9 7 7 . D O C

Venture Properties  
ATTN: Mr. Rob Robles  
9970-A Palm Court  
Morgan Hill, California 95037

RE: Water Sampling at 23724 Saklan Avenue, Hayward,  
California on 8-8-90.

Dear Mr. Robles:

Following is the analytical report for the water sample  
taken from the subject facility on 8-8-90.

Prior to sampling, the well was purged of three well  
volumes, allowing the pH, temperature and conductivity to  
stabilize. Specific well purging data is contained on page  
2.

If you have any questions regarding this report, please feel  
free to contact us at your convenience.

Sincerely,

Kip Porter



# CHIPS Environmental Consultants, Inc.

718 E. Evelyn Avenue  
Sunnyvale, CA 94086

(408)736-1380  
FAX (408)736-0887

August 15, 1990

D s k 1 6 9 7 7 . D O C

Venture Properties  
ATTN: Mr. Rob Robles  
9970-A Palm Court  
Morgan Hill, California 95037

RE: Water Sampling at 23724 Saklan Avenue, Hayward,  
California on 8-8-90.

### Project Data

Depth to Water: 14.375'


Depth to Bottom: 24.438'

Standing Water Volume: 6.569 gallons

Diameter: 4"

<u>Purging Data</u>	<u>pH</u>	<u>Temp (C)</u>	<u>Conductivity (mS)</u>
Initial	6.5	20	1.25
After 1st Purge	6.0	19	1.21
After 2nd Purge	5.9	19	1.20
After 3rd Purge	5.9	19	1.19





# CHIPS Environmental Consultants, Inc.

### SAMPLE HANDLING/LOG-IN

Date 8-8-90

23724 TRIDENT TRUCKING  
Test Location 30000 AVE., HAYWARD


	Sample Type	Volume	Comments
1.	002438	7.4ml w/BS	GPS NESTLE BREAK
2.			
3.			
4.			
5.			
6.			
7.			
8.			
9.			
10.			
11.			
12.			

### CHAIN OF CUSTODY

[Signature] 8-8-90  
FIELD

[Signature] 8-8-90  
LAB





# CHIPS Environmental Consultants, Inc.

## SAMPLE HANDLING/LOG-IN

Date 8-8-90


23724 TRIDENT TRUCKING  
Test Location SARAWAN AVE., HAYWARD

	Sample Type	Volume	Comments
1.	002434	7.4ml WBS	GAS DESICL BLEN
2.			
3.			
4.			
5.			
6.			
7.			
8.			
9.			
10.			
11.			
12.			

### CHAIN OF CUSTODY

[Signature] 8-8-90  
FIELD

[Signature] 8-8-90  
LAB



**CHIPS**  
**Environmental**  
**Consultants, Inc.**

718 E. Evelyn Avenue  
Sunnyvale, CA 94086

(408)736-1380  
FAX (408)736-0887

90 AUG 22 AM 10:21

August 15, 1990

D s k 1 6 9 7 7 . D O C

Venture Properties  
ATTN: Mr. Rob Robles  
9970-A Palm Court  
Morgan Hill, California 95037

RE: Water Sampling at 23724 Saklan Avenue, Hayward,  
California on 8-8-90.

Dear Mr. Robles:

Following is the analytical report for the water sample  
taken from the subject facility on 8-8-90.

Prior to sampling, the well was purged of three well  
volumes, allowing the pH, temperature and conductivity to  
stabilize. Specific well purging data is contained on page  
2.

If you have any questions regarding this report, please feel  
free to contact us at your convenience.

Sincerely,



Kip Porter



# CHIPS Environmental Consultants, Inc.

718 E. Evelyn Avenue  
Sunnyvale, CA 94086

(408)736-1380  
FAX (408)736-0887

August 15, 1990

D B K 1 6 9 7 7 . D O C

Venture Properties  
ATTN: Mr. Rob Robles  
9970-A Palm Court  
Morgan Hill, California 95037

RE: Water Sampling at 23724 Saklan Avenue, Hayward,  
California on 8-8-90.

### Project Data

Depth to Water: 14.375'

Depth to Bottom: 24.438'

Standing Water Volume: 6.569 gallons

Diameter: 4"

<u>Purging Data</u>	<u>pH</u>	<u>Temp (C)</u>	<u>Conductivity (mS)</u>
Initial	6.5	20	1.25
After 1st Purge	6.0	19	1.21
After 2nd Purge	5.9	19	1.20
After 3rd Purge	5.9	19	1.19