

**CHIPS**  
**Environmental**  
**Consultants, Inc.**

718 E. Evelyn Avenue  
Sunnyvale, CA 94086

(408)736-1380  
FAX (408)736-0887

September 19, 1990

D s k 1 7 1 0 0 6 . D O C

Trident Trucking  
ATTN: Mr. Bob Senna  
P.O. Box 4030  
Hayward, California 94540

RE: Water Sampling at 23724 Saklan Avenue, Hayward,  
California on 9-7-90.

Dear Mr. Senna:

Following is the analytical report for the water sample  
taken from the subject facility on 9-7-90.

Prior to sampling, the well was purged of three well  
volumes, allowing the pH, temperature and conductivity to  
stabilize. Specific well purging data is listed on page 2.

If you have any questions regarding this report, please feel  
free to contact us at your convenience.

Sincerely,

Mark D. Chips



# CHIPS Environmental Consultants, Inc.

718 E. Evelyn Avenue  
Sunnyvale, CA 94086

(408)736-1380  
FAX (408)736-0887

September 19, 1990

Dsk 17 1006.DOC

Trident Trucking  
ATTN: Mr. Bob Senna  
P.O. Box 4030  
Hayward, California 94540

RE: Water Sampling at 23724 Saklan Avenue, Hayward,  
California on 9-7-90.

### Project Data

Depth to Water: 14'


Depth to Bottom: 24.438'

Standing Water Volume: 6.6 gallons

Diameter: 4"

<u>Purging Data</u>	<u>pH</u>	<u>Temp (F)</u>	<u>Conductivity (mS)</u>
Initial	6.9	68	1.25
After 1st Purge	6.6	67	1.19
After 2nd Purge	6.6	67	1.19
After 3rd Purge	6.6	67	1.19





# CHIPS Environmental Consultants, Inc.

SAMPLE HANDLING/LOG-IN

#1006

Date 9-7-90

Test Location TRIDENT TRUCKING

	Sample Type	Volume	Comments
1.	004262	4-4 <sup>and</sup> VOAS	GAS DIESEL BTEX
2.			
3.			
4.			
5.			
6.			
7.			
8.			
9.			
10.			
11.			
12.			

CHAIN OF CUSTODY

*H. M.* 9-7-90  
FIELD

*H. M.* 9-7-90  
LAB