

Drogos, Donna, Env. Health

Subject: RO2859 - 7280 Johnson Dr
Entry Type: Phone call

Start: Thu 1/4/2007 5:00 PM
End: Thu 1/4/2007 5:00 PM
Duration: 0 hours

01/04/07, 506p, John Rigtor

Another case Chlorox, leak from hydraulic hoist in old bldg not used
Opened up
Took out tanks for hoist & oil water sep & surge chamber
Old equip maintenance facility
O&G & TPHD high
925-454-2337
7280 Johnson Dr
Have an open LUFT case

Drogos, Donna, Env. Health

Subject: POTENTIAL NEW SITE - Clorox, 7280 Johnson Dr, Pleasanton,
Entry Type: Phone call

Start: Wed 8/11/2004 9:33 AM
End: Wed 8/11/2004 9:33 AM
Duration: 0 hours

potential new site

8/11/04, John Rictor, MBM coming over

Clorox, 7280 Johnson Dr, Pleasanton, 10K diesel UST, everything seemed clean, 24 ppm in stockpile after 3 composited into 1, stockpile deposited into hole, out of service a long time, no dispenser containment, 2nd dairy could pass tightness.