

ALAMEDA COUNTY  
HEALTH CARE SERVICES

AGENCY  
DAVID J. KEARS, Agency Director



R02860

DEPARTMENT OF ENVIRONMENTAL HEALTH  
Hazardous Materials Program  
80 Swan Way, Rm. 200  
Oakland, CA 94621  
(415)

July 18, 1990

Mr. Bob Fernandez  
General Manager  
Smith-Kline Bio Sciences  
6511 Golden Gate Dr.  
Dublin, CA 94568

Re: **Completed underground tank closure at 6511 Golden Gate Dr.,  
Dublin**

Dear Mr. Fernandez:

As you're aware, on November 7, 1989, one underground storage tank was removed from the above facility, and soil samples were collected and analyzed according to guidelines established by the San Francisco Regional Water Quality Control Board. GTEL Laboratories analyzed the samples and reported hydrocarbon levels of 24 ppm in one and "ND" in the other. Contaminated excavation spoils were hauled under manifest to GSX in McKittrick, CA.

Based on the information outlined above, no further site remediation is needed at this time. Please be aware that this does not free present or future landowners or operators from cleanup responsibilities in the event that new information indicates a pollutant problem on the site or originating from the site.

If you have any questions about this letter, please contact the undersigned at 271-4320.

Sincerely,

Gil Wistar  
Hazardous Materials Specialist

cc: Tom Hathcox, Dougherty Regional Fire Dist.  
Rafat A. Shahid, Asst. Agency Director, Environmental Health files