

UNDERGROUND STORAGE TANK UNAUTHORIZED RELEASE (LEAK)/ CONTAMINATION SITE REPORT			
EMERGENCY <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		HAS STATE OFFICE OF EMERGENCY SERVICES REPORT BEEN FILED? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
REPORT DATE 6/27/2007		CASE #	
FOR LOCAL AGENCY USE ONLY I HEREBY CERTIFY THAT I AM A DESIGNATED GOVERNMENT EMPLOYEE AND THAT I HAVE REPORTED THIS INFORMATION TO LOCAL OFFICIALS PURSUANT TO SECTION 25180.7 OF THE HEALTH AND SAFETY CODE.		SIGNED: [Signature] DATE: 7/6/07	
REPORTED BY	NAME OF INDIVIDUAL FILING REPORT IAN HULL		PHONE 510-420-3344
	SIGNATURE [Signature]		
REPRESENTING	<input type="checkbox"/> LOCAL AGENCY <input type="checkbox"/> REGIONAL BOARD <input checked="" type="checkbox"/> OWNER/OPERATOR <input type="checkbox"/> OTHER...		COMPANY OR AGENCY NAME CONESTOGA-ROVERS & ASSOCIATES
	ADDRESS 5900 HOLLIS STREET, SUITE A. EMERYVILLE CA 94608		
RESPONSIBLE PARTY	NAME CHEVRON ENVIRONMENTAL MANAGEMENT COMPANY <input type="checkbox"/> Unknown		PHONE SATYA SINHA 925-842-9876
	ADDRESS 6001 BOLINGER CANYON ROAD SAN RAMON CA 94583		
SITE LOCATION	FACILITY NAME (IF APPLICABLE) FORMER STANDARD OIL #30-7233		OPERATOR
	ADDRESS 2259 FIRST STREET LIVERMORE ALAMEDA 94550		PHONE
	CROSS STREET LIVERMORE AVENUE		
IMPLEMENTING AGENCIES	LOCAL AGENCY AGENCY NAME Livermore-Pleasanton Fire Department - John Rigter		PHONE 925-454-2357
	REGIONAL BOARD SF-RWQCB		PHONE 510-622-2300
SUBSTANCES INVOLVED	(1) NAME UNKNOWN		QUANTITY LOST (GALLONS) <input checked="" type="checkbox"/> Unknown
	(2) <input type="checkbox"/> Unknown		
DISCOVERY/ABATEMENT	DATE DISCOVERED 6/20/2007	HOW DISCOVERED <input type="checkbox"/> Tank Test <input checked="" type="checkbox"/> Tank Removal <input type="checkbox"/> Nuisance Conditions <input type="checkbox"/> Inventory Control <input type="checkbox"/> Subsurface Monitoring <input type="checkbox"/> Other...	
	DATE DISCHARGE BEGAN	METHOD USED TO STOP DISCHARGE (CHECK ALL THAT APPLY) <input checked="" type="checkbox"/> Unknown <input checked="" type="checkbox"/> Remove Contents <input checked="" type="checkbox"/> Close Tank <input type="checkbox"/> Repair Tank <input type="checkbox"/> Change Procedure <input type="checkbox"/> Replace Tank <input checked="" type="checkbox"/> Other... <input type="checkbox"/> Repair Piping	
	HAS DISCHARGE BEEN STOPPED? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No IF YES, DATE 06/20/2007	Remove Tank	
SOURCE/ CAUSE	SOURCE OF DISCHARGE <input checked="" type="checkbox"/> Tank Leak <input type="checkbox"/> Piping Leak <input type="checkbox"/> Unknown <input type="checkbox"/> Other...		CAUSE(S) <input type="checkbox"/> Overfill <input type="checkbox"/> Corrosion <input type="checkbox"/> Rupture/Failure <input checked="" type="checkbox"/> Unknown <input type="checkbox"/> Spill <input type="checkbox"/> Other...
	CHECK ONE ONLY <input checked="" type="checkbox"/> Undetermined <input type="checkbox"/> Soil Only <input type="checkbox"/> Groundwater <input type="checkbox"/> Drinking Water - (CHECK ONLY IF WATER WELLS HAVE ACTUALLY BEEN AFFECTED)		
CURRENT STATUS	CHECK ONE ONLY <input type="checkbox"/> No Action Taken <input type="checkbox"/> Case Closed (Cleanup Completed or Unnecessary) <input checked="" type="checkbox"/> Leak Being Confirmed <input type="checkbox"/> Pollution Characterization <input type="checkbox"/> Remediation Plan <input type="checkbox"/> Post Cleanup Monitoring in Progress <input type="checkbox"/> Preliminary Site Assessment Workplan Submitted <input type="checkbox"/> Cleanup Underway <input type="checkbox"/> Preliminary Site Assessment Underway		
	CHECK APPROPRIATE ACTION(S) <input type="checkbox"/> Cap Site (CD) <input type="checkbox"/> Excavate & Treat (ET) <input type="checkbox"/> Treatment at Hookup (HU) <input checked="" type="checkbox"/> Other... Site Assessment <input type="checkbox"/> Contamination Barrier (CB) <input type="checkbox"/> No Action Required (NA) <input type="checkbox"/> Enhanced Bio Degradation (IT) <input type="checkbox"/> Vacuum Extract (VE) <input type="checkbox"/> Remove Free Product (FP) <input type="checkbox"/> Replace Supply (RS) <input checked="" type="checkbox"/> Excavate & Dispose (ED) <input type="checkbox"/> Pump & Treat Groundwater (GT) <input type="checkbox"/> Vent Soil (VS)		
COMMENTS	A previous URF was submitted by the City of Livermore on 09/21/00 for an orphan tank found in the vicinity. We believe the tanks are connected and want to clarify the owner of the previous excavated orphan tank.		