

FINAL CLOSURE REPORT FOR UNDERGROUND
STORAGE TANK REMOVAL

October 14, 1996

for

City of Pleasanton

3200 Santa Rita Road
Pleasanton Ca. 94559
510 484-8067

primary contact / project manager:

Leland Yialelis

Contractor:

W. A. Craig, Inc.
P. O. Box 448
Napa, California 94559
(707) 252-3353

Contractor License #455752 - A, B, and Hazardous Materials
(copies attached)

Workman's Compensation: Policy #NWC 254067
(exp. date March 29, 1997)
(copies attached)

RECEIVED

OCT 31 1996

PLEASANTON FIRE DEPARTMENT



TANK REMOVAL INFORMATION

Date: September 12, 1996

Reason for removal: The tanks were no longer in use.

Tank Transporter: **Erickson, Inc.**
255 Parr Boulevard
Richmond, California 94801
Phone: (510) 235-1393
EPA #: CAD 009466392

Disposal of Tank: Tank shipped to:

Erickson, Inc.
255 Parr Boulevard
Richmond, California 94801
Phone: (510) 235-1393
EPA #: CAD 009466392

This is a licensed T. S. D. F. Facility. (See attached for documentation of disposal)

Soil sample processing: Soil samples were analyzed by:

McCampbell Analytical
110 2nd Ave. South
Pacheco, Ca. 94553
State Certification #: 1644

(note: sample processing and associated method preparation numbers are noted on the lab results which are attached.)

Location of the tank: The tanks were located at City of Pleasanton, 3200 Santa Rita Road, Pleasanton, CA. A map is attached which shows the location of the tanks and associated underground piping as well as, streets, north direction, and buildings on site.

Sampling: Soil sampling was performed by Russ Gentry, as requested by the representative of City of Pleasanton. Four (4) samples were taken, two (2) samples of the soil in the stockpile and one (1) samples of the soil was taken below the gasoline tank at a depth of approximately 9.5 feet and one (1) sample was taken from south sidewall of the excavation area at approximately 4 feet.

Sampling methodology: The soil samples were obtained by driving clean brass tubes (2 x 6) into native soil which was excavated from the tank pit and the soil in the stockpile. The tubes were driven by using a wooden mallet. The tubes were then sealed with aluminum foil, plastic end caps, and the tubes were placed in a zip lock plastic bag. The samples were labeled, placed on ice, and were transported to a state certified lab for processing. A chain of custody form was maintained for the samples, a copy of which is attached.

Soil Sample Analyses:

Samples taken at time of tank removal:

The soil samples were labeled:

SW-S-4'	soil sample from the excavation area
SP-C	soil sample from the stockpile
SP-S	soil sample from the stockpile
PB-G-9.5'	soil sample from the excavation area

Summary of analyses of soil samples:

	<u>TPH(g)</u>	<u>MTBE</u>	<u>Benzene</u>	<u>Toulene</u>	<u>Ethyl Benzene</u>	<u>Xylenes</u>
SW-S-4'	150	--	ND<0.02	ND<0.02	0.88	1.8
SP-C	11	--	ND	ND	ND	0.042
SP-S	190	--	ND	0.035	0.37	2.5
PB-G-9.5'	1.8	--	ND	ND	ND	0.025

	<u>TPH-d</u>
SW-S-4'	2800
SP-C	84
SP-S	1900
PB-G-9.5'	29

Disposal of stockpile: It is recommended that the stockpile be profiled, hauled, and disposed of at a licensed disposal facility .

SPECIFIC INFORMATION REGARDING THE TANKS

Tank # 1:

Size/capacity: 500 gallons

Former contents of the tank: diesel

Construction of the tank: single walled steel.

Age of the tank: unknown.

Condition of the tank upon removal: The tank was found to be in good condition, no holes were found in the tank.

Material sampled: soil

Tank # 2:

Size/capacity: 500 gallons

Former contents of the tank: gasoline

Construction of the tank: single walled steel.

Age of the tank: unknown.

Condition of the tank upon removal: The tank was found to be in good condition, no holes were found in the tank.

Material sampled: soil

The pipes to the dispensers (both diesel and gas) had holes in them (1/2" - 1" holes).

CONCLUSIONS AND RECOMMENDATIONS:

The soil samples from the tank pits were tested for TPH-g gasoline, TPH-d diesel, and BTEX. Our recommendation is further excavation in the bottom and the sidewalls of the tank area to remove any further soil containing petroleum hydrocarbons. Soil will be stockpiled on site, on plastic sheeting and covered with plastic sheeting. Soil samples will be taken and analyzed, stockpiled soil will be disposed at a licensed disposal facility.

I Declare under penalty of perjury that the foregoing information is true and correct.

Executed October 14, 1996.

Nature of Business: Environmental Construction

Name of Business W. A. Craig, Inc.

Address of Business: P. O. Box 448,
Napa, California 94559


Printed name and title of applicant:

W. A. Craig, II
Owner/ R.E.A. #01414 (exp. 6-1997)

Signature of applicant:

Date:

10-17-96



Reportage




Copies of the sampling report, the chain of custody, and the certified analysis data sheets will be submitted to the appropriate agencies as follows:

Chris Boykin
City of Pleasanton, Hazardous Materials Division
3333 Railroad Avenue
Pleasanton, CA.

MAPS

Mon. Sep 10

Santa Rita Rd




Pipe from low area to drain



West Las Positas Blvd

56'



SP-C
SP-S

4 samples collected
P.B.-G-9 1/2'
South S.W.-D-4'
S.P.-C
S.P.-S

Parking

Fence

Fence

ANALYSES / CHAIN-OF-CUSTODY

7171 PAID * 9348

PROJECT NO. 3620		PROJECT NAME Pleasanton, City of Sta. 1 Sta. 3		MATRIX: Soil, Water, Air, Sludge, Other	ANALYSIS						REMARKS	LABORATORY I. D. NUMBER
PURCHASE ORDER NO.		SIGNATURE OF SAMPLER Russell Scott			TPHgasoline (8015)	BTEX (602/8020)	TPHdiesel (8015)	TPHg & BTEX				
DATE	TIME	W. A. CRAIG, INC.'S SAMPLE IDENTIFICATION										
9/12	2:00	PB-D-7'		S		✓	✓			ICE		68944
	2:07	PB-G-7.5'										68945
	2:12	SP										68946
	3:15	PB-D-7.5' SW-S-4'										68947
	3:22	SP-C										68948
✓	3:26	SP-S		↓		↓	↓			↓		68949
	3:10	PB-G-9 1/2'		↓		↓	↓			↓		68950

✓
✓
✓
✓
✓
✓
✓
✓

✓
✓
✓
✓
✓
✓
✓
✓

UNLOADED BY (Signature): Russell Scott	DATE/TIME 9/12/96 4:50	RECEIVED BY (Signature): [Signature]
UNLOADED BY (Signature):	DATE/TIME	RECEIVED BY (Signature):
UNLOADED BY (Signature):	DATE/TIME	RECEIVED BY (Signature):

LABORATORY:
McCoybell
Analytical
TURNAROUND
TIME:
5-day

PLEASE SEND RESULTS TO:
W. A. CRAIG, INC.
P.O. BOX 448
NAPA, CA 94559-0448
(707) 252-3353
paid chk # 9348
ATTN:

McCAMPBELL ANALYTICAL INC.

110 2nd Avenue South, #D7, Pacheco, CA 94553

Tele: 510-798-1620 Fax: 510-798-1622

W.A. Craig, Inc. P.O. Box 448 Napa, CA 94559-0448	Client Project ID: City of Pleasanton; # 3620	Date Sampled: 09/12/96
		Date Received: 09/12/96
	Client Contact: Bill Craig	Date Extracted: 09/12/96
	Client P.O.:	Date Analyzed: 09/12-09/13/96

Gasoline Range (C6-C12) Volatile Hydrocarbons as Gasoline*, with Methyl tert-Butyl Ether* & BTEX*
 EPA methods 5030, modified 8015, and 8020 or 602; California RWQCB (SF Bay Region) method GCFID(5030)

Lab ID	Client ID	Matrix	TPH(g) ⁺	MTBE	Benzene	Toluene	Ethylbenzene	Xylenes	% Rec. Surrogate
68944	PB-D-7'	S	ND	---	ND	ND	ND	ND	105
68945	PB-G-7.5'	S	ND	---	ND	ND	ND	ND	102
68946	SP	S	ND	---	ND	ND	ND	0.008	106
68947	SW-S-4'	S	150,g	---	ND < 0.02	ND < 0.02	0.88	1.8	97
68948	SP-C	S	11,g	---	ND	ND	ND	0.042	100
68949	SP-S	S	190,g	---	ND	0.035	0.37	2.5	100
68950	PB-G-9.5'	S	1.8,g	---	ND	ND	ND	0.025	95
Reporting Limit unless otherwise stated; ND means not detected above the reporting limit	W	50 ug/L	5.0	0.5	0.5	0.5	0.5	0.5	
	S	1.0 mg/kg	0.05	0.005	0.005	0.005	0.005	0.005	

* water and vapor samples are reported in ug/L, soil and sludge samples in mg/kg, and all TCLP extracts in mg/L

cluttered chromatogram; sample peak coelutes with surrogate peak

+ The following descriptions of the TPH chromatogram are cursory in nature and McCampbell Analytical is not responsible for their interpretation: a) unmodified or weakly modified gasoline is significant; b) heavier gasoline range compounds are significant(aged gasoline?); c) lighter gasoline range compounds (the most mobile fraction) are significant; d) gasoline range compounds having broad chromatographic peaks are significant; biologically altered gasoline?; e) TPH pattern that does not appear to be derived from gasoline (?); f) one to a few isolated peaks present; g) strongly aged gasoline or diesel range compounds are significant; h) lighter than water immiscible sheen is present; i) liquid sample that contains greater than ~ 5 vol. % sediment; j) no recognizable pattern.

McCAMPBELL ANALYTICAL INC.

110 2nd Avenue South, #D7, Pacheco, CA 94553
 Tele: 510-798-1620 Fax: 510-798-1622

QC REPORT FOR HYDROCARBON ANALYSES

Date: 09/13/96

Matrix: Soil

Analyte	Concentration (mg/kg) Sample (#67156)			Amount Spiked	% Recovery		
	MS	MSD			MS	MSD	RPD
TPH (gas)	0.000	1.745	1.807	2.03	86	89	3.5
Benzene	0.000	0.194	0.176	0.2	97	88	9.7
Toluene	0.000	0.204	0.184	0.2	102	92	10.3
Ethylbenzene	0.000	0.208	0.186	0.2	104	93	11.2
Xylenes	0.000	0.608	0.542	0.6	101	90	11.5
TPH (diesel)	0	294	307	300	98	102	4.2
TRPH (oil and grease)	N/A	N/A	N/A	N/A	N/A	N/A	N/A

$$\% \text{ Rec.} = (\text{MS} - \text{Sample}) / \text{amount spiked} \times 100$$

$$\text{RPD} = (\text{MS} - \text{MSD}) / (\text{MS} + \text{MSD}) \times 2 \times 100$$

CERTIFICATES OF DISPOSAL

DAY OR NIGHT
TELEPHONE
(510) 235-1393

CERTIFICATE CERTIFIED SERVICES COMPANY

265 Parr Boulevard - Richmond, California 94801

NO. 16234

CUSTOMER W. A. CRAIG ASSO
JOB NO. 969114

FOR: ERICKSON, INC. TANK NO. 18802

LOCATION: RICHMOND DATE: 96/10/02 TIME: 12:00

TEST METHOD VISUAL GASTECH/1314 SMPN LAST PRODUCT D

This is to certify that I have personally determined that this tank is in accordance with the American Petroleum Institute and have found the condition to be in accordance with its assigned designation. This certificate is based on conditions existing at the time the inspection herein set forth was completed and is issued subject to compliance with all qualifications and instructions.

TANK SIZE 500 GALLON TANK CONDITION SAFE FOR FIRE

REMARKS: OXYGEN 20.9% LOWER EXPLOSIVE LIMIT LESS THAN 0.1%
ERICKSON, INC. HEREBY CERTIFIES THAT THE ABOVE NUMBERED TANK HAS BEEN
PROCESSED, AND THEREFORE DESTROYED AT OUR PERMITTED HAZARDOUS
WASTE FACILITY.
ERICKSON, INC. HAS THE APPROPRIATE PERMITS FOR, AND HAS ACCEPTED THE TANK
SHIPPED TO US FOR PROCESSING.

In the event of any physical or atmospheric changes affecting the gas-free conditions of the above tanks, or if in any doubt, immediately stop all hot work and contact the undersigned. This permit is valid for 24 hours if no physical or atmospheric changes occur.

STANDARD SAFETY DESIGNATION

SAFE FOR MEN: Means that in the compartment or space so designated (a) The oxygen content of the atmosphere is at least 19.5 percent by volume; and that (b) Toxic materials in the atmosphere are within permissible concentrations; and (c) In the judgment of the Inspector, the residues are not capable of producing toxic materials under existing atmospheric conditions while maintained as directed on the Inspector's certificate.

SAFE FOR FIRE: Means that in the compartment so designated (a) The concentration of flammable materials in the atmosphere is below 10 percent of the lower explosive limit; and that (b) In the judgment of the Inspector, the residues are not capable of producing a higher concentration that permitted under existing atmospheric conditions in the presence of fire and while maintained as directed on the Inspector's certificate, and further, (c) All adjacent spaces have either been cleaned sufficiently to prevent the spread of fire, are satisfactorily inerted, or in the case of fuel tanks, have been treated as deemed necessary by the Inspector.

The undersigned representative acknowledges receipt of this certificate and understands the conditions and limitations under which it was issued.

W. A. Craig
REPRESENTATIVE

TITLE

Dave Sato
INSPECTOR

DAY OR NIGHT
TELEPHONE
(510) 235-1393

CERTIFICATE
CERTIFIED SERVICES COMPANY
255 Parr Boulevard • Richmond, California 94801

NO. 1623

CUSTOMER
W. A. CRAIG ASSO
JOB NO.
969114

FOR: ERICKSON, INC. TANK NO. 18802

LOCATION: RICHMOND DATE: 96/10/02 TIME: 12:00

TEST METHOD VISUAL GASTECH/1314 SMPN LAST PRODUCT D

This is to certify that I have personally determined that this tank is in accordance with the American Petroleum Institute and have found the condition to be in accordance with its assigned designation. This certificate is based on conditions existing at the time the inspection herein set forth was completed and is issued subject to compliance with all qualifications and instructions.

TANK SIZE 500 GALLON TANK CONDITION SAFE FOR FIRE

REMARKS: OXYGEN 20.9% LOWER EXPLOSIVE LIMIT LESS THAN 3.1%
ERICKSON, INC. HEREBY CERTIFIES THAT THE ABOVE NUMBERED TANK HAS BEEN
TESTED, PROCESSED, AND THEREFORE DESTROYED AT OUR PERMITTED HAZARDOUS
WASTE FACILITY.
ERICKSON, INC. HAS THE APPROPRIATE PERMITS FOR, AND HAS ACCEPTED THE TANK
SHIPPED TO US FOR PROCESSING.

In the event of any physical or atmospheric changes affecting the gas-free conditions of the above tanks, or if in any doubt, immediately stop all hot work and contact the undersigned. This permit is valid for 24 hours if no physical or atmospheric changes occur.

STANDARD SAFETY DESIGNATION

SAFE FOR MEN: Means that in the compartment or space so designated (a) The oxygen content of the atmosphere is at least 19.5 percent by volume; and that (b) Toxic materials in the atmosphere are within permissible concentrations; and (c) In the judgment of the Inspector, the residues are not capable of producing toxic materials under existing atmospheric conditions while maintained as directed on the Inspector's certificate.

SAFE FOR FIRE: Means that in the compartment so designated (a) The concentration of flammable materials in the atmosphere is below 10 percent of the lower explosive limit; and that (b) In the judgment of the Inspector, the residues are not capable of producing a higher concentration that permitted under existing atmospheric conditions in the presence of fire and while maintained as directed on the Inspector's certificate, and further, (c) All adjacent spaces have either been cleaned sufficiently to prevent the spread of fire, are satisfactorily inerted, or in the case of fuel tanks, have been treated as deemed necessary by the Inspector.

The undersigned representative acknowledges receipt of this certificate and understands the conditions and limitations under which it was issued.

[Signature]
REPRESENTATIVE

TITLE

[Signature]
INSPECTOR

PERMITS

**City of Pleasanton Fire Department
Closure Permit**

Permit # CP-96-002 Effective Date: 9/5/96 Expiration Date: 10/5/96

Under the provisions of the Uniform Fire Code of the City of Pleasanton, a permit is granted for the following activity:

Permit Issued to: W. A. Craig
Contact Person: Diane Loren Phone # 707-252-3353
Site Facility: Flra. Stations #1 & 3
Site Address: 444 Railroad Rd. & 3200 Santa Rita Rd.

This permit does not take the place of any license required by law and is not transferrable. Any change in the use, occupancy, or plans shall require a new or modified permit.
This permit is issued and accepted on condition that all provisions of the currently adopted edition of the Uniform Fire Code of the City of Pleasanton be complied with. Any violations of the provisions may be grounds for the revocation of this permit.

Additional Comments:

Must be removed in accordance with approved closure plan. Any modifications to plan must be pre-approved.

C. ita Dyer
Authorized Signature

9-5-96
Date

THIS PERMIT MUST BE KEPT POSTED AT ALL TIMES ON THE PREMISES MENTIONED ABOVE

Fee/ paid/ for/ plan/ review
and permh/ / \$239 /

FEEES WAIVED PER CONTRACT

Post-It™ brand fax transmittal memo 7671 # of pages 1
To DIANE From DOROTHY
Co. Co.



BAY AREA AIR QUALITY MANAGEMENT DISTRICT

939 ELLIS STREET
SAN FRANCISCO, CALIFORNIA 94109
(415) 771-6000

REGULATION 8, RULE 40
Aeration of Contaminated Soil and
Removal of Underground Storage Tanks

NOTIFICATION FORM

- Removal or Replacement of Tanks
- Excavation of Contaminated Soil

SITE INFORMATION

SITE ADDRESS 3200 Santa Rita Rd and 4444 Railroad Ave.
 CITY, STATE, ZIP Pleasanton, CA. 94566
 OWNER NAME City of Pleasanton - (Contact Roger Kennedy)
 SPECIFIC LOCATION OF PROJECT 3200 Santa Rita Rd. and 4444 Railroad Ave., Pleasanton

TANK REMOVAL

CONTAMINATED SOIL EXCAVATION

SCHEDULED STARTUP DATE 8-27-96

SCHEDULED STARTUP DATE _____

VAPORS REMOVED BY:

STOCKPILES WILL BE COVERED? YES _____ NO _____

WATER WASH

ALTERNATIVE METHOD OF AERATION (DESCRIBE BELOW):

VAPOR FREEING (CO²)

VENTILATION

(MAY REQUIRE PERMIT)

CONTRACTOR INFORMATION

NAME W. A. Craig, Inc. CONTACT Steve Hardister
 ADDRESS P. O BOX 448 PHONE (707) 252-3353
 CITY, STATE, ZIP Napa, CA, 94559

CONSULTANT INFORMATION (IF APPLICABLE)

NAME _____ CONTACT _____
 ADDRESS _____ PHONE () _____
 CITY, STATE, ZIP _____

FOR OFFICE USE ONLY

DATE RECEIVED _____ BY _____ (INIT.) _____
 CC: INSPECTOR NO. _____ DATE _____ BY _____ (INIT.) _____
 TELEPHONE UPDATE: CALLER _____ CHANGE MADE _____
 BAAQMD N # _____

LICENSES / INSURANCE

CONTRACTORS STATE LICENSE BOARD

No. 455752

Building Quality

ISSUED 04-29-84

This license is the property of the Registrar of Contractors, is not transferable, and shall be returned to the Registrar upon demand when suspended, revoked, or invalidated for any reason. It becomes void if not renewed.


Contractor's License

Pursuant to the provisions of Chapter 9 of Division 3 of the Business and Professions Code and the Rules and Regulations of the Contractors State License Board, the Registrar of Contractors does hereby issue this license to:

CRAIG W A IAC

to engage in the business or act in the capacity of a contractor in the following classification(s):
A GENERAL ENGINEERING CONTRACTOR

WITNESS my hand and sealed this
1ST day of MAY 1984.



STATE AND CONSUMER SERVICES AGENCY
DEPARTMENT OF CONSUMER AFFAIRS

J. M. Aloney
Registrar of Contractors

[Signature]
Signature of Licensee

[Signature]
Signature of person who qualified on behalf of the licensee

PERMIT

Permit Issued To

(Insert Employer's Name, Address and Telephone No.)

W. A. CRAIG INC
 10 CASE CT
 AMERICAN CANYON, CA 94589
 (707) 252-3353

No. Headquarters
 Date 12/8/95
 Region 1
 District 5
 Tel. (707) 576-2388

Type of Permit T1-ANNUAL TRENCH/EXCAVATION

Pursuant to Labor Code Sections 6500 and 6502, this Permit is issued to the above-named employer for the projects described below.

State Contractor's License Number		455752	Permit Valid through		December 31, 1996
Description of Project	Location Address	City and County	Anticipated Dates		
			Starting	Completion	
Various	Statewide		1/1/96	12/31/96	

This Permit is issued upon the following conditions:

1. That the work is performed by the same employer. If this is an annual permit the appropriate District Office shall be notified, in writing, of dates and location of job site prior to commencement.
2. The employer will comply with all occupational safety and health standards or orders applicable to the above projects, and any other lawful orders of the Division.
3. That if any unforeseen condition causes deviation from the plans or statements contained in the Permit Application Form the employer will notify the Division immediately.
4. Any variation from the specification and assertions of the Permit Application Form or violation of safety orders may be cause to revoke the permit.
5. This permit shall be posted at or near each place of employment as provided in 8 CCR 341.4

Received From	Received By	
DELANO YIALELIS	Bob Low	
<input type="checkbox"/> Cash	Amount	Date
<input checked="" type="checkbox"/> Check 7846	\$100.00	12/8/95

Investigated by _____
 Safety Engineer
 Date _____

Approved by M. Raw
 Permit Unit
 Date 12/11/95



Building Quality



HAZARDOUS SUBSTANCES REMOVAL AND REMEDIAL ACTIONS CERTIFICATION

Pursuant to the provisions of Section 7058.7 of the Business and Professions Code, the Registrar of Contractors does hereby certify that the following qualifying person has successfully completed the hazardous substances removal and remedial actions examination.



Qualifier: WILLIAM ALEXANDER CRAIG II
License No.: 455752
Namestyle: W. A. CRAIG, INC.

WITNESS my hand and official seal this
6 day of SEPTEMBER, 1988

J. M. Along
Registrar of Contractors

13L-36 (1/88)


This certification is the property of the Registrar of Contractors, is not transferable, and shall be returned to the Registrar upon demand when suspended, revoked, or invalidated for any reason.

A1571

CERTIFICATE OF INSURANCE

Producer: LIA/ENVIRONMENTAL PROFESSIONALS INSURANCE TRUST P O BOX 1319 SANTA BARBARA, CA 93102-1319	Issue Date: 8/7/1996 This Certificate is issued as a matter of information only and confers no rights upon the Certificate Holder. This Certificate does not amend, extend or alter the coverage afforded by the policy below.
---	--

Insured: W A CRAIG, INC P O BOX 448 NAPA, CA 94559-0448	<p align="center"><u>COMPANY AFFORDING COVERAGE</u></p> <p align="center">AMERICAN SAFETY RISK RETENTION GROUP, INC. 1845 The Exchange, Suite 200 Atlanta, Georgia 30339</p>
--	--



TYPE OF INSURANCE	POLICY NUMBER	EFFECTIVE DATE	EXPIRATION DATE	LIMITS
Commercial General Liability Claims-Made	AST185107-0	07/29/1996	07/29/1997	General Aggregate \$ 2,000,000 Products Comp/Op Aggregate . \$ 2,000,000 Personal & Adv. Injury \$ 2,000,000 Each Occurrence \$ 2,000,000 Fire Damage (any one fire) . . \$ 50,000 Med. Expense (any one person) \$ 5,000
Professional Liability Endorsement # <u>ASR063 10 94</u>	INCL			
Pollution Liability Endorsement # <u>ASR061 10 94</u>	INCL			

Description of Operations/Locations/Special Items:

[This section is mostly blank or contains illegible text.]

Certificate Holder: <p align="center">FOR INFORMATION PURPOSES ONLY</p>	Cancellation: Should the above described policy be cancelled before the expiration date thereof, the issuing company will endeavor to mail 30 days written notice (10 days if cancelled for non-payment of premium) to the Certificate Holder named to the left. But failure to mail such notice shall impose no obligation or liability of any kind upon the Company, its Agents or Representatives.
---	---

Signature: Lloyd Fox
 Company's Representative

Insured Copy

ACORD CERTIFICATE OF INSURANCE

ISSUE DATE (MM/DD/YY)

4/2/1996

PRODUCER

Rogers & Young Insurance
 1558 Round Barn Blvd. Ste.#203
 Santa Rosa, CA 95403
 (707) 579-5200

THIS CERTIFICATE IS ISSUED AS A MATTER OF INFORMATION ONLY AND CONFERS NO RIGHTS UPON THE CERTIFICATE HOLDER. THIS CERTIFICATE DOES NOT AMEND, EXTEND OR ALTER THE COVERAGE AFFORDED BY THE POLICIES BELOW.

COMPANIES AFFORDING COVERAGE

- COMPANY LETTER A Golden Eagle Insurance Company
- COMPANY LETTER B
- COMPANY LETTER C
- COMPANY LETTER D
- COMPANY LETTER E

INSURED

N. A. Craig, Inc.
 P. O. Box 448
 Napa CA 94559

OVERVIEW

THIS IS TO CERTIFY THAT THE POLICIES OF INSURANCE LISTED BELOW HAVE BEEN ISSUED TO THE INSURED NAMED ABOVE FOR THE POLICY PERIOD INDICATED, NOTWITHSTANDING ANY REQUIREMENT, TERM OR CONDITION OF ANY CONTRACT OR OTHER DOCUMENT WITH RESPECT TO WHICH THIS CERTIFICATE MAY BE ISSUED OR MAY PERTAIN, THE INSURANCE AFFORDED BY THE POLICIES DESCRIBED HEREIN IS SUBJECT TO ALL THE TERMS, EXCLUSIONS AND CONDITIONS OF SUCH POLICIES. LIMITS SHOWN MAY HAVE BEEN REDUCED BY PAID CLAIMS.

TYPE OF INSURANCE	POLICY NUMBER	POLICY EFFECTIVE DATE (MM/DD/YY)	POLICY EXPIRATION DATE (MM/DD/YY)	LIMITS
GENERAL LIABILITY				GENERAL AGGREGATE \$
COMMERCIAL GENERAL LIABILITY				PRODUCTS-COMP/OP AGG. \$
CLAIMS MADE OCCUR				PERSONAL & ADV. INJURY \$
OWNERS & CONTRACTORS PILOT				EACH OCCURRENCE \$
				FIRE DAMAGE (Any one fire) \$
				MED. EXPENSE (Any one person) \$
AUTOMOBILE LIABILITY				COMBINED SINGLE LIMIT \$
ANY AUTO				BODILY INJURY (Per person) \$
ALL OWNED AUTOS				BODILY INJURY (Per accident) \$
SCHEDULED AUTOS				PROPERTY DAMAGE \$
HIRED AUTOS				EACH OCCURRENCE \$
NON-OWNED AUTOS				AGGREGATE \$
GARAGE LIABILITY				<input checked="" type="checkbox"/> STATUTORY LIMITS
EXCESS LIABILITY				EACH ACCIDENT \$ 1,000,000
UMBRELLA FORM				DISEASE - POLICY LIMIT \$ 1,000,000
OTHER THAN UMBRELLA FORM				DISEASE - EACH EMPLOYEE \$ 1,000,000
WORKER'S COMPENSATION AND EMPLOYERS' LIABILITY	NWC367064-02	03/29/96	03/29/97	
OTHER				

DESCRIPTION OF OPERATION/LOCATION/VEHICLES/SPECIAL ITEMS
 Re: License #455752

Cancellation: Except for non-payment of premium or non-reporting of payroll, in which case a ten day notice shall apply.

CERTIFICATE HOLDER

Contractor's State License Board
 P. O. Box 26000
 Sacramento CA 95826

CANCELLATION

SHOULD ANY OF THE ABOVE DESCRIBED POLICIES BE CANCELLED BEFORE THE EXPIRATION DATE THEREOF, THE ISSUING COMPANY WILL ENDEAVOR TO MAIL 30 DAYS WRITTEN NOTICE TO THE CERTIFICATE HOLDER NAMED TO THE LEFT, BUT FAILURE TO MAIL SUCH NOTICE SHALL IMPOSE NO OBLIGATION OR LIABILITY OF ANY KIND UPON THE COMPANY, ITS AGENTS OR REPRESENTATIVES

AUTHORIZED REPRESENTATIVE