


# UNDERGROUND STORAGE TANK (UST) SITE - UNAUTHORIZED RELEASE / CONTAMINATION REPORT

EMERGENCY <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	HAS STATE OFFICE OF EMERGENCY SERVICES REPORT BEEN FILED? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	<b>FOR LOCAL AGENCY USE ONLY</b> I HEREBY CERTIFY THAT I AM A DESIGNATED GOVERNMENT EMPLOYEE AND THAT I HAVE REPORTED THIS INFORMATION TO LOCAL OFFICIALS PURSUANT TO SECTION 25180.7 OF THE HEALTH AND SAFETY CODE.  SIGNED _____ DATE _____	
REPORT DATE 10/23/2013	CASE # RWQCB SL0600101555		
REPORTED BY	NAME OF INDIVIDUAL FILING REPORT <b>James Green</b>		PHONE (925) 949-1016
	REPRESENTING <input type="checkbox"/> LOCAL AGENCY <input type="checkbox"/> REGIONAL BOARD <input type="checkbox"/> OWNER/OPERATOR <input checked="" type="checkbox"/> OTHER		SIGNATURE  COMPANY OR AGENCY NAME <b>Haley &amp; Aldrich, Inc.</b>
	ADDRESS <b>2033 North Main Street, Suite 309</b> Walnut Creek CA 94596 <small>STREET CITY STATE ZIP</small>		
RESPONSIBLE PARTY	NAME <b>USL Pleasanton Lakes, L.P.</b>	CONTACT PERSON <b>Debbie Patterson</b> <input type="checkbox"/> Unknown	
	ADDRESS <b>100 Waugh, Suite 600</b> Houston TX 77007 <small>STREET CITY STATE ZIP</small>		
SITE LOCATION	FACILITY NAME (IF APPLICABLE) <b>Former Hanson Aggregates Radum Facility</b>		OPERATOR <b>N/A</b>
	ADDRESS <b>3000 Busch Road</b> Pleasanton Alameda 94588 <small>STREET CITY COUNTY ZIP</small>		
	CROSS STREET <b>Valley Road</b>		
IMPLEMENTING AGENCIES	LOCAL AGENCY AGENCY NAME <b>Livermore-Pleasanton Fire Department c/o John Rigter</b>		PHONE <b>(925) 454-2333</b>
	REGIONAL BOARD <b>Northern California Regional Water Quality Control Board</b>		PHONE ( )
SUBSTANCES INVOLVED	(1) NAME		QUANTITY LOST (GALLONS)
	<b>Diesel (TPHd)</b>		<input checked="" type="checkbox"/> Unknown
	(2) NAME		QUANTITY LOST (GALLONS)
	<b>Motor Oil (TPHmo)</b>		<input checked="" type="checkbox"/> Unknown
DISCOVERY/ABATEMENT	DATE DISCOVERED <b>10/9/2013</b>	HOW DISCOVERED <input type="checkbox"/> Tank Test <input type="checkbox"/> Tank Removal <input checked="" type="checkbox"/> Nuisance Conditions <input type="checkbox"/> Inventory Control <input type="checkbox"/> Subsurface Monitoring <input checked="" type="checkbox"/> Other	
	DATE DISCHARGE BEGAN <b>NA</b> <input checked="" type="checkbox"/> Unknown	METHOD USED TO STOP DISCHARGE (CHECK ALL THAT APPLY) <input type="checkbox"/> Remove Contents <input type="checkbox"/> Close Tank <input type="checkbox"/> Repair Tank <input type="checkbox"/> Change Procedure <input type="checkbox"/> Replace Tank <input checked="" type="checkbox"/> Other <input type="checkbox"/> Repair Piping	
	HAS DISCHARGE BEEN STOPPED? <input type="checkbox"/> Yes <input type="checkbox"/> No    IF YES, DATE <b>UNKNOWN</b>		
SOURCE/CAUSE	SOURCE OF DISCHARGE		CAUSE(S)
	<input checked="" type="checkbox"/> Tank <input type="checkbox"/> Piping <input type="checkbox"/> Dispenser <input type="checkbox"/> Delivery Problem <input type="checkbox"/> Submersible Turbine Pump (STP) <input type="checkbox"/> Other		<input type="checkbox"/> Spill <input type="checkbox"/> Overfill <input type="checkbox"/> Physical/Mechanical Damage <input type="checkbox"/> Corrosion <input type="checkbox"/> Installation Problem <input checked="" type="checkbox"/> Unknown <input type="checkbox"/> Other
CASE TYPE	CHECK ONE ONLY <input checked="" type="checkbox"/> Undetermined <input type="checkbox"/> Soil Only <input type="checkbox"/> Groundwater <input type="checkbox"/> Drinking Water -- (CHECK ONLY IF WATER WELLS HAVE ACTUALLY BEEN AFFECTED)		
CURRENT STATUS	CHECK ONE ONLY <input type="checkbox"/> Open - Site Assessment <input type="checkbox"/> Open - Verification Monitoring <input type="checkbox"/> Open - Assessment & Interim Remedial Action <input type="checkbox"/> Open - Inactive <input checked="" type="checkbox"/> Open - Remediation <input type="checkbox"/> Closed - No Further Action Required		
REMEDIAL ACTION	CHECK APPROPRIATE ACTION(S) Human health exposure control? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Unknown Groundwater migration control? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Unknown		
	<input type="checkbox"/> No Action Required (NAR) <input type="checkbox"/> Excavate & Treat (ET) <input type="checkbox"/> Treatment at Hookup (TH) <input type="checkbox"/> Other <input checked="" type="checkbox"/> Excavate & Dispose (ED) <input type="checkbox"/> Free Product Removal (FPR) <input type="checkbox"/> Replace Supply (RS)		
COMMENTS	Tank has an outlet pipe/hole on the top of the tank that when exposed leaked a viscous material; sorbent material and socks were installed to stop the leak until the tank could be emptied and removed.		