



WESCO Laboratories

15 0 15 0 15 15
OCT - 8 1986

TETRA TECH INC
LAFAYETTE CALIF

Date: September 23, 1986

Client Job/P.O. #: 20-8154/0586

Client: Groundwater Technology

Date collected: 9-15-86

Submitted by: Eric

Date submitted: 9-15-86

Report to: Chuck Constock

& type of sample(s): 2 Water
6 Soil

WESCO Job #: GWT 8616

Lab No.	Client ID	Motor Fuel (mg/l)	Benzene (mg/l)	Toluene (mg/l)	Xylene (mg/l)	Fuel Type
5408	Water Monitor Well #1 - 9/15 @ 11:30	4.52	1.59	0.012	1.0	Gasoline
5409	Water Monitor Well #2 - 9/15 @ 11:45	< 0.05	0.009	< 0.001	< 0.001	Gasoline
Lab No.	Client ID	Motor Fuel (mg/kg)	Benzene (mg/kg)	Toluene (mg/kg)	Xylene (mg/kg)	Fuel Type
5410	Soil MW1-1 @ 4-1/2-5 feet	< 0.05	< 0.001	< 0.001	< 0.001	Gasoline
5411	Soil MW2-1 @ 4-1/2-5 feet	< 0.05	< 0.001	< 0.001	< 0.001	Gasoline
5412	Soil MW2-2 @ 9-1/2-10 feet	< 0.05	< 0.001	< 0.001	< 0.001	Gasoline
5413	Soil S1-1 @ 4-1/2-5 feet	< 0.05	< 0.001	< 0.001	0.022	Gasoline
5414	Soil S2-1 @ 4-1/2-5 feet	< 0.44	< 0.001	< 0.001	< 0.001	Aged Gas
5415	Soil S3-1 @ 4-1/2-5 feet	34	0.012	0.010	0.058	Aged Gas
	Detection Limit	0.050	0.001	0.001	0.001	Gasoline
	METHOD(S): Note 1					

NOTES:

Note 1 - EPA Methods 5020/8015/8020.

Michael White
Analytical Supervisor

Excavation Permit Granted _____ No. 8849

CITY OF OAKLAND

Permit to Excavate and Install, Repair, or Remove Inflammable Liquid Tanks. No. _____

Oakland, California, JANUARY 6, 1987 19__

PERMISSION IS HEREBY GRANTED TO install remove repair Gasoline tank and excavate commencing _____ feet inside _____ line

on the EAST side of TIDEWATER AVENUE Street Avenue _____ feet _____ of _____ Street Avenue

House No. 4575 TIDEWATER AVENUE Street Avenue Present Storage DIESEL FUEL

Owner ABE BREIGHT Address 4575 TIDEWATER AVENUE Phone 533-8575


Applicant ROY F. WESTON, INC. Address 1001 GALAXY WAY, CONCORD Phone _____

Dimension of street (sidewalk) surface to be disturbed 0 x 0 Number of Tanks 2 Capacity 10,000 Gallons, each.

Remarks _____

This Permit is granted in accordance with existing City Ordinances.
Owner hereby agrees to remove tanks on discontinuance of use or when notified by the City Authorities.
When installing, removing or repairing tanks, no open flame to be on or near premises.

Approved _____ Fire Marshal
Approved _____ Drainage Division Engineering Dept.



EXCAVATING PERMIT

Issued in accordance with Ord. No. 278 CMS, Sec. 6-2.64

_____ square feet of digging or removal granted.
The receipt of \$ _____ special deposit is hereby acknowledged.
GENERAL DEPOSIT. _____ **BUREAU OF PERMITS AND LICENSES.**

CERTIFICATE OF TANK AND EQUIPMENT INSPECTION

Inspected and passed on _____ 19__
By _____ Fire Marshal

Inspection Fee Paid _____ \$ 50.00 REC. # 110123
Received by B. LANGOSCH
FIRE PREVENTION BUREAU

NOTICE
Before Covering Tanks, Above Certificate Must Be Signed.
When ready for inspection notify Fire Prevention Bureau, 273-3851

THIS PERMIT MUST BE LEFT ON THE WORK AS AUTHORITY THEREFOR.