

SITE INSPECTION NOTES

CASE NO.: RO3078

SITE NAME: Ashland Youth Center

ADDRESS: 16301 East 14th Street, San Leandro

DATE: November 15, 2011

PARTICIPANTS:

Jerry Wickham, ACEH

Rob Weston, ACEH

Trip Miller, GSA TSD

Jacob Lee, Cornerstone Earth Group

We met at the site to check on the progress of excavation and two concrete structures encountered during grading. The following observations were made:

- The excavation was near final depth in most other areas of the site but had not reached final depth in the northern corner of the site.
- No unusual conditions had been encountered other than the two concrete structures.
- The concrete structure on the eastern end of the site had two chambers. Some water was observed in the structure. The structure appeared to be a rectangular concrete vault; its former use was not obvious. . The sides and bottom of the structure had not been excavated; therefore, it is not known whether the structure has inlets or outlets.
- The concrete structure in the western portion of the site may have a detached lid. A solvent odor was observed near the opening of the western structure. Its former use was also not obvious.
- Samples of the liquids from both vaults had been collected. Analytical results should be available on 11/16 and will be sent to Jerry Wickham by Peter Langtry.
- Whether a permit will be needed to remove the concrete structures will depend upon the results of the analyses.
- GSA would like to complete excavation and backfilling by next week.

Inspection notes by Jerry Wickham