



October 19, 2010

Mr. Robert Weston
Alameda County Health Care Services Agency
Environmental Health Services
1131 Harbor Bay Parkway, Rm 250
Alameda, CA 94502-6577

Job # 9172

**SUBJECT: CLOSURE REPORT FOR
UNDERGROUND STORAGE TANK**

**SITE: 50 E LEWELLING BOULEVARD
SAN LORENZO, CA 94580**

Dear Mr. Weston:

Golden Gate Tank Removal, Inc. is pleased to submit the attached report documenting the removal of underground storage tank (UST) from 50 E Lewelling Boulevard.

Please include us in the distribution of the notice of completion. Thank you for the opportunity to provide you with our services. If you have any questions, please call Tim Hallen or Joshua Alexander at (415) 512-1555.

Sincerely,
Golden Gate Tank Removal, Inc.

Tim Hallen
General Manager

cc: San Lorenzo Unified School District, c/o Karen Langmaid, 15510 Usher Street, San Lorenzo, CA 94580




TANK CLOSURE REPORT

50 E Lewelling Boulevard
San Lorenzo, CA 94580
Job No. 9172
September 16, 2010

Prepared For:

San Lorenzo Unified School District
c/o Karen Langmaid
15510 Usher Street
San Lorenzo, CA 94580





Tim Hallen
Registered Environmental Assessor 08006

TABLE OF CONTENTS

COVER SHEET

TABLE OF CONTENTS

| | |
|---|-----|
| 1. SITE LOCATION | 1 |
| 2. SITE HISTORY | 1 |
| 3. TANK REMOVAL | 1-2 |
| 4. TANK AND SOIL CONDITION | 2 |
| 5. TANK REMOVAL SAMPLING | 2 |
| 6. TANK SAMPLE LABORATORY ANALYSIS | 2 |
| 7. OVER-EXCAVATION, RE-SAMPLING & ANALYSIS | 2-3 |
| 8. WASTE MANAGEMENT & SOIL DISPOSAL | 3 |
| 9. PRESSURE TEST FILL, PRODUCT AND RETURN LINES | 3 |
| 10. SITE RESTORATION | 3 |
| 11. FINDINGS / RECOMMENDATION | 3-4 |

FIGURES

TABLE

ATTACHMENTS

1. SITE LOCATION

The subject property is San Lorenzo High School located at 50 E Lewelling Boulevard at the cross street of Ashland Avenue in San Lorenzo, California. Figure 1 attached shows the general site location.

2. SITE HISTORY

One underground storage tank (UST) containing diesel was located beneath the grade within the property line. The tank had a capacity of approximately 6,000 gallons, measuring approximately 16 feet in length by 8 feet in diameter, and was constructed of single wall bare steel. The fill port was located on the south end of the tank. The age of the tank is unknown. The owner had no prior knowledge of the tank nor is there any indication of previous site investigation activities. Figure 2 depicts the approximate location of the tank as well as nearby streets.

3. TANK REMOVAL

In August 2010, Golden Gate Tank Removal, Inc. (GGTR) applied for and obtained permits from the Alameda County Environmental Health Services (ACEHS) and Alameda County Fire Department (ACFD) prior to the UST removal operations. Copies of the permit documents are included as an attachment.

On August 16, 2010, GGTR mobilized its equipment and began work on the project. The overburden soil covering the tank was removed and placed upon and covered with visqueen in a protected and covered stockpile adjacent to the tank excavation. Field measurements indicate the bottom of the tank was 12 feet below grade (fbg). The subsurface product piping extending between the top of the tank and the foundation of the exterior building structure was cut at each end, drained of any residual product and removed from the excavation area. Exposed vent and fill pipes were removed; product lines were cut, drained and plugged.

As part of the removal operations, GGTR contracted Uniwaste Environmental to pump the residual product from the tank to a vacuum truck for transportation and disposal. GGTR then pressure-washed the interior of the tank with a 180-degree water using 3000-psi pressure. A non-toxic enzyme detergent was used to break down thick oil deposits. After a third washing, Uniwaste Environmental removed the wash and rinse water from the tank and transported the Non-RCRA hazardous waste liquid (600 gallons) under Uniform Hazardous Waste Manifest No.007267018JJK to the Clearwater Environmental facility in Silver Springs, Nevada. A copy of the liquid waste manifest is included as an attachment.

Prior to liquid disposal, GGTR collected a sample of the rinsate water and submitted it to Accutest Laboratories (State Certification#08258) under a formal Chain-of-Custody protocol. The rinsate sample was analyzed for Total Petroleum Hydrocarbons Extractable as Motor Oil (TPH-MO) and as Diesel (TPH-D) by Method SW846 8015B M SW846 3510C. (Historically Heating Oil has been various petroleum hydrocarbon mixtures from C9-C32; this includes Diesel and/or Motor Oil ranges. Therefore, TPH in either range could be Heating Oil). The analytical results of the rinsate sample were acceptable by the ACEHS for the disposal of the UST as non-hazardous scrap metal. The tank was also certified as non-hazardous waste under the California Code of Regulations, Title 22, Division 4.5, Chapter 32. The attached Table "Sampling Results Form" presents a summary of the analytical results. A copy of the laboratory certificate of analysis and chain of custody form and a copy of the Hazardous Waste Tank Closure Certification are included as attachments.

On August 18, 2010, upon the approval of Mr. Robert Weston of the ACEHS and Rich Enright of the ACFD, GGTR removed the tank from the excavation. After a visual inspection, the tank was loaded onto a flatbed truck and transported as scrap metal to Circosta Iron & Metal, Inc. in San Francisco, California. Copies of the Certificate of Disposal and Circosta Scrap Metal Recycling Receipt & photographs of the tank being loaded onto a truck for transport and disposal are attached.

4. TANK AND SOIL CONDITION

The tank was found to be in poor condition with at least one visible hole. Additionally, soil discoloration and hydrocarbon odors were observed in the tank overburden soil and in the soil underlying the tank. Soil observed during the UST removal was predominantly clay. Groundwater was observed in the excavation during tank removal activities. Because of holes in the tank, an Underground Storage Tank Unauthorized Release (Leak) / Contamination Site Report was required for submission by the ACEHS. A copy of this report is included as an attachment.

5. TANK REMOVAL SAMPLING

Immediately following tank removal activities, under the direction of Mr. Robert Weston, GGTR collected two composite soil samples from the soil stockpile containing the overburden soil. The composite stockpile samples were labeled 9172-SP1(A-D)Comp and 9172-SP2(A-D)Comp. Following over-excavation of the sidewalls and excavation bottom, GGTR collected confirmation soil samples from the east, west, north and south sidewalls of the former tank excavation at approximately 12 fbg, labeled 9172-E-12, 9172-W-12, 9172-N-12 and 9172-S-12, respectively. All samples were transported to Accutest Laboratories (State Certification#08258) under formal chain-of-custody protocol for the required analyses. Figure 2 depicts the approximate soil samples locations.

6. TANK REMOVAL SAMPLE ANALYSIS

The tank excavation and stockpile composite soil samples were analyzed for Total Petroleum Hydrocarbons Extractable as Motor Oil (TPH-MO) and as Diesel (TPH-D) by Method SW846 8015B M SW846 3545A. (Historically Heating Oil has been various petroleum hydrocarbon mixtures from C9-C32; this includes Diesel and/or Motor Oil ranges. Therefore TPH in either range could be Heating Oil); Benzene, Toluene, Ethylbenzene, Total Xylenes (BTEX), 1,2-Dibromoethane (1,2-DIB), 1,2-Dichloroethane (1,2-DIC), and Di-isopropyl ether (DI-IE), Ethyl Alcohol, Ethyl Tert-Butyl Ether (ETBE), Methyl-Tertiary-Butyl Ether (MTBE), Tert-Amyl Methyl Ether (TAME), Tert Butyl Alcohol (TBA), by Method SW846 8260B, and Total Lead by SW3050B SW6020. Both stockpile sample results exceed regulatory limits, and all stockpiled overburden and over-excavated material was disposed of according to all handling, transportation and disposal guidelines (see sections 7 and 8 for detailed information regarding over-excavation and soil disposal).

7. OVER-EXCAVATION, RE-SAMPLING & ANALYSIS

Based on initial sample results and at the direction of ACEHS inspector Robert Weston, on August 23, GGTR returned to the site to perform additional over-excavation and confirmation sampling activities. GGTR began by removing the concrete dead man that was strapped to the tank providing an anchor against the buoyancy of the tank at the bottom of the excavation. The anchor was broken into pieces using a backhoe breaker and the concrete was removed from the excavation and stockpiled for disposal. Following removal of the deadman anchor; GGTR observed groundwater infiltrating into the bottom of the UST excavation. GGTR contracted Clearwater Environmental to remove the groundwater from the excavation and transported the

waste liquid (1,000 gallons) under Non-Hazardous Waste Manifest No. 007267036JJK to the Clearwater Environmental facility in Silver Springs, Nevada. Figure 2 depicts the approximate groundwater sample location.

After allowing the groundwater to recharge, under the direct observation of ACEHS inspector Robert Weston, GGTR collected a grab groundwater sample from the recharged groundwater. The grab sample was labeled 9172-GW and was analyzed for Total Petroleum Hydrocarbons Extractable as Motor Oil (TPH-MO) and as Diesel (TPH-D) by Method SW846 8015B M SW846 3510C. (Historically Heating Oil has been various petroleum hydrocarbon mixtures from C9-C32; this includes Diesel and/or Motor Oil ranges. Therefore TPH in either range could be Heating Oil); Benzene, Toluene, Ethylbenzene, Total Xylenes (BTEX), 1,2- Dibromoethane (1,2-DIB), 1,2- Dichloroethane (1,2-DIC), and Di-isopropyl Ether (DI-IE), Ethyl Alcohol, Ethyl Tert-Butyl Ether (ETBE), Methyl-Tertiary-Butyl Ether (MTBE), Tert-Amyl Methyl Ether (TAME), Tert Butyl Alcohol (TBA), by Method SW846 8260B. A summary of the analytical results is included in the Table "Sampling Results Form" and a copy of the associated laboratory certificate of analysis and chain of custody form is included as an attachment.

8. WASTE MANAGEMENT & SOIL DISPOSAL

Contamination exceeding local environmental screening levels (ESLs) was reported in both the soil over-excavation stockpiles. GGTR profiled the soil for waste disposal acceptance at the Newby Island Sanitary Landfill Facility located in Milpitas, California.

On August 24 and August 25, 2010, GGTR transported the Non-Hazardous Solid Waste (46.4 tons) under Non-Hazardous Waste Manifest Nos. 22057, 22063, 42102 and 102973 to Newby Island Landfill Facility in Milpitas, California. Additionally, F. A. Poli Trucking transported Non-Hazardous Solid Waste (81.75 tons) under Non-Hazardous Waste Manifest No. 22058, 22060, 22061, 22062, 109365 and 109366. Copies of the solid waste manifests and associated weight tags are included as an attachment.

9. PRESSURE TEST FILL, PRODUCT AND RETURN LINES

On August 24, GGTR pressure tested the fill, product and return lines. The product and return lines, running from the former the tank to the boiler room, held approximately 10 pounds per square inch (psi) of pressure for approximately 1 hour. ACEHS inspector Robert Weston approved these lines for abandonment in place with no additional testing required. The fill line, running from the parking area to the former tank, did not adequately hold pressure. Additional testing and potential removal of this line may be required by the ACEHS.

10. SITE RESTORATION



On August 23 and 24, 2010, GGTR backfilled the excavation with drain rock and virgin $\frac{3}{4}$ inch class II AB. The drain rock was placed from the bottom of the excavation to the top of the groundwater zone. A layer of geo-fabric was placed between the drain rock and the virgin $\frac{3}{4}$ inch class II AB. The soil was placed in 12" lifts and compacted using a backhoe with hydraulic plate compactor. The ground surface was subsequently replaced with 5 inches of $\frac{1}{4}$ inch asphalt in conformance with surrounding conditions.

11. FINDINGS / RECOMMENDATION

Visible holes in the tank, soil discoloration and hydrocarbon odors in the soil stockpile and excavation were noted during tank removal activities. Laboratory analytical reporting confirmed the presence of petroleum hydrocarbons in the soil stockpile and excavation sidewalls. The soil stockpile and over-excavated material, including: pit bottom, sidewall and concrete from

deadman anchor, were transported and disposed of under Non-Hazardous Waste Manifests at a State-licensed landfill facility. Over-excavation was completed to the maximum extent feasible. Groundwater was observed in the excavation during tank removal activities. The groundwater was subsequently pumped from the excavation and disposed of under Uniform Hazardous Waste Manifest. A grab groundwater sample was collected following recharge. Petroleum hydrocarbon concentrations of relative significance were reported in the groundwater sample. Any further action will be dependent on the recommendation of Alameda County Environmental Health Services.

FIGURES



GOLDEN GATE TANK REMOVAL, INC.

3730 Mission Street
San Francisco, CA 94110
Ph (415) 512-1555 Fx (415) 512-0964

VICINITY MAP


50 East Lewelling Blvd.
San Lorenzo, CA 94580

GGTR Project No.9172

Drawing By: AC

August 2010

Figure 1



GOLDEN GATE TANK REMOVAL, INC.
 3730 Mission Street
 San Francisco, California 94110
 Phone (415) 512-1555 Fax (415) 512-0964


GGTR Proj. No. 9172

Site Drawing
 50 E Lewelling Boulevard
 San Lorenzo, California 94580


Figure By: AC

September 2010


Figure 2



**UST READY TO BE REMOVED
FROM EXCAVATION**



TANK REMOVAL IN PROCESS



**TANK READY TO BE
TRANSPORTED FOR DISPOSAL**

GOLDEN GATE TANK REMOVAL, INC.
3730 Mission Street
San Francisco, CA 94110
Ph (415) 512-1555 Fx (415) 512-0964

UST REMOVAL
50 E Lewelling Boulevard
San Lorenzo, CA 94580

GGTR Project No. 9172

Drawing By: AC

September 2010

Figure 3

SAMPLING RESULTS FORM

Underground Storage Tank Site Address:

50 E Lewelling Boulevard, San Lorenzo, CA 94580

Business Site Name: **San Lorenzo High School**

| Description Sample ID (Specify location, i.e., tank, pipe, stockpile) and number | Sample Depth (Indicate depth of sample from grade) | Media (soil/water) | Date (Date Sample was collected) | Soil Type (specify if sand, clay, sil, etc.) | Results expressed in parts per million (ppm) | | | | | | | | | | | | | LEAD | |
|---|---|-----------------------|--|---|--|-----------|----------|----------|----------|-----------|----------|----------|----------|---------------|----------|----------|----------|----------|-----|
| | | | | | TPH-D | TPH-MO | B | T | E | X | 1,2-Dib | 1,2-Dic | Di-IE | Ethyl alcohol | ETBE | MTBE | TAME | | TBA |
| | | | | | Diesel | Motor Oil | | | | | | | | | | | | | |
| 9172-SP1(A-D)COMP (Stockpile) | Not Applicable | soil | 8/18/2010 | clay | 44.5* | ND<200 | ND<0.250 | ND<0.250 | ND<0.250 | ND<0.500 | ND<0.250 | ND<0.250 | ND<0.250 | ND<25 | ND<0.250 | ND<0.250 | ND<0.250 | ND<2.000 | 8.4 |
| 9172-SP2(A-D)COMP (Stockpile) | Not Applicable | soil | 8/18/2010 | clay | 303* | ND<100 | ND<0.250 | ND<0.250 | ND<0.250 | ND<0.500 | ND<0.250 | ND<0.250 | ND<0.250 | ND<25 | ND<0.250 | ND<0.250 | ND<0.250 | ND<2.000 | 12 |
| 9172-G-12 (Excavation) | 12 feet | soil | 8/18/2010 | clay | 21.8* | ND<20 | ND<0.014 | ND<0.014 | 0.0094 | ND<0.027 | ND<0.014 | ND<0.014 | ND<0.014 | ND<1.4 | ND<0.014 | ND<0.014 | ND<0.014 | ND<0.110 | 5.0 |
| 9172-W-12 (Excavation) | 12 feet | soil | 8/18/2010 | clay | 3410* | ND<1000 | ND<1.2 | ND<1.2 | ND<1.2 | ND<2.5 | ND<1.2 | ND<1.2 | ND<1.2 | ND<1.20 | ND<1.2 | ND<1.2 | ND<1.2 | ND<0.800 | 7.0 |
| 9172-N-12 (Excavation) | 12 feet | soil | 8/18/2010 | clay | 32.8 | ND<20 | ND<0.005 | ND<0.005 | ND<0.005 | ND<0.0099 | ND<0.005 | ND<0.005 | ND<0.005 | ND<0.500 | ND<0.005 | ND<0.005 | ND<0.005 | ND<0.040 | 6.8 |
| 9172-S-12 (Excavation) | 12 feet | soil | 8/18/2010 | clay | 3470* | ND<500 | ND<2.500 | ND<2.500 | ND<2.500 | ND<5.000 | ND<2.500 | ND<2.500 | ND<2.500 | ND<250 | ND<2.500 | ND<2.500 | ND<2.500 | ND<20 | 6.0 |
| 9172-R3 (Rinsate Sample) | Not Applicable | water | 8/17/2010 | NA | 3.09* | ND<0.94 | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A | N/A |
| 9172-GW (Rinsate Sample) | Not Applicable | water | 8/23/2010 | NA | 12.1* | ND<1.9 | ND<0.001 | ND<0.001 | 0.0047 | 0.0018 | ND<0.001 | ND<0.001 | ND<0.005 | ND<0.100 | ND<0.005 | ND<0.001 | ND<0.005 | ND<0.010 | N/A |

TPH = Total Petroleum Hydrocarbons
 * = Heating Oil (HO) is not a unique pattern. Historically HO has been various petroleum hydrocarbon mixtures from C9-C33; this includes the Diesel/ & or Motor Oil ranges; therefore, TPH in either range could be HO.

BTEX = Benzene, Toluene, Ethylbenzene, Xylene

1,2-Dib = 1,2-Dibromoethane

1,2-Dic = 1,2-Dichloroethane

Di-IE = Di-Isopropyl Ether

ETBE = Ethyl tert-Butyl Ether

MTBE = Methyl-t-Butyl Ether

TAME = Tert-Amyl Methyl Ether

TBA = Tert Butyl Alcohol


NA = Not Analyzed

ND = Non-Detectable Results

List of additional analytical results and detection limits on attached certified lab report

ATTACHMENTS

ANALYTICAL REPORT
CERTIFICATE OF TANK DISPOSAL
SCRAP METAL RECYCLING RECEIPT
LIQUID & SOLID MANIFESTS
WEIGHT TAG
UST UNAUTHORIZED RELEASE (LEAK) / CONTAMINATION REPORT
HAZARDOUS WASTE TANK CLOSURE CERTIFICATION
PERMIT



08/20/10

Technical Report for

Golden Gate Tank Removal

50 E. Lewelling Blvd - San Lorenzo, CA

9172

Accutest Job Number: C12178


Sampling Dates: 08/17/10 - 08/18/10



Report to:

Golden Gate Tank Removal
3730 Mission Street
San Francisco, CA 94110
Data@ggtr.com; j.alexander@ggtr.com
ATTN: Josh Alexander

Total number of pages in report: 29



Test results contained within this data package meet the requirements of the National Environmental Laboratory Accreditation Conference and/or state specific certification programs as applicable.

Laurie Glantz-Murphy
Laurie Glantz-Murphy
Laboratory Director

Client Service contact: Diane Theesen 408-588-0200

Certifications: CA (08258CA) DoD/ISO/IEC 17025:2005 (I.2242)

This report shall not be reproduced, except in its entirety, without the written approval of Accutest Laboratories.
Test results relate only to samples analyzed.

Table of Contents

-1-

| | |
|---|-----------|
| Section 1: Sample Summary | 3 |
| Section 2: Sample Results | 5 |
| 2.1: C12178-1: 9172-R3 | 6 |
| 2.2: C12178-6: 9172-SP1(A-D)COMP | 7 |
| 2.3: C12178-11: 9172-SP2(A-D)COMP | 9 |
| 2.4: C12178-12: 9172-E-12 | 11 |
| 2.5: C12178-13: 9172-W-12 | 13 |
| 2.6: C12178-14: 9172-N-12 | 15 |
| 2.7: C12178-15: 9172-S-12 | 17 |
| Section 3: Misc. Forms | 19 |
| 3.1: Chain of Custody | 20 |
| Section 4: GC/MS Volatiles - QC Data Summaries | 22 |
| 4.1: Method Blank Summary | 23 |
| 4.2: Blank Spike Summary | 24 |
| Section 5: GC Semi-volatiles - QC Data Summaries | 25 |
| 5.1: Method Blank Summary | 26 |
| 5.2: Blank Spike/Blank Spike Duplicate Summary | 28 |



Sample Summary

Golden Gate Tank Removal

Job No: C12178

50 E.Lewelling Blvd - San Lorenzo, CA
 Project No: 9172

| Sample Number | Collected Date | Time By | Received | Matrix Code | Type | Client Sample ID |
|---------------|----------------|----------|----------|-------------|--------------|-------------------|
| C12178-1 | 08/17/10 | 14:20 JA | 08/19/10 | AQ | Ground Water | 9172-R3 |
| C12178-2 | 08/18/10 | 13:24 JA | 08/19/10 | SO | Soil | 9172-SP1(A) |
| C12178-3 | 08/18/10 | 13:24 JA | 08/19/10 | SO | Soil | 9172-SP1(B) |
| C12178-4 | 08/18/10 | 13:24 JA | 08/19/10 | SO | Soil | 9172-SP1(C) |
| C12178-5 | 08/18/10 | 13:24 JA | 08/19/10 | SO | Soil | 9172-SP1(D) |
| C12178-6 | 08/18/10 | 00:00 JA | 08/19/10 | SO | Soil | 9172-SP1(A-D)COMP |
| C12178-7 | 08/18/10 | 13:36 JA | 08/19/10 | SO | Soil | 9172-SP2(A) |
| C12178-8 | 08/18/10 | 13:36 JA | 08/19/10 | SO | Soil | 9172-SP2(B) |
| C12178-9 | 08/18/10 | 13:36 JA | 08/19/10 | SO | Soil | 9172-SP2(C) |
| C12178-10 | 08/18/10 | 13:36 JA | 08/19/10 | SO | Soil | 9172-SP2(D) |
| C12178-11 | 08/18/10 | 00:00 JA | 08/19/10 | SO | Soil | 9172-SP2(A-D)COMP |
| C12178-12 | 08/18/10 | 14:56 JA | 08/19/10 | SO | Soil | 9172-E-12 |
| C12178-13 | 08/18/10 | 15:03 JA | 08/19/10 | SO | Soil | 9172-W-12 |

Soil samples reported on a dry weight basis unless otherwise indicated on result page.

Sample Summary (continued)


Golden Gate Tank Removal

Job No: C12178

50 E.Lewelling Blvd - San Lorenzo, CA
Project No: 9172

| Sample Number | Collected Date | Time By | Received | Matrix Code | Type | Client Sample ID |
|---------------|----------------|----------|----------|-------------|------|------------------|
| C12178-14 | 08/18/10 | 15:07 JA | 08/19/10 | SO | Soil | 9172-N-12 |
| C12178-15 | 08/18/10 | 14:59 JA | 08/19/10 | SO | Soil | 9172-S-12 |

Soil samples reported on a dry weight basis unless otherwise indicated on result page.



IT'S ALL IN THE CHEMISTRY

Sample Results

Report of Analysis

Report of Analysis

2.1
2

| | |
|--|-------------------------|
| Client Sample ID: 9172-R3 | Date Sampled: 08/17/10 |
| Lab Sample ID: C12178-1 | Date Received: 08/19/10 |
| Matrix: AQ - Ground Water | Percent Solids: n/a |
| Method: SW846 8015B M SW846 3510C | |
| Project: 50 E.Lewelling Blvd - San Lorenzo, CA | |

| Run # | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|--------|-----------|----|----------|----|-----------|------------|------------------|
| Run #1 | GG16602.D | 5 | 08/20/10 | JH | 08/19/10 | OP2555 | GGG495 |
| Run #2 | | | | | | | |

| Run # | Initial Volume | Final Volume |
|--------|----------------|--------------|
| Run #1 | 1060 ml | 1.0 ml |
| Run #2 | | |

TPH Extractable

| CAS No. | Compound | Result | RL | MDL | Units | Q |
|---------|---------------------------|--------|------|------|-------|---|
| | TPH (Diesel) ^a | 3.09 | 0.47 | 0.24 | mg/l | |
| | TPH (Motor Oil) | ND | 0.94 | 0.47 | mg/l | |

| CAS No. | Surrogate Recoveries | Run# 1 | Run# 2 | Limits |
|----------|----------------------|--------|--------|---------|
| 630-01-3 | Hexacosane | 70% | | 45-140% |

(a) Heating oil is not a unique pattern. Historically Heating oil has been various petroleum hydrocarbon mixtures from C9-C32; this includes the Diesel and/or Motor oil ranges. Therefore TPH in either range could be Heating oil.

ND = Not detected MDL - Method Detection Limit
 RL = Reporting Limit
 E = Indicates value exceeds calibration range

J = Indicates an estimated value
 B = Indicates analyte found in associated method blank
 N = Indicates presumptive evidence of a compound

Report of Analysis

2.2
2

| | |
|--|----------------------------------|
| Client Sample ID: 9172-SP1(A-D)COMP | Date Sampled: 08/18/10 |
| Lab Sample ID: C12178-6 | Date Received: 08/19/10 |
| Matrix: SO - Soil | Percent Solids: n/a ^a |
| Method: SW846 8260B | |
| Project: 50 E.Lewelling Blvd - San Lorenzo, CA | |

| Run # | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|---------------------|----------|----|----------|----|-----------|------------|------------------|
| Run #1 ^b | M16427.D | 1 | 08/20/10 | XB | n/a | n/a | VM536 |
| Run #2 | | | | | | | |

| Run # | Initial Weight | Final Volume | Methanol Aliquot |
|--------|----------------|--------------|------------------|
| Run #1 | 5.00 g | 5.0 ml | 100 ul |
| Run #2 | | | |

BTEX, Oxygenates

| CAS No. | Compound | Result | RL | MDL | Units | Q |
|-----------|-------------------------|--------|-------|------|-------|---|
| 71-43-2 | Benzene | ND | 250 | 75 | ug/kg | |
| 108-88-3 | Toluene | ND | 250 | 75 | ug/kg | |
| 100-41-4 | Ethylbenzene | ND | 250 | 75 | ug/kg | |
| 1330-20-7 | Xylene (total) | ND | 500 | 200 | ug/kg | |
| 106-93-4 | 1,2-Dibromoethane | ND | 250 | 50 | ug/kg | |
| 107-06-2 | 1,2-Dichloroethane | ND | 250 | 75 | ug/kg | |
| 108-20-3 | Di-Isopropyl ether | ND | 250 | 75 | ug/kg | |
| 64-17-5 | Ethyl alcohol | ND | 25000 | 5000 | ug/kg | |
| 637-92-3 | Ethyl tert-Butyl Ether | ND | 250 | 75 | ug/kg | |
| 1634-04-4 | Methyl Tert Butyl Ether | ND | 250 | 50 | ug/kg | |
| 994-05-8 | Tert-Amyl Methyl Ether | ND | 250 | 60 | ug/kg | |
| 75-65-0 | Tert Butyl Alcohol | ND | 2000 | 500 | ug/kg | |

| CAS No. | Surrogate Recoveries | Run# 1 | Run# 2 | Limits |
|-----------|----------------------|--------|--------|---------|
| 1868-53-7 | Dibromofluoromethane | 103% | | 60-130% |
| 2037-26-5 | Toluene-D8 | 100% | | 60-130% |
| 460-00-4 | 4-Bromofluorobenzene | 101% | | 60-130% |

- (a) All results reported on wet weight basis.
- (b) 4:1 composite

ND = Not detected MDL - Method Detection Limit
 RL = Reporting Limit
 E = Indicates value exceeds calibration range

J = Indicates an estimated value
 B = Indicates analyte found in associated method blank
 N = Indicates presumptive evidence of a compound

Report of Analysis

2.2
2

| | | | |
|-------------------|---------------------------------------|-----------------|------------------|
| Client Sample ID: | 9172-SP1(A-D)COMP | Date Sampled: | 08/18/10 |
| Lab Sample ID: | C12178-6 | Date Received: | 08/19/10 |
| Matrix: | SO - Soil | Percent Solids: | n/a ^a |
| Method: | SW846 8015B M SW846 3545A | | |
| Project: | 50 E.Lewelling Blvd - San Lorenzo, CA | | |

| Run # | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|---------------------|-----------|----|----------|----|-----------|------------|------------------|
| Run #1 ^b | GG16606.D | 5 | 08/20/10 | JH | 08/19/10 | OP2561 | GGG495 |
| Run #2 | | | | | | | |

| Run # | Initial Weight | Final Volume |
|--------|----------------|--------------|
| Run #1 | 5.00 g | 1.0 ml |
| Run #2 | | |

TPH Extractable

| CAS No. | Compound | Result | RL | MDL | Units | Q |
|---------|---------------------------|--------|-----|-----|-------|---|
| | TPH (Diesel) ^c | 445 | 100 | 50 | mg/kg | |
| | TPH (Motor Oil) | ND | 200 | 100 | mg/kg | |

| CAS No. | Surrogate Recoveries | Run# 1 | Run# 2 | Limits |
|----------|----------------------|--------|--------|---------|
| 630-01-3 | Hexacosane | 90% | | 45-140% |

- (a) All results reported on wet weight basis.
- (b) Reporting limit increased due to high moisture in the sample. 5grams prepared instead of the standard 10 grams.
- (c) Heating oil is not a unique pattern. Historically Heating oil has been various petroleum hydrocarbon mixtures from C9-C32; this includes the Diesel and/or Motor oil ranges. Therefore TPH in either range could be Heating oil.

ND = Not detected MDL - Method Detection Limit
 RL = Reporting Limit
 E = Indicates value exceeds calibration range

J = Indicates an estimated value
 B = Indicates analyte found in associated method blank
 N = Indicates presumptive evidence of a compound

Report of Analysis

2.3
2

| | |
|--|----------------------------------|
| Client Sample ID: 9172-SP2(A-D)COMP | Date Sampled: 08/18/10 |
| Lab Sample ID: C12178-11 | Date Received: 08/19/10 |
| Matrix: SO - Soil | Percent Solids: n/a ^a |
| Method: SW846 8260B | |
| Project: 50 E.Lewelling Blvd - San Lorenzo, CA | |

| Run # | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|---------------------|----------|----|----------|----|-----------|------------|------------------|
| Run #1 ^b | M16428.D | 1 | 08/20/10 | XB | n/a | n/a | VM536 |
| Run #2 | | | | | | | |

| Run # | Initial Weight | Final Volume | Methanol Aliquot |
|--------|----------------|--------------|------------------|
| Run #1 | 5.00 g | 5.0 ml | 100 ul |
| Run #2 | | | |

BTEX, Oxygenates

| CAS No. | Compound | Result | RL | MDL | Units | Q |
|-----------|-------------------------|--------|-------|------|-------|---|
| 71-43-2 | Benzene | ND | 250 | 75 | ug/kg | |
| 108-88-3 | Toluene | ND | 250 | 75 | ug/kg | |
| 100-41-4 | Ethylbenzene | ND | 250 | 75 | ug/kg | |
| 1330-20-7 | Xylene (total) | ND | 500 | 200 | ug/kg | |
| 106-93-4 | 1,2-Dibromoethane | ND | 250 | 50 | ug/kg | |
| 107-06-2 | 1,2-Dichloroethane | ND | 250 | 75 | ug/kg | |
| 108-20-3 | Di-Isopropyl ether | ND | 250 | 75 | ug/kg | |
| 64-17-5 | Ethyl alcohol | ND | 25000 | 5000 | ug/kg | |
| 637-92-3 | Ethyl tert-Butyl Ether | ND | 250 | 75 | ug/kg | |
| 1634-04-4 | Methyl Tert Butyl Ether | ND | 250 | 50 | ug/kg | |
| 994-05-8 | Tert-Amyl Methyl Ether | ND | 250 | 60 | ug/kg | |
| 75-65-0 | Tert Butyl Alcohol | ND | 2000 | 500 | ug/kg | |

| CAS No. | Surrogate Recoveries | Run# 1 | Run# 2 | Limits |
|-----------|----------------------|--------|--------|---------|
| 1868-53-7 | Dibromofluoromethane | 99% | | 60-130% |
| 2037-26-5 | Toluene-D8 | 101% | | 60-130% |
| 460-00-4 | 4-Bromofluorobenzene | 106% | | 60-130% |

- (a) All results reported on wet weight basis.
- (b) 4:1 composite

ND = Not detected MDL - Method Detection Limit J = Indicates an estimated value
 RL = Reporting Limit B = Indicates analyte found in associated method blank
 E = Indicates value exceeds calibration range N = Indicates presumptive evidence of a compound

Report of Analysis

2.3
2

| | |
|--|----------------------------------|
| Client Sample ID: 9172-SP2(A-D)COMP | Date Sampled: 08/18/10 |
| Lab Sample ID: C12178-11 | Date Received: 08/19/10 |
| Matrix: SO - Soil | Percent Solids: n/a ^a |
| Method: SW846 8015B M SW846 3545A | |
| Project: 50 E.Lewelling Blvd - San Lorenzo, CA | |

| Run # | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|--------|-----------|----|----------|----|-----------|------------|------------------|
| Run #1 | GG16607.D | 5 | 08/20/10 | JH | 08/19/10 | OP2561 | GGG495 |
| Run #2 | | | | | | | |

| Run # | Initial Weight | Final Volume |
|--------|----------------|--------------|
| Run #1 | 10.0 g | 1.0 ml |
| Run #2 | | |

TPH Extractable

| CAS No. | Compound | Result | RL | MDL | Units | Q |
|---------|---------------------------|--------|-----|-----|-------|---|
| | TPH (Diesel) ^b | 303 | 50 | 25 | mg/kg | |
| | TPH (Motor Oil) | ND | 100 | 50 | mg/kg | |

| CAS No. | Surrogate Recoveries | Run# 1 | Run# 2 | Limits |
|----------|----------------------|--------|--------|---------|
| 630-01-3 | Hexacosane | 89% | | 45-140% |

(a) All results reported on wet weight basis.

(b) Heating oil is not a unique pattern. Historically Heating oil has been various petroleum hydrocarbon mixtures from C9-C32; this includes the Diesel and/or Motor oil ranges. Therefore TPH in either range could be Heating oil.

ND = Not detected MDL - Method Detection Limit
 RL = Reporting Limit
 E = Indicates value exceeds calibration range

J = Indicates an estimated value
 B = Indicates analyte found in associated method blank
 N = Indicates presumptive evidence of a compound

Report of Analysis

2.4
2

| | |
|---|---|
| Client Sample ID: 9172-E-12 Lab Sample ID: C12178-12 Matrix: SO - Soil Method: SW846 8260B Project: 50 E.Lewelling Blvd - San Lorenzo, CA | Date Sampled: 08/18/10 Date Received: 08/19/10 Percent Solids: n/a ^a |
|---|---|

| Run # | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|---------------------|----------|----|----------|----|-----------|------------|------------------|
| Run #1 ^b | M16429.D | 1 | 08/20/10 | XB | n/a | n/a | VM536 |
| Run #2 | | | | | | | |

| Run # | Initial Weight |
|--------|----------------|
| Run #1 | 1.85 g |
| Run #2 | |

BTEX, Oxygenates

| CAS No. | Compound | Result | RL | MDL | Units | Q |
|-----------|-------------------------|--------|------|-----|-------|---|
| 71-43-2 | Benzene | ND | 14 | 4.1 | ug/kg | |
| 108-88-3 | Toluene | ND | 14 | 4.1 | ug/kg | |
| 100-41-4 | Ethylbenzene | 9.4 | 14 | 4.1 | ug/kg | J |
| 1330-20-7 | Xylene (total) | ND | 27 | 11 | ug/kg | |
| 106-93-4 | 1,2-Dibromoethane | ND | 14 | 2.7 | ug/kg | |
| 107-06-2 | 1,2-Dichloroethane | ND | 14 | 4.1 | ug/kg | |
| 108-20-3 | Di-Isopropyl ether | ND | 14 | 4.1 | ug/kg | |
| 64-17-5 | Ethyl alcohol | ND | 1400 | 270 | ug/kg | |
| 637-92-3 | Ethyl tert-Butyl Ether | ND | 14 | 4.1 | ug/kg | |
| 1634-04-4 | Methyl Tert Butyl Ether | ND | 14 | 2.7 | ug/kg | |
| 994-05-8 | Tert-Amyl Methyl Ether | ND | 14 | 3.2 | ug/kg | |
| 75-65-0 | Tert Butyl Alcohol | ND | 110 | 27 | ug/kg | |

| CAS No. | Surrogate Recoveries | Run# 1 | Run# 2 | Limits |
|-----------|----------------------|--------|--------|---------|
| 1868-53-7 | Dibromofluoromethane | 105% | | 60-130% |
| 2037-26-5 | Toluene-D8 | 98% | | 60-130% |
| 460-00-4 | 4-Bromofluorobenzene | 105% | | 60-130% |

- (a) All results reported on wet weight basis.
- (b) Dilution required due to high concentration of heavy hydrocarbons.

ND = Not detected MDL - Method Detection Limit
 RL = Reporting Limit
 E = Indicates value exceeds calibration range

J = Indicates an estimated value
 B = Indicates analyte found in associated method blank
 N = Indicates presumptive evidence of a compound

Report of Analysis

| | |
|--|----------------------------------|
| Client Sample ID: 9172-E-12 | Date Sampled: 08/18/10 |
| Lab Sample ID: C12178-12 | Date Received: 08/19/10 |
| Matrix: SO - Soil | Percent Solids: n/a ^a |
| Method: SW846 8015B M SW846 3545A | |
| Project: 50 E.Lewelling Blvd - San Lorenzo, CA | |

| Run # | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|--------|-----------|----|----------|----|-----------|------------|------------------|
| Run #1 | GG16600.D | 1 | 08/20/10 | JH | 08/19/10 | OP2561 | GGG495 |
| Run #2 | | | | | | | |

| Run # | Initial Weight | Final Volume |
|--------|----------------|--------------|
| Run #1 | 10.0 g | 1.0 ml |
| Run #2 | | |

TPH Extractable

| CAS No. | Compound | Result | RL | MDL | Units | Q |
|---------|---------------------------|--------|----|-----|-------|---|
| | TPH (Diesel) ^b | 21.8 | 10 | 5.0 | mg/kg | |
| | TPH (Motor Oil) | ND | 20 | 10 | mg/kg | |

| CAS No. | Surrogate Recoveries | Run# 1 | Run# 2 | Limits |
|----------|----------------------|--------|--------|---------|
| 630-01-3 | Hexacosane | 80% | | 45-140% |

(a) All results reported on wet weight basis.

(b) Heating oil is not a unique pattern. Historically Heating oil has been various petroleum hydrocarbon mixtures from C9-C32; this includes the Diesel and/or Motor oil ranges. Therefore TPH in either range could be Heating oil.

ND = Not detected MDL - Method Detection Limit
 RL = Reporting Limit
 E = Indicates value exceeds calibration range

J = Indicates an estimated value
 B = Indicates analyte found in associated method blank
 N = Indicates presumptive evidence of a compound

Report of Analysis

| | | | |
|-------------------|---------------------------------------|-----------------|------------------|
| Client Sample ID: | 9172-W-12 | Date Sampled: | 08/18/10 |
| Lab Sample ID: | C12178-13 | Date Received: | 08/19/10 |
| Matrix: | SO - Soil | Percent Solids: | n/a ^a |
| Method: | SW846 8260B | | |
| Project: | 50 E.Lewelling Blvd - San Lorenzo, CA | | |

| Run # | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|---------------------|----------|----|----------|----|-----------|------------|------------------|
| Run #1 ^b | M16431.D | 1 | 08/20/10 | XB | n/a | n/a | VM536 |
| Run #2 | | | | | | | |

| Run # | Initial Weight | Final Volume | Methanol Aliquot |
|--------|----------------|--------------|------------------|
| Run #1 | 5.10 g | 5.0 ml | 20.0 ul |
| Run #2 | | | |

BTEX, Oxygenates

| CAS No. | Compound | Result | RL | MDL | Units | Q |
|-----------|-------------------------|--------|--------|-------|-------|---|
| 71-43-2 | Benzene | ND | 1200 | 370 | ug/kg | |
| 108-88-3 | Toluene | ND | 1200 | 370 | ug/kg | |
| 100-41-4 | Ethylbenzene | ND | 1200 | 370 | ug/kg | |
| 1330-20-7 | Xylene (total) | ND | 2500 | 980 | ug/kg | |
| 106-93-4 | 1,2-Dibromoethane | ND | 1200 | 250 | ug/kg | |
| 107-06-2 | 1,2-Dichloroethane | ND | 1200 | 370 | ug/kg | |
| 108-20-3 | Di-Isopropyl ether | ND | 1200 | 370 | ug/kg | |
| 64-17-5 | Ethyl alcohol | ND | 120000 | 25000 | ug/kg | |
| 637-92-3 | Ethyl tert-Butyl Ether | ND | 1200 | 370 | ug/kg | |
| 1634-04-4 | Methyl Tert Butyl Ether | ND | 1200 | 250 | ug/kg | |
| 994-05-8 | Tert-Amyl Methyl Ether | ND | 1200 | 290 | ug/kg | |
| 75-65-0 | Tert Butyl Alcohol | ND | 9800 | 2500 | ug/kg | |

| CAS No. | Surrogate Recoveries | Run# 1 | Run# 2 | Limits |
|-----------|----------------------|--------|--------|---------|
| 1868-53-7 | Dibromofluoromethane | 98% | | 60-130% |
| 2037-26-5 | Toluene-D8 | 100% | | 60-130% |
| 460-00-4 | 4-Bromofluorobenzene | 104% | | 60-130% |

(a) All results reported on wet weight basis.

(b) Dilution required due to high concentration of heavy hydrocarbons.

ND = Not detected MDL - Method Detection Limit
 RL = Reporting Limit
 E = Indicates value exceeds calibration range

J = Indicates an estimated value
 B = Indicates analyte found in associated method blank
 N = Indicates presumptive evidence of a compound

Report of Analysis

2.5
2

| | |
|--|----------------------------------|
| Client Sample ID: 9172-W-12 | Date Sampled: 08/18/10 |
| Lab Sample ID: C12178-13 | Date Received: 08/19/10 |
| Matrix: SO - Soil | Percent Solids: n/a ^a |
| Method: SW846 8015B M SW846 3545A | |
| Project: 50 E.Lewelling Blvd - San Lorenzo, CA | |

| Run # | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|--------|-----------|----|----------|----|-----------|------------|------------------|
| Run #1 | GG16604.D | 50 | 08/20/10 | JH | 08/19/10 | OP2561 | GGG495 |
| Run #2 | | | | | | | |

| Run # | Initial Weight | Final Volume |
|--------|----------------|--------------|
| Run #1 | 10.0 g | 1.0 ml |
| Run #2 | | |

TPH Extractable

| CAS No. | Compound | Result | RL | MDL | Units | Q |
|---------|---------------------------|--------|------|-----|-------|---|
| | TPH (Diesel) ^b | 3410 | 500 | 250 | mg/kg | |
| | TPH (Motor Oil) | ND | 1000 | 500 | mg/kg | |

| CAS No. | Surrogate Recoveries | Run# 1 | Run# 2 | Limits |
|----------|----------------------|--------|--------|---------|
| 630-01-3 | Hexacosane | 94% | | 45-140% |

(a) All results reported on wet weight basis.

(b) Heating oil is not a unique pattern. Historically Heating oil has been various petroleum hydrocarbon mixtures from C9-C32; this includes the Diesel and/or Motor oil ranges. Therefore TPH in either range could be Heating oil.

ND = Not detected MDL - Method Detection Limit
 RL = Reporting Limit
 E = Indicates value exceeds calibration range

J = Indicates an estimated value
 B = Indicates analyte found in associated method blank
 N = Indicates presumptive evidence of a compound

Report of Analysis

2.6
2

| | |
|--|----------------------------------|
| Client Sample ID: 9172-N-12 | Date Sampled: 08/18/10 |
| Lab Sample ID: C12178-14 | Date Received: 08/19/10 |
| Matrix: SO - Soil | Percent Solids: n/a ^a |
| Method: SW846 8260B | |
| Project: 50 E.Lewelling Blvd - San Lorenzo, CA | |

| Run # | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|--------|----------|----|----------|----|-----------|------------|------------------|
| Run #1 | M16437.D | 1 | 08/20/10 | XB | n/a | n/a | VM536 |
| Run #2 | | | | | | | |

| Run # | Initial Weight |
|--------|----------------|
| Run #1 | 5.04 g |
| Run #2 | |

BTEX, Oxygenates

| CAS No. | Compound | Result | RL | MDL | Units | Q |
|-----------|-------------------------|--------|-----|------|-------|---|
| 71-43-2 | Benzene | ND | 5.0 | 1.5 | ug/kg | |
| 108-88-3 | Toluene | ND | 5.0 | 1.5 | ug/kg | |
| 100-41-4 | Ethylbenzene | ND | 5.0 | 1.5 | ug/kg | |
| 1330-20-7 | Xylene (total) | ND | 9.9 | 4.0 | ug/kg | |
| 106-93-4 | 1,2-Dibromoethane | ND | 5.0 | 0.99 | ug/kg | |
| 107-06-2 | 1,2-Dichloroethane | ND | 5.0 | 1.5 | ug/kg | |
| 108-20-3 | Di-Isopropyl ether | ND | 5.0 | 1.5 | ug/kg | |
| 64-17-5 | Ethyl alcohol | ND | 500 | 99 | ug/kg | |
| 637-92-3 | Ethyl tert-Butyl Ether | ND | 5.0 | 1.5 | ug/kg | |
| 1634-04-4 | Methyl Tert Butyl Ether | ND | 5.0 | 0.99 | ug/kg | |
| 994-05-8 | Tert-Amyl Methyl Ether | ND | 5.0 | 1.2 | ug/kg | |
| 75-65-0 | Tert Butyl Alcohol | ND | 40 | 9.9 | ug/kg | |

| CAS No. | Surrogate Recoveries | Run# 1 | Run# 2 | Limits |
|-----------|----------------------|--------|--------|---------|
| 1868-53-7 | Dibromofluoromethane | 103% | | 60-130% |
| 2037-26-5 | Toluene-D8 | 98% | | 60-130% |
| 460-00-4 | 4-Bromofluorobenzene | 100% | | 60-130% |

(a) All results reported on wet weight basis.

ND = Not detected MDL - Method Detection Limit
 RL = Reporting Limit
 E = Indicates value exceeds calibration range

J = Indicates an estimated value
 B = Indicates analyte found in associated method blank
 N = Indicates presumptive evidence of a compound

Report of Analysis

2.6
2

| | |
|--|----------------------------------|
| Client Sample ID: 9172-N-12 | Date Sampled: 08/18/10 |
| Lab Sample ID: C12178-14 | Date Received: 08/19/10 |
| Matrix: SO - Soil | Percent Solids: n/a ^a |
| Method: SW846 8015B M SW846 3545A | |
| Project: 50 E.Lewelling Blvd - San Lorenzo, CA | |

| Run # | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|--------|-----------|----|----------|----|-----------|------------|------------------|
| Run #1 | GG16605.D | 1 | 08/20/10 | JH | 08/19/10 | OP2561 | GGG495 |
| Run #2 | | | | | | | |

| Run # | Initial Weight | Final Volume |
|--------|----------------|--------------|
| Run #1 | 10.0 g | 1.0 ml |
| Run #2 | | |

TPH Extractable

| CAS No. | Compound | Result | RL | MDL | Units | Q |
|---------|---------------------------|--------|----|-----|-------|---|
| | TPH (Diesel) ^b | 32.8 | 10 | 5.0 | mg/kg | |
| | TPH (Motor Oil) | ND | 20 | 10 | mg/kg | |

| CAS No. | Surrogate Recoveries | Run# 1 | Run# 2 | Limits |
|----------|----------------------|--------|--------|---------|
| 630-01-3 | Hexacosane | 86% | | 45-140% |

(a) All results reported on wet weight basis.

(b) Heating oil is not a unique pattern. Historically Heating oil has been various petroleum hydrocarbon mixtures from C9-C32; this includes the Diesel and/or Motor oil ranges. Therefore TPH in either range could be Heating oil.

ND = Not detected MDL - Method Detection Limit
 RL = Reporting Limit
 E = Indicates value exceeds calibration range

J = Indicates an estimated value
 B = Indicates analyte found in associated method blank
 N = Indicates presumptive evidence of a compound

Report of Analysis

| | |
|--|----------------------------------|
| Client Sample ID: 9172-S-12 | Date Sampled: 08/18/10 |
| Lab Sample ID: C12178-15 | Date Received: 08/19/10 |
| Matrix: SO - Soil | Percent Solids: n/a ^a |
| Method: SW846 8260B | |
| Project: 50 E.Lewelling Blvd - San Lorenzo, CA | |

| Run # | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|---------------------|----------|----|----------|----|-----------|------------|------------------|
| Run #1 ^b | M16433.D | 1 | 08/20/10 | XB | n/a | n/a | VM536 |
| Run #2 | | | | | | | |

| Run # | Initial Weight | Final Volume | Methanol Aliquot |
|--------|----------------|--------------|------------------|
| Run #1 | 5.02 g | 5.0 ml | 10.0 ul |
| Run #2 | | | |

BTEX, Oxygenates

| CAS No. | Compound | Result | RL | MDL | Units | Q |
|-----------|-------------------------|--------|--------|-------|-------|---|
| 71-43-2 | Benzene | ND | 2500 | 750 | ug/kg | |
| 108-88-3 | Toluene | ND | 2500 | 750 | ug/kg | |
| 100-41-4 | Ethylbenzene | ND | 2500 | 750 | ug/kg | |
| 1330-20-7 | Xylene (total) | ND | 5000 | 2000 | ug/kg | |
| 106-93-4 | 1,2-Dibromoethane | ND | 2500 | 500 | ug/kg | |
| 107-06-2 | 1,2-Dichloroethane | ND | 2500 | 750 | ug/kg | |
| 108-20-3 | Di-Isopropyl ether | ND | 2500 | 750 | ug/kg | |
| 64-17-5 | Ethyl alcohol | ND | 250000 | 50000 | ug/kg | |
| 637-92-3 | Ethyl tert-Butyl Ether | ND | 2500 | 750 | ug/kg | |
| 1634-04-4 | Methyl Tert Butyl Ether | ND | 2500 | 500 | ug/kg | |
| 994-05-8 | Tert-Amyl Methyl Ether | ND | 2500 | 600 | ug/kg | |
| 75-65-0 | Tert Butyl Alcohol | ND | 20000 | 5000 | ug/kg | |

| CAS No. | Surrogate Recoveries | Run# 1 | Run# 2 | Limits |
|-----------|----------------------|--------|--------|---------|
| 1868-53-7 | Dibromofluoromethane | 100% | | 60-130% |
| 2037-26-5 | Toluene-D8 | 98% | | 60-130% |
| 460-00-4 | 4-Bromofluorobenzene | 104% | | 60-130% |

- (a) All results reported on wet weight basis.
- (b) Dilution required due to high concentration of heavy hydrocarbons.

ND = Not detected MDL - Method Detection Limit
 RL = Reporting Limit
 E = Indicates value exceeds calibration range

J = Indicates an estimated value
 B = Indicates analyte found in associated method blank
 N = Indicates presumptive evidence of a compound

Report of Analysis

| | |
|--|----------------------------------|
| Client Sample ID: 9172-S-12 | Date Sampled: 08/18/10 |
| Lab Sample ID: C12178-15 | Date Received: 08/19/10 |
| Matrix: SO - Soil | Percent Solids: n/a ^a |
| Method: SW846 8015B M SW846 3545A | |
| Project: 50 E.Lewelling Blvd - San Lorenzo, CA | |

| Run # | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|--------|-----------|----|----------|----|-----------|------------|------------------|
| Run #1 | GG16599.D | 25 | 08/20/10 | JH | 08/19/10 | OP2561 | GGG495 |
| Run #2 | | | | | | | |

| Run # | Initial Weight | Final Volume |
|--------|----------------|--------------|
| Run #1 | 10.0 g | 1.0 ml |
| Run #2 | | |

TPH Extractable

| CAS No. | Compound | Result | RL | MDL | Units | Q |
|---------|---------------------------|--------|-----|-----|-------|---|
| | TPH (Diesel) ^b | 3470 | 250 | 130 | mg/kg | |
| | TPH (Motor Oil) | ND | 500 | 250 | mg/kg | |


| CAS No. | Surrogate Recoveries | Run# 1 | Run# 2 | Limits |
|----------|----------------------|--------|--------|---------|
| 630-01-3 | Hexacosane | 91% | | 45-140% |

(a) All results reported on wet weight basis.

(b) Heating oil is not a unique pattern. Historically Heating oil has been various petroleum hydrocarbon mixtures from C9-C32; this includes the Diesel and/or Motor oil ranges. Therefore TPH in either range could be Heating oil.

ND = Not detected MDL - Method Detection Limit
 RL = Reporting Limit
 E = Indicates value exceeds calibration range

J = Indicates an estimated value
 B = Indicates analyte found in associated method blank
 N = Indicates presumptive evidence of a compound



IT'S ALL IN THE CHEMISTRY

Misc. Forms

Custody Documents and Other Forms

Includes the following where applicable:

- Chain of Custody

CHAIN OF CUSTODY

2105 Lundy Ave, San Jose, CA 95131
(408) 586-0200 FAX: (408) 586-0201

GGTRCASF2933

FED-EX Tracking # _____ Bottle Order Control # _____
Accutest Quote # _____ Accutest NC Job #: C **C12178**

Client / Reporting Information
Company Name: Golden Gate Task Service
Address: 570 Mission St.
City: San Francisco CA 94110
Project Contact: 9172
Phone #: 415-512-1555
Sampler's Name: Johanna Alexander

Project Information
Project Name: _____
Street: 150 E Lewellyn Blvd.
City: San Lorenzo, CA
Project #: 9172
Client Purchase Order #: _____

Requested Analysis

| | | | | | | | | | | | |
|--------------------------|--|--------------------------|-----------------|--------------------------|---------------|--------------------------|------------|--------------------------|-------------------------|--------------------------|-----------|
| <input type="checkbox"/> | 8260 Full Lit | <input type="checkbox"/> | TPH as Gasoline | <input type="checkbox"/> | 8270 | <input type="checkbox"/> | PAHs only | <input type="checkbox"/> | 625 | <input type="checkbox"/> | ATOCs |
| <input type="checkbox"/> | MS/MS (includes BTEX / TBA / EBE / DPE / TAME / 1,2-DCA / EDX) | <input type="checkbox"/> | TPH as Gas | <input type="checkbox"/> | Direct - Nonp | <input type="checkbox"/> | Oil - Ober | <input type="checkbox"/> | With Silica Gel Cleanup | <input type="checkbox"/> | PCBs-8081 |
| <input type="checkbox"/> | PCBs-8081 | <input type="checkbox"/> | 606 | <input type="checkbox"/> | PCBs-8082 | <input type="checkbox"/> | 606 | <input type="checkbox"/> | PCBs-8083 | <input type="checkbox"/> | 606 |
| <input type="checkbox"/> | BTEX-MBE-TPH as Gasoline by GC/MS | <input type="checkbox"/> | FID | <input type="checkbox"/> | PCBs-8084 | <input type="checkbox"/> | 606 | <input type="checkbox"/> | PCBs-8085 | <input type="checkbox"/> | 606 |

Matrix Codes
WV - Wastewater
GW - Ground Water
SV - Surface Water
SO - Soil
OI - Oil
WP - Wipe
LIQ - Non-aqueous Liquid
AIR
DW - Drinking Water (Perchlorate Only)

| Accutest Sample ID | Sample ID / Field Point / Point of Collection | Date | Time | Sampled by | Matrix | # of bottles | Number of preserved Bottles | | | | | | | | | | | | | | |
|--------------------|---|---------|---------|------------|--------|--------------|-----------------------------|------|------|------|------|------|------|------|------|------|------|------|--|--|--|
| | | | | | | | 8260 | 8270 | 8270 | 8270 | 8270 | 8270 | 8270 | 8270 | 8270 | 8270 | 8270 | 8270 | | | |
| -1 | 9172-R3 | 8/17/10 | 2:20 PM | FUBEN | W | 1 | | | | | | | | | | | | | | | |
| | 9172-SP1 (A-D) | 8/18/10 | 1:21 PM | JOSH | S | 4 | | | | | | | | | | | | | | | |
| | 9172-SP2 (A-D) | 8/18/10 | 1:36 PM | | | 4 | | | | | | | | | | | | | | | |
| -12 | 9172-E-12 | | 2:50 PM | | | 1 | | | | | | | | | | | | | | | |
| -13 | 9172-W-12 | | 3:05 PM | | | 1 | | | | | | | | | | | | | | | |
| -14 | 9172-N-12 | | 3:07 PM | | | 1 | | | | | | | | | | | | | | | |
| -15 | 9172-S-12 | | 3:59 PM | | | 1 | | | | | | | | | | | | | | | |

| 8260 Full Lit | 8270 | 8270 | 8270 | 8270 | 8270 | 8270 | 8270 | 8270 | 8270 | 8270 | 8270 |
|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |
| <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> |

Turnaround Time (Business days)
 Standard TAT 15 Business Days
 10 Day (Workload dependent)
 5 Day (Workload dependent)
 3 Day (125% markup)
 2 Day (150% markup)
 1 Day (200% markup)
 Same Day (300% markup)

Data Deliverable Information
 Commercial "A" - Results only
 Commercial "B" - Results with QC summaries
 Commercial "B+" - Results, QC, and chromatograms
 FULT1 - Level 4 data package
 EDF for Geotracker
 Provide EDF Global ID
 Provide EDF logcode: 10837

1 DAY
 1x121 Amber DMN N
 (2" x 8") BAGS TUBES (12)
 2 (14") Composites

Emergency TIA data available VIA Lablink

| Relinquished by Sampler | Date Time | Received By | Date Time | Relinquished by | Date Time | Received By | Date Time |
|-------------------------|------------------------|--------------------|----------------------|--------------------|----------------|--------------------|-----------|
| <u>[Signature]</u> | <u>8/19/10 1:12 PM</u> | <u>[Signature]</u> | <u>8/19/10 14:25</u> | <u>[Signature]</u> | <u>8/19/10</u> | <u>[Signature]</u> | <u>2</u> |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |

Appropriate Bottle / Rest N
 Labels match Doc N
 Headspace Y/N N
 Separate Receipt Loc N
 On Ice N
 Cooler Temp: 0.8 + 0.3 = 1.1 °C

**Accutest Laboratories Northern California
Sample Receiving Check List**

Job#: C12178

Sample Control Rep. Initial: EK JM

Review Chain of Custody Chain of Custody is to be complete and legible.

- Are these regulatory (NPDES) samples? GWA Yes / No
- Is pH requested? Yes / No
- Was Client informed that hold time is 15 min? Yes / No Continue Yes / No
- Was ortho-Phosphate filtered with in 15 min? Yes / No Continue Yes / No
- Are sample within hold time? Yes / No
- Are sample in danger of exceeding hold-time? Yes / No
- Existing Client? Yes / No Existing Project? Yes / No
- If No: Is Report to info complete and legible, including;
 - deliverable Name Address phone e-mail
 - Is Bill to info complete and legible, including;
 - PO# Credit card Contact address phone e-mail
 - Is Contact and/or Project Manager identified, including;
 - phone e-mail
- Project name / number Special requirements? Yes / No
- Sample IDs / date & time of collection provided? Yes / No
- Is Matrix listed and correct? Yes / No
- Analyses listed we do or client has authorized a subcontract? Yes / No
- Chain is signed and dated by both client and sample custodian? Yes / No
- TAT requested available? Yes / No Approved by PM

Review Coolers:

- Were Coolers temperatures measured at ≤6°C? Cooler # 1 Temp 1.1 °C
- If cooler is outside the ≤6°C; note down below the affected bottles in that cooler
- Note that ANC does NOT accept evidentiary samples. (We do not lock refrigerators)
- Shipment Received Method AC
- Custody Seals: Present: Yes / No If Yes; Unbroken: Yes / No

Review of Sample Bottles: If you answer no, explain to the side


- Chain matches bottle labels? Yes / No Sample bottle intact? Yes / No
- Is there enough sample volume in proper bottle for requested analyses? Yes / No
- Proper Preservatives? Yes / No Check pH on preserved samples except 1664, 625, 8270 and VOAs.
- Headspace-VOAs? Greater than 6mm in diameter Yes / No List sample ID and affected container

| Client Sample ID | pH Check | Other Comments/Issues |
|------------------|----------|-----------------------|
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

Non-Compliance issues and discrepancies on the COC are forwarded to Project Management

\\anc-srv-file1\d\$\Entech-Data\Laboratory\SOPs\SOP_CompleteListing\SC001F1_1_Form1_SampleControl_SampleReceivingChecklist_2010-02-15.doc





IT'S ALL IN THE CHEMISTRY

GC/MS Volatiles

QC Data Summaries

Includes the following where applicable:

- Method Blank Summaries
- Blank Spike Summaries
- Matrix Spike and Duplicate Summaries

Method Blank Summary

Job Number: C12178
 Account: GGTRCASF Golden Gate Tank Removal
 Project: 50 E.Lewelling Blvd - San Lorenzo, CA

| Sample | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|----------|----------|----|----------|----|-----------|------------|------------------|
| VM536-MB | M16423.D | 1 | 08/20/10 | XB | n/a | n/a | VM536 |

4.1.1
4

The QC reported here applies to the following samples:

Method: SW846 8260B

C12178-6, C12178-11, C12178-12, C12178-13, C12178-14, C12178-15

| CAS No. | Compound | Result | RL | MDL | Units | Q |
|-----------|-------------------------|--------|-----|-----|-------|---|
| 71-43-2 | Benzene | ND | 5.0 | 1.5 | ug/kg | |
| 106-93-4 | 1,2-Dibromoethane | ND | 5.0 | 1.0 | ug/kg | |
| 107-06-2 | 1,2-Dichloroethane | ND | 5.0 | 1.5 | ug/kg | |
| 108-20-3 | Di-Isopropyl ether | ND | 5.0 | 1.5 | ug/kg | |
| 64-17-5 | Ethyl alcohol | ND | 500 | 100 | ug/kg | |
| 100-41-4 | Ethylbenzene | ND | 5.0 | 1.5 | ug/kg | |
| 637-92-3 | Ethyl tert-Butyl Ether | ND | 5.0 | 1.5 | ug/kg | |
| 1634-04-4 | Methyl Tert Butyl Ether | ND | 5.0 | 1.0 | ug/kg | |
| 994-05-8 | Tert-Amyl Methyl Ether | ND | 5.0 | 1.2 | ug/kg | |
| 75-65-0 | Tert Butyl Alcohol | ND | 40 | 10 | ug/kg | |
| 108-88-3 | Toluene | ND | 5.0 | 1.5 | ug/kg | |
| 1330-20-7 | Xylene (total) | ND | 10 | 4.0 | ug/kg | |

| CAS No. | Surrogate Recoveries | Limits | |
|-----------|----------------------|--------|---------|
| 1868-53-7 | Dibromofluoromethane | 103% | 60-130% |
| 2937-26-5 | Toluene-D8 | 99% | 60-130% |
| 460-00-4 | 4-Bromofluorobenzene | 102% | 60-130% |

Blank Spike Summary

Job Number: C12178
 Account: GGTRCASF Golden Gate Tank Removal
 Project: 50 E.Lewelling Blvd - San Lorenzo, CA

| Sample | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|----------|----------|----|----------|----|-----------|------------|------------------|
| VM536-BS | M16421.D | 1 | 08/20/10 | XB | n/a | n/a | VM536 |

4.2.1

4


The QC reported here applies to the following samples:

Method: SW846 8260B

C12178-6, C12178-11, C12178-12, C12178-13, C12178-14, C12178-15

| CAS No. | Compound | Spike ug/kg | BSP ug/kg | BSP % | Limits |
|-----------|-------------------------|----------------|--------------|----------|--------|
| 71-43-2 | Benzene | 40 | 42.4 | 106 | 60-130 |
| 106-93-4 | 1,2-Dibromoethane | 40 | 38.5 | 96 | 60-130 |
| 107-06-2 | 1,2-Dichloroethane | 40 | 42.9 | 107 | 60-130 |
| 108-20-3 | Di-Isopropyl ether | 40 | 42.9 | 107 | 60-130 |
| 64-17-5 | Ethyl alcohol | 800 | 881 | 110 | 60-130 |
| 100-41-4 | Ethylbenzene | 40 | 39.8 | 100 | 60-130 |
| 637-92-3 | Ethyl tert-Butyl Ether | 40 | 43.1 | 108 | 60-130 |
| 1634-04-4 | Methyl Tert Butyl Ether | 40 | 43.3 | 108 | 60-130 |
| 994-05-8 | Tert-Amyl Methyl Ether | 40 | 42.9 | 107 | 60-130 |
| 75-65-0 | Tert Butyl Alcohol | 200 | 228 | 114 | 60-130 |
| 108-88-3 | Toluene | 40 | 39.6 | 99 | 60-130 |
| 1330-20-7 | Xylene (total) | 120 | 119 | 99 | 60-130 |

| CAS No. | Surrogate Recoveries | BSP | Limits |
|-----------|----------------------|------|---------|
| 1868-53-7 | Dibromofluoromethane | 103% | 60-130% |
| 2037-26-5 | Toluene D8 | 94% | 60-130% |
| 460-00-4 | 4-Bromofluorobenzene | 101% | 60-130% |



IT'S ALL IN THE CHEMISTRY

GC Semi-volatiles



QC Data Summaries

Includes the following where applicable:

- Method Blank Summaries
- Blank Spike Summaries
- Matrix Spike and Duplicate Summaries

Method Blank Summary

Job Number: C12178
Account: GGTRCASF Golden Gate Tank Removal
Project: 50 E.Lewelling Blvd - San Lorenzo, CA

| Sample | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|-----------|-----------|----|----------|----|-----------|------------|------------------|
| OP2555-MB | GG16539.D | 1 | 08/19/10 | JH | 08/18/10 | OP2555 | GGG494 |

The QC reported here applies to the following samples:

Method: SW846 8015B M

C12178-1

| CAS No. | Compound | Result | RL | MDL | Units | Q |
|---------|-----------------|--------|------|-------|-------|---|
| | TPH (Diesel) | ND | 0.10 | 0.050 | mg/l | |
| | TPH (Motor Oil) | ND | 0.20 | 0.10 | mg/l | |

| CAS No. | Surrogate Recoveries | Limits |
|----------|----------------------|-------------|
| 630-01-3 | Hexacosane | 79% 45-140% |

5.1.1
5

Method Blank Summary

Job Number: C12178
Account: GGTRCASF Golden Gate Tank Removal
Project: 50 E.Lewelling Blvd - San Lorenzo, CA

| Sample | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|-----------|----------|----|----------|----|-----------|------------|------------------|
| OP2561-MB | HH7877.D | 1 | 08/20/10 | JH | 08/19/10 | OP2561 | GHH338 |

The QC reported here applies to the following samples:

Method: SW846 8015B M

C12178-6, C12178-11, C12178-12, C12178-13, C12178-14, C12178-15

| CAS No. | Compound | Result | RL | MDL | Units | Q |
|---------|-----------------|--------|----|-----|-------|---|
| | TPH (Diesel) | ND | 10 | 5.0 | mg/kg | |
| | TPH (Motor Oil) | ND | 20 | 10 | mg/kg | |

| CAS No. | Surrogate Recoveries | Limits |
|----------|----------------------|-------------|
| 630-01-3 | Hexacosane | 60% 45-140% |

512
5

Blank Spike/Blank Spike Duplicate Summary

Job Number: C12178
 Account: GGTRCASF Golden Gate Tank Removal
 Project: 50 E.Lewelling Blvd - San Lorenzo, CA

| Sample | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|------------|-----------|----|----------|----|-----------|------------|------------------|
| OP2555-BS | GG16540.D | 1 | 08/19/10 | JH | 08/18/10 | OP2555 | GGG494 |
| OP2555-BSD | GG16541.D | 1 | 08/19/10 | JH | 08/18/10 | OP2555 | GGG494 |

The QC reported here applies to the following samples:

Method: SW846 8015B M

C12178-1

| CAS No. | Compound | Spike mg/l | BSP mg/l | BSP % | BSD mg/l | BSD % | RPD | Limits Rec/RPD |
|---------|-----------------|---------------|-------------|----------|-------------|----------|-----|-------------------|
| | TPH (Diesel) | 1 | 0.931 | 93 | 0.826 | 83 | 12 | 45-140/30 |
| | TPH (Motor Oil) | 1 | 0.780 | 78 | 0.761 | 76 | 2 | 45-140/30 |

| CAS No. | Surrogate Recoveries | BSP | BSD | Limits |
|----------|----------------------|-----|-----|---------|
| 630-01-3 | Hexacosane | 82% | 77% | 45-140% |

Blank Spike/Blank Spike Duplicate Summary

Job Number: C12178
 Account: GGTRCASF Golden Gate Tank Removal
 Project: 50 E.Lewelling Blvd - San Lorenzo, CA

| Sample | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|------------|----------|----|----------|----|-----------|------------|------------------|
| OP2561-BS | HH7878.D | 1 | 08/20/10 | JH | 08/19/10 | OP2561 | GHH338 |
| OP2561-BSD | HH7879.D | 1 | 08/20/10 | JH | 08/19/10 | OP2561 | GHH338 |

Method: SW846 8015B M

The QC reported here applies to the following samples:

C12178-6, C12178-11, C12178-12, C12178-13, C12178-14, C12178-15

| CAS No. | Compound | Spike mg/kg | BSP mg/kg | BSP % | BSD mg/kg | BSD % | RPD | Limits Rec/RPD |
|---------|-----------------|----------------|--------------|----------|--------------|----------|-----|-------------------|
| | TPH (Diesel) | 100 | 57.8 | 58 | 59.6 | 60 | 3 | 45-140/30 |
| | TPH (Motor Oil) | 100 | 65.8 | 66 | 65.7 | 66 | 0 | 45-140/30 |

| CAS No. | Surrogate Recoveries | BSP | BSD | Limits |
|----------|----------------------|-----|-----|---------|
| 630-01-3 | Hexacosane | 69% | 68% | 45-140% |

5.2.2
5

Technical Report for

Golden Gate Tank Removal

50 E.Lewelling Blvd - San Lorenzo, CA

9172

Accutest Job Number: C12178X

Sampling Date: 08/18/10

Report to:

Golden Gate Tank Removal
3730 Mission Street
San Francisco, CA 94110
Data@ggtr.com; j.alexander@ggtr.com
ATTN: Josh Alexander

Total number of pages in report:



Test results contained within this data package meet the requirements of the National Environmental Laboratory Accreditation Conference and/or state specific certification programs as applicable.

Laurie Glantz-Murphy
Laboratory Director

Client Service contact: Diane Theesen 408-588-0200

Certifications: CA (08258CA) DoD/ISO/IEC 17025:2005 (L2242)

This report shall not be reproduced, except in its entirety, without the written approval of Accutest Laboratories.
Test results relate only to samples analyzed.

Sample Summary


Golden Gate Tank Removal

Job No: C12178X

50 E. Lewelling Blvd - San Lorenzo, CA
Project No: 9172

| Sample Number | Collected Date | Time By | Received | Matrix Code | Type | Client Sample ID |
|---------------|----------------|----------|----------|-------------|------|-------------------|
| C12178-6X | 08/18/10 | 00:00 JA | 08/19/10 | SO | Soil | 9172-SP1(A-D)COMP |
| C12178-11X | 08/18/10 | 00:00 JA | 08/19/10 | SO | Soil | 9172-SP2(A-D)COMP |
| C12178-12X | 08/18/10 | 14:56 JA | 08/19/10 | SO | Soil | 9172-E-12 |
| C12178-13X | 08/18/10 | 15:03 JA | 08/19/10 | SO | Soil | 9172-W-12 |
| C12178-14X | 08/18/10 | 15:07 JA | 08/19/10 | SO | Soil | 9172-N-12 |
| C12178-15X | 08/18/10 | 14:59 JA | 08/19/10 | SO | Soil | 9172-S-12 |

Soil samples reported on a dry weight basis unless otherwise indicated on result page.



Northern California

CHAIN OF CUSTODY

2105 Lundy Ave, San Jose, CA 95131
 (408) 588-0200 FAX: (408) 588-0201

GGTRCASFA933

| | |
|-------------------|------------------------------------|
| FED-EX Tracking # | Bottle Order Control # |
| Accutest Quote # | Accutest NC Job #: C C12178 |

| Client / Reporting Information | | Project Information | |
|---|---|---------------------|--|
| Company Name: Golden Gate Task Remediation | Project Name: | | |
| Address: 5730 Mission St. | Street: 150 E. Lewellyn Blvd. | | |
| City: San Francisco, CA State: CA Zip: 94110 | City: San Lorenzo, CA State: CA | | |
| Project Contact: 9172 | Project #: 9172 | | |
| Phone #: 415-512-7555 | EMAIL: j.alexander@ggtr.com | | |
| Sampler's Name: Joshua Alexander | Client Purchase Order # | | |

| Accutest Sample ID | Sample ID / Field Point / Point of Collection | Date | Time | Sampled by | Matrix | # of bottles | Number of preserved Bottles | | | | | | | | | | | | | | | | | |
|--------------------|---|---------|---------|------------|--------|--------------|-----------------------------|---|---|---|---|---|---|---|---|---|----|----|--|--|--|--|--|--|
| | | | | | | | 0 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | | | | | | |
| -1 | 9172-R3 | 8/17/10 | 2:20PM | JUBEN | W | 1 | | | | | | | | | | | | | | | | | | |
| | 9172-SP1 (A-D) -2,3,4,5 | 8/18/10 | 12:12PM | JOSH | S | 4 | | | | | | | | | | | | | | | | | | |
| | 9172-SP2 (A-D) -7,8,9,10 | | 1:36PM | | | 4 | | | | | | | | | | | | | | | | | | |
| -12 | 9172-E-12 | | 2:50PM | | | 1 | | | | | | | | | | | | | | | | | | |
| -13 | 9172-W-12 | | 3:05PM | | | 1 | | | | | | | | | | | | | | | | | | |
| -14 | 9172-N-12 | | 3:01PM | | | 1 | | | | | | | | | | | | | | | | | | |
| -15 | 9172-S-12 | | 2:59PM | | | 1 | | | | | | | | | | | | | | | | | | |

| Requested Analysis | | | | | | | | | | | | Matrix Codes | |
|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|---------------------------------------|--|
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | WV- Wastewater | |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | GW- Ground Water | |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | SW- Surface Water | |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | SO- Soil | |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | OI-OI | |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | WP-Wpe | |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | LIQ- Non-aqueous Liquid | |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | AIR | |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | DW- Drinking Water (Perchlorate Only) | |
| | | | | | | | | | | | | LAB USE ONLY | |

Turnaround Time (Business days)

Standard TAT 15 Business Days

10 Day (Workload dependent)

5 Day (Workload dependent)

3 Day (125% markup)

2 Day (150% markup)

1 Day (200% markup)

Same Day (300% markup)

Approved By J Date: **8/19/10**

1-DAY

Data Deliverable Information

Commercial "A" - Results only

Commercial "B" - Results with QC summaries

Commercial "B+" - Results, QC, and chromatograms

FULT1 - Level 4 data package

EDF for Geotracker EDD Format

Provide EDF Global ID

Provide EDF Logcode: **10837**

1 DAY

1x11x11 Amber DMS N/A

(2"x8") BAGG-TUBES (12)

2x(4") Composites

Emergency T/A data available VIA Lablink

Sample Custody must be documented below each time samples change possession, including courier delivery.

| | | | |
|--------------------------|----------------------------------|------------------|---------------------------------|
| Relinquished by Sampler: | Date Time: 8/18/10 5:12PM | Received By: | Date Time: 8/19/10 14:25 |
| Relinquished by: | Date Time: | Relinquished By: | Date Time: |
| 3 | Date Time: | 3 | Date Time: |
| Relinquished by: | Date Time: | 4 | Date Time: |
| 5 | Date Time: | 5 | Date Time: |

Appropriate Bottle / Res Y/N Headspace Y/N On Ice Y/N Cooler Temp. **0.8 + 0.3 = 1.1** °C

Labels match Coc Y/N Separate Receipt Log Y/N

Subcontract Data



McC Campbell Analytical, Inc.

"When Quality Counts"

1534 Willow Pass Road, Pittsburg, CA 94565-1701
Web: www.mccampbell.com E-mail: main@mccampbell.com
Telephone: 877-252-9262 Fax: 925-252-9269

| | | |
|---|-------------------------------|--------------------------|
| Accutest Laboratories 2105 Lundy Ave San Jose, CA 95131 | Client Project ID: #9172 | Date Sampled: 08/18/10 |
| | | Date Received: 08/19/10 |
| | Client Contact: Diane Theesen | Date Reported: 08/20/10 |
| | Client P.O.: #C12178 | Date Completed: 08/20/10 |

WorkOrder: 1008593

August 20, 2010

Dear Diane:

Enclosed within are:


- 1) The results of the 6 analyzed samples from your project: #9172,
- 2) A QC report for the above samples,
- 3) A copy of the chain of custody, and
- 4) An invoice for analytical services.

All analyses were completed satisfactorily and all QC samples were found to be within our control limits.

If you have any questions or concerns, please feel free to give me a call. Thank you for choosing McC Campbell Analytical Laboratories for your analytical needs.

Best regards,

Angela Rydelius
Laboratory Manager
McC Campbell Analytical, Inc.



1008593

Accutest ID and PO#: C12178

2105 Lindy Avenue, San Jose, CA 95131 Phone: (408)588-0200 Fax: (408)588-0201

Subcontract Chain of Custody

Subcontract Lab: McCampbell Analytical
 Date Sent: 08/19/10
 Date Due: 08/20/10

1 DAY

Project Name: 9172
 Project Location:

| Accutest Lab Number | Customer Sample Name/Field Point ID | Matrix | Method | Collect Date | Collect Time |
|---------------------|-------------------------------------|--------|-------------|--------------|--------------|
| C12178-6 | | Soil | Lead (6010) | 08-18-10 | 13:24 |
| C12178-11 | | Soil | Lead (6010) | 08-18-10 | 13:36 |
| C12178-12 | | Soil | Lead (6010) | 08-18-10 | 14:56 |
| C12178-13 | | Soil | Lead (6010) | 08-18-10 | 15:03 |
| C12178-14 | | Soil | Lead (6010) | 08-18-10 | 15:07 |
| C12178-15 | | Soil | Lead (6010) | 08-18-10 | 14:59 |

Comments: Report Due: 08/20/10.
 C12178-6 & C12178-11*Sample composited (4.1) & homogenized @ Accutest.

| | | | |
|--|------------------------------------|----------------|------------|
| Relinquished By: <i>EKumar</i> | Received By: <i>[Signature]</i> | Date: 08-19-10 | Time: 5:21 |
| Relinquished By: <i>[Signature]</i> | Received By: <i>[Signature]</i> | Date: | Time: |

ICE 11 *ES*
 GOOD CONDITION _____ APPROPRIATE
 HEAD SPACE ABSENT _____ CONTAINERS
 DECHLORINATED IN LAB _____ PRESERVED IN LAB _____
 NOAS (C&G, WELLS, OTHER)
 BY COLLECTION

Send the Report to: dianet@accutest.com

McCampbell Analytical, Inc.



1534 Willow Pass Rd
Pittsburg, CA 94565-1701
(925) 252-9262

CHAIN-OF-CUSTODY RECORD

WorkOrder: 1008593

ClientCode: EALY

WaterTrax

WriteOn

EDF

Excel

Fax

Email

HardCopy

ThirdParty

J-flag

Report to:

Diane Theesen
Accutest Laboratories
2105 Lundy Ave
San Jose, CA 95131
(408) 588-0200 FAX (408) 588-0201

Email: dianet@accutest.com

CC: #C12178
PO: #C12178

ProjectNo: #9172

Bill to:

Accounts Payable
Accutest Laboratories
2235 Route 130
Dayton, NJ 08810
laural@accutest.com

Requested TAT: 1 day

Date Received: 08/19/2010

Date Printed: 08/19/2010

| Lab ID | Client ID | Matrix | Collection Date | Hold | Requested Tests (See legend below) | | | | | | | | | | | | | | |
|-------------|-----------|--------|-----------------|--------------------------|------------------------------------|---|---|---|---|---|---|---|---|----|----|----|--|--|--|
| | | | | | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | | | |
| 1008593-001 | C12178-6 | Soil | 8/18/2010 13:24 | <input type="checkbox"/> | A | | | | | | | | | | | | | | |
| 1008593-002 | C12178-11 | Soil | 8/18/2010 13:36 | <input type="checkbox"/> | A | | | | | | | | | | | | | | |
| 1008593-003 | C12178-12 | Soil | 8/18/2010 14:56 | <input type="checkbox"/> | A | | | | | | | | | | | | | | |
| 1008593-004 | C12178-13 | Soil | 8/18/2010 15:03 | <input type="checkbox"/> | A | | | | | | | | | | | | | | |
| 1008593-005 | C12178-14 | Soil | 8/18/2010 15:07 | <input type="checkbox"/> | A | | | | | | | | | | | | | | |
| 1008593-006 | C12178-15 | Soil | 8/18/2010 14:59 | <input type="checkbox"/> | A | | | | | | | | | | | | | | |

Test Legend:

| | |
|----|------|
| 1 | PB_S |
| 6 | |
| 11 | |

| | |
|----|--|
| 2 | |
| 7 | |
| 12 | |

| | |
|---|--|
| 3 | |
| 8 | |

| | |
|---|--|
| 4 | |
| 9 | |

| | |
|----|--|
| 5 | |
| 10 | |

Prepared by: Ana Venegas

Comments: 24hr rush

NOTE: Soil samples are discarded 60 days after results are reported unless other arrangements are made (Water samples are 30 days).
Hazardous samples will be returned to client or disposed of at client expense.



Sample Receipt Checklist

Client Name: **Accutest Laboratories**

Date and Time Received: **8/19/2010 7:30:38 PM**

Project Name: **#9172**

Checklist completed and reviewed by: **Ana Venegas**

WorkOrder N°: **1008593** Matrix Soil

Carrier: Derik Cartan (MAI Courier)

Chain of Custody (COC) Information

- Chain of custody present? Yes No
- Chain of custody signed when relinquished and received? Yes No
- Chain of custody agrees with sample labels? Yes No
- Sample IDs noted by Client on COC? Yes No
- Date and Time of collection noted by Client on COC? Yes No
- Sampler's name noted on COC? Yes No

Sample Receipt Information

- Custody seals intact on shipping container/cooler? Yes No NA
- Shipping container/cooler in good condition? Yes No
- Samples in proper containers/bottles? Yes No
- Sample containers intact? Yes No
- Sufficient sample volume for indicated test? Yes No

Sample Preservation and Hold Time (HT) Information

- All samples received within holding time? Yes No
- Container/Temp Blank temperature Cooler Temp: 8.8°C NA
- Water - VOA vials have zero headspace / no bubbles? Yes No No VOA vials submitted
- Sample labels checked for correct preservation? Yes No
- Metal - pH acceptable upon receipt (pH<2)? Yes No NA
- Samples Received on Ice? Yes No

(Ice Type: WET ICE)

* NOTE: If the "No" box is checked, see comments below.

Client contacted:

Date contacted:

Contacted by:

Comments:



McC Campbell Analytical, Inc.

"When Quality Counts"

1534 Willow Pass Road, Pittsburg, CA 94565-1701
Web: www.mcccampbell.com E-mail: main@mcccampbell.com
Telephone: 877-252-9262 Fax: 925-252-9269

| | | |
|---|-------------------------------|--------------------------|
| Accutest Laboratories 2105 Lundy Ave San Jose, CA 95131 | Client Project ID: #9172 | Date Sampled: 08/18/10 |
| | | Date Received: 08/19/10 |
| | Client Contact: Diane Theesen | Date Extracted: 08/19/10 |
| | Client P.O.: #C12178 | Date Analyzed: 08/20/10 |

Lead by ICP-MS*

Extraction method: SW3050B

Analytical methods: SW6020

Work Order: 1008593

| Lab ID | Client ID | Matrix | Extraction Type | Lead | DF | %SS | Comments |
|--------------|-----------|--------|-----------------|------|----|-----|----------|
| 1008593-001A | C12178-6 | S | TOTAL | 8.4 | 10 | 88 | |
| 1008593-002A | C12178-11 | S | TOTAL | 12 | 10 | 84 | |
| 1008593-003A | C12178-12 | S | TOTAL | 5.0 | 10 | 88 | |
| 1008593-004A | C12178-13 | S | TOTAL | 7.0 | 1 | 111 | |
| 1008593-005A | C12178-14 | S | TOTAL | 6.8 | 10 | 86 | |
| 1008593-006A | C12178-15 | S | TOTAL | 6.0 | 1 | 111 | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |


| | | | | |
|--|---|-------|-----|-------|
| Reporting Limit for DF =1; ND means not detected at or above the reporting limit | W | TOTAL | NA | µg/L |
| | S | TOTAL | 0.5 | mg/Kg |

*water samples are reported in µg/L, product/oil/non-aqueous liquid samples and all TCLP / STLC / DISTLC / SPLP extracts are reported in mg/L, soil/sludge/solid samples in mg/kg, wipe samples in µg/wipe, filter samples in µg/filter.

means surrogate diluted out of range; ND means not detected above the reporting limit/method detection limit; N/A means not applicable to this sample or instrument.

TOTAL = Hot acid digestion of a representative sample aliquot.
TRM = Total recoverable metals is the "direct analysis" of a sample aliquot taken from its acid-preserved container.
DISS = Dissolved metals by direct analysis of 0.45 µm filtered and acidified sample.

%SS = Percent Recovery of Surrogate Standard
DF = Dilution Factor



08/28/10

Technical Report for

Golden Gate Tank Removal

50 E. Lewelling Blvd - San Lorenzo, CA

9172

Accutest Job Number: C12230

Sampling Date: 08/23/10




Report to:

Golden Gate Tank Removal
3730 Mission Street
San Francisco, CA 94110
Data@ggtr.com; j.alexander@ggtr.com

ATTN: Josh Alexander

Total number of pages in report: 17



Test results contained within this data package meet the requirements of the National Environmental Laboratory Accreditation Conference and/or state specific certification programs as applicable.

Laurie Glantz-Murphy
Laboratory Director

Client Service contact: Diane Theesen 408-588-0200

Certifications: CA (08258CA) DoD/ISO/IEC 17025:2005 (L2242)

This report shall not be reproduced, except in its entirety, without the written approval of Accutest Laboratories.

Test results relate only to samples analyzed.




Table of Contents

-1-

Section 1: Sample Summary 3

Section 2: Sample Results 4

2.1: C12230-1: 9172-GW 5

Section 3: Misc. Forms 7

3.1: Chain of Custody 8

Section 4: GC/MS Volatiles - QC Data Summaries 10

4.1: Method Blank Summary 11

4.2: Blank Spike Summary 12

4.3: Matrix Spike/Matrix Spike Duplicate Summary 13

Section 5: GC Semi-volatiles - QC Data Summaries 14

5.1: Method Blank Summary 15

5.2: Blank Spike/Blank Spike Duplicate Summary 16

5.3: Matrix Spike/Matrix Spike Duplicate Summary 17



Sample Summary

Golden Gate Tank Removal

Job No: C12230

50 E.Lewelling Blvd - San Lorenzo, CA
Project No: 9172

| Sample Number | Collected Date | Time By | Received | Matrix Code Type | Client Sample ID |
|---------------|----------------|----------|----------|------------------|------------------|
| C12230-1 | 08/23/10 | 10:35 JA | 08/24/10 | AQ Ground Water | 9172-GW |



IT'S ALL IN THE CHEMISTRY

Sample Results

Report of Analysis

Report of Analysis

2.1
2

| | | |
|--|--|-------------------------|
| Client Sample ID: 9172-GW | | Date Sampled: 08/23/10 |
| Lab Sample ID: C12230-1 | | Date Received: 08/24/10 |
| Matrix: AQ - Ground Water | | Percent Solids: n/a |
| Method: SW846 8015B M SW846 3510C | | |
| Project: 50 E.Lewelling Blvd - San Lorenzo, CA | | |

| Run # | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|--------|-----------|----|----------|----|-----------|------------|------------------|
| Run #1 | GG16820.D | 10 | 08/26/10 | JH | 08/25/10 | OP2579 | GGG500 |
| Run #2 | | | | | | | |

| Run # | Initial Volume | Final Volume |
|--------|----------------|--------------|
| Run #1 | 1050 ml | 1.0 ml |
| Run #2 | | |

TPH Extractable

| CAS No. | Compound | Result | RL | MDL | Units | Q |
|---------|---------------------------|--------|------|------|-------|---|
| | TPH (Diesel) ^a | 12.1 | 0.95 | 0.48 | mg/l | |
| | TPH (Motor Oil) | ND | 1.9 | 0.95 | mg/l | |

| CAS No. | Surrogate Recoveries | Run# 1 | Run# 2 | Limits |
|----------|----------------------|--------|--------|---------|
| 630-01-3 | Hexacosane | 46% | | 45-140% |

(a) Heating oil is not a unique pattern. Historically Heating oil has been various petroleum hydrocarbon mixtures from C9-C32; this includes the Diesel and/or Motor oil ranges. Therefore TPH in either range could be Heating oil.

ND = Not detected MDL - Method Detection Limit J = Indicates an estimated value
 RL = Reporting Limit B = Indicates analyte found in associated method blank
 E = Indicates value exceeds calibration range N = Indicates presumptive evidence of a compound

Report of Analysis

| | | | |
|-------------------|---------------------------------------|-----------------|----------|
| Client Sample ID: | 9172-GW | Date Sampled: | 08/23/10 |
| Lab Sample ID: | C12230-1 | Date Received: | 08/24/10 |
| Matrix: | AQ - Ground Water | Percent Solids: | n/a |
| Method: | SW846 8260B | | |
| Project: | 50 E.Lewelling Blvd - San Lorenzo, CA | | |

| Run # | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|---------------------|----------|----|----------|----|-----------|------------|------------------|
| Run #1 ^a | W15178.D | 1 | 08/26/10 | XB | n/a | n/a | VW533 |
| Run #2 | | | | | | | |

| Run # | Purge Volume |
|--------|--------------|
| Run #1 | 10.0 ml |
| Run #2 | |

BTEX, Oxygenates


| CAS No. | Compound | Result | RL | MDL | Units | Q |
|-----------|-------------------------|--------|-----|------|-------|---|
| 71-43-2 | Benzene | ND | 1.0 | 0.30 | ug/l | |
| 108-88-3 | Toluene | ND | 1.0 | 0.50 | ug/l | |
| 100-41-4 | Ethylbenzene | 4.7 | 1.0 | 0.30 | ug/l | |
| 1330-20-7 | Xylene (total) | 1.8 | 2.0 | 0.70 | ug/l | J |
| 106-93-4 | 1,2-Dibromoethane | ND | 1.0 | 0.20 | ug/l | |
| 107-06-2 | 1,2-Dichloroethane | ND | 1.0 | 0.30 | ug/l | |
| 108-20-3 | Di-Isopropyl ether | ND | 5.0 | 0.50 | ug/l | |
| 64-17-5 | Ethyl Alcohol | ND | 100 | 40 | ug/l | |
| 637-92-3 | Ethyl Tert Butyl Ether | ND | 5.0 | 0.50 | ug/l | |
| 1634-04-4 | Methyl Tert Butyl Ether | ND | 1.0 | 0.50 | ug/l | |
| 994-05-8 | Tert-Amyl Methyl Ether | ND | 5.0 | 0.50 | ug/l | |
| 75-65-0 | Tert-Butyl Alcohol | ND | 10 | 5.0 | ug/l | |

| CAS No. | Surrogate Recoveries | Run# 1 | Run# 2 | Limits |
|-----------|----------------------|--------|--------|---------|
| 1868-53-7 | Dibromofluoromethane | 99% | | 60-130% |
| 2037-26-5 | Toluene-D8 | 102% | | 60-130% |
| 460-00-4 | 4-Bromofluorobenzene | 99% | | 60-130% |

(a) Sample was not preserved to a pH < 2.

ND = Not detected MDL - Method Detection Limit
 RL = Reporting Limit
 E = Indicates value exceeds calibration range

J = Indicates an estimated value
 B = Indicates analyte found in associated method blank
 N = Indicates presumptive evidence of a compound



IT'S ALL IN THE CHEMISTRY



Misc. Forms

Custody Documents and Other Forms

Includes the following where applicable:

- Chain of Custody

CHAIN OF CUSTODY

2105 Lundy Ave, San Jose, CA 95131
(408) 588-0200 FAX: (408) 588-0201

GATRCASF2933

| | | | |
|---|--------------------|--|--------------------|
| ED-EX Tracking # | | Bottle Order Control # | |
| Accutest Quote # | | Accutest NC Job #: C12230 | |
| Client / Reporting Information | | Project Information | |
| Company Name: Golden Gate Tank Rental | | Project Name: | |
| Address: 3780 Mission ST | | Street: 50 E Lewelling Blvd | |
| City: San Francisco CA 94110 | | City: San Lorenzo | |
| Project Contact: Josh Alexander | | Project #: 9172 | |
| Phone #: 415 512 1555 | | EMAIL: J.Alexander@GATRC.com | |
| Samplers Name: Jostwa Alexander | | Client Purchase Order #: | |
| Requested Analysis | | Matrix Codes | |
| <input type="checkbox"/> 8260 Full List <input type="checkbox"/> 824 <input type="checkbox"/> TPH as Gasoline <input type="checkbox"/> 8260 Petro Includes BTEX / MIBE / TBA / EBPE / DIPE / YAME / 1,2-DCA / EDG / TPH as Gas <input type="checkbox"/> 8270 <input type="checkbox"/> PAHs only <input type="checkbox"/> 625 <input type="checkbox"/> ATCs <input checked="" type="checkbox"/> TPH-Extractable - Diesel - Motor-Oil - Grease <input checked="" type="checkbox"/> With Silica Gel Cleanup <input type="checkbox"/> Heating Oil <input type="checkbox"/> METALS: CAM-170 LUFT-301 ROD-981 <input type="checkbox"/> PPM-130 <input type="checkbox"/> Pesticides-6081 <input type="checkbox"/> PCBs-6082 <input type="checkbox"/> 608 <input type="checkbox"/> <input type="checkbox"/> BTEX-MIBE-TPH as Gasoline by GC/MS-FID <input type="checkbox"/> | | WW- Wastewater GW- Ground Water SW- Surface Water SO- Soil QI-Q3 WP-Wqa LIQ - Non-aqueous Liquid AIR DW- Drinking Water (Perchlorate Only) | |
| LAB USE ONLY | | | |
| Turnaround Time (Business days) | | Data Deliverable Information | |
| <input type="checkbox"/> Standard TAT 15 Business Days <input type="checkbox"/> 10 Day (Workload dependent) <input type="checkbox"/> 5 Day (Workload dependent) <input type="checkbox"/> 3 Day (125% markup) <input type="checkbox"/> 2 Day (150% markup) <input type="checkbox"/> 1 Day (200% markup) <input type="checkbox"/> Same Day (300% markup) | | <input type="checkbox"/> Commercial "A" - Results only <input checked="" type="checkbox"/> Commercial "B" - Results with QC summaries <input type="checkbox"/> Commercial "B*" - Results, QC, and chromatograms <input type="checkbox"/> FULL1 - Level 4 data package <input type="checkbox"/> EDF for Geotracker <input type="checkbox"/> EDD Format Provide EDF Global ID Provide EDF Legend: 8/24/10 0835 | |
| Emergency T/A data available VIA Lablink | | Comments / Remarks | |
| | | 3 vials (w/ HCL) 8x14 Amber NLP | |
| Sample Custody must be documented below each time samples change possession, including courier delivery. | | | |
| Relinquished by: [Signature] | Date Time: 8/23/10 | Received By: [Signature] | Date Time: 8/24/10 |
| Relinquished by: [Signature] | Date Time: 8/23/10 | Received By: [Signature] | Date Time: 8/24/10 |
| Relinquished by: [Signature] | Date Time: 8/23/10 | Received By: [Signature] | Date Time: 8/24/10 |
| Relinquished by: [Signature] | Date Time: 8/23/10 | Received By: [Signature] | Date Time: 8/24/10 |
| 3 | | 3 | |
| 5 | | 5 | |
| Appropriate Bottle / Pres (Y) N | | Headspace (Y) N | |
| Labels match Coc? (Y) N | | Separate Receipt Log? (Y) N | |
| | | Cooler Temp. 1.9 to 2 = 2.2 °C | |

C12230: Chain of Custody
Page 1 of 2

Accutest Laboratories Northern California
Sample Receiving Check List

Job#: C12230
 Sample Control Rep. Initial: Ek/Im

Review Chain of Custody Chain of Custody is to be complete and legible.

- Are these regulatory (NPDES) samples? ~~QWA~~ Yes / No (Yes/No)
- Is pH requested? Yes / No (Yes/No)
- Was Client informed that hold time is 15 min? Yes / No Continue Yes / No
- Was ortho-Phosphate filtered with in 15 min? Yes / No Continue Yes / No
- Are sample within hold time? Yes / No (Yes/No)

Are sample in danger of exceeding hold-time Yes / No (Yes/No)

- Existing Client? Yes / No Existing Project? Yes / No (Yes/No)
- If No: Is Report to info complete and legible, including;
 - deliverable Name Address phone e-mail
 Is Bill to info complete and legible, including;
 - PO# Credit card Contact address phone e-mail
 Is Contact and/or Project Manager identified, including;
 - phone e-mail

- Project name / number Special requirements? Yes / No (Yes/No)
- Sample IDs / date & time of collection provided? Yes / No (Yes/No)
- Is Matrix listed and correct? Yes / No (Yes/No)
- Analyses listed we do or client has authorized a subcontract? ~~With TAT~~ Yes / No (Yes/No)
- Chain is signed and dated by both client and sample custodian? Yes / No (Yes/No)
- TAT requested available? Yes / No Approved by PM

Review Coolers: 1. 9 to 3 = 22°C

- Were Coolers temperatures measured at ≤6°C? Cooler # 1 Temp 2.1°C
- If cooler is outside the ≤6°C; note down below the affected bottles in that cooler
- Note that ANC does NOT accept evidentiary samples. (We do not lock refrigerators)

- Shipment Received Method Nexter Courier
- Custody Seals: Present: Yes / No (No) If Yes; Unbroken: Yes / No


Review of Sample Bottles: If you answer no, explain to the side

- Chain matches bottle labels? Yes / No (Yes/No) Sample bottle intact? Yes / No (Yes/No)
- Is there enough sample volume in proper bottle for requested analyses? Yes / No (Yes/No)
- Proper Preservatives? Yes / No (Yes/No) Check pH on preserved samples except 1664, 625, 8270 and VOAs.
- Headspace-VOAs? Greater than 6mm in diameter Yes / No (No) List sample ID and affected container

| Client Sample ID | pH Check | Other Comments/Issues |
|------------------|----------|-----------------------|
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

Non-Compliance issues and discrepancies on the COC are forwarded to Project Management

\\anc-srv-file1\dl\Entech-Data\Laboratory\SOPs\SOP_CompleteListing\SC001F1_1_Form1_SampleControl_SampleReceivingChecklist_2010-02-15.doc



IT'S ALL IN THE CHEMISTRY

GC/MS Volatiles

QC Data Summaries

Includes the following where applicable:

- Method Blank Summaries
- Blank Spike Summaries
- Matrix Spike and Duplicate Summaries

Method Blank Summary

Job Number: C12230
 Account: GGTRCASF Golden Gate Tank Removal
 Project: 50 E.Lewelling Blvd - San Lorenzo, CA

| Sample | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|----------|----------|----|----------|----|-----------|------------|------------------|
| VW533-MB | W15173.D | 1 | 08/26/10 | XB | n/a | n/a | VW533 |

4.1.1
4

The QC reported here applies to the following samples:

Method: SW846 8260B

C12230-1

| CAS No. | Compound | Result | RL | MDL | Units | Q |
|-----------|-------------------------|--------|-----|------|-------|---|
| 71-43-2 | Benzene | ND | 1.0 | 0.30 | ug/l | |
| 106-93-4 | 1,2-Dibromoethane | ND | 1.0 | 0.20 | ug/l | |
| 107-06-2 | 1,2-Dichloroethane | ND | 1.0 | 0.30 | ug/l | |
| 108-20-3 | Di-Isopropyl ether | ND | 5.0 | 0.50 | ug/l | |
| 100-41-4 | Ethylbenzene | ND | 1.0 | 0.30 | ug/l | |
| 64-17-5 | Ethyl Alcohol | ND | 100 | 40 | ug/l | |
| 637-92-3 | Ethyl Tert Butyl Ether | ND | 5.0 | 0.50 | ug/l | |
| 1634-04-4 | Methyl Tert Butyl Ether | ND | 1.0 | 0.50 | ug/l | |
| 994-05-8 | Tert-Amyl Methyl Ether | ND | 5.0 | 0.50 | ug/l | |
| 75-65-0 | Tert-Butyl Alcohol | ND | 10 | 5.0 | ug/l | |
| 108-88-3 | Toluene | ND | 1.0 | 0.50 | ug/l | |
| 1330-20-7 | Xylene (total) | ND | 2.0 | 0.70 | ug/l | |

| CAS No. | Surrogate Recoveries | | Limits |
|-----------|----------------------|------|---------|
| 1868-53-7 | Dibromofluoromethane | 97% | 60-130% |
| 2037-26-5 | Toluene-D8 | 101% | 60-130% |
| 460-00-4 | 4-Bromofluorobenzene | 98% | 60-130% |

Blank Spike Summary

Job Number: C12230
Account: GGTRCASF Golden Gate Tank Removal
Project: 50 E.Lewelling Blvd - San Lorenzo, CA

| Sample | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|----------|----------|----|----------|----|-----------|------------|------------------|
| VW533-BS | W15171.D | 1 | 08/26/10 | XB | n/a | n/a | VW533 |

4.2.1
4

The QC reported here applies to the following samples:

Method: SW846 8260B

C12230-1

| CAS No. | Compound | Spike ug/l | BSP ug/l | BSP % | Limits |
|-----------|-------------------------|---------------|-------------|----------|--------|
| 71-43-2 | Benzene | 20 | 20.9 | 105 | 60-130 |
| 106-93-4 | 1,2-Dibromoethane | 20 | 23.1 | 116 | 60-130 |
| 107-06-2 | 1,2-Dichloroethane | 20 | 22.4 | 112 | 60-130 |
| 108-20-3 | Di-Isopropyl ether | 20 | 21.1 | 106 | 60-130 |
| 100-41-4 | Ethylbenzene | 20 | 20.9 | 105 | 60-130 |
| 64-17-5 | Ethyl Alcohol | 400 | 508 | 127 | 60-130 |
| 637-92-3 | Ethyl Tert Butyl Ether | 20 | 20.9 | 105 | 60-130 |
| 1634-04-4 | Methyl Tert Butyl Ether | 20 | 22.1 | 111 | 60-130 |
| 994-05-8 | Tert-Amyl Methyl Ether | 20 | 21.0 | 105 | 60-130 |
| 75-65-0 | Tert-Butyl Alcohol | 100 | 145 | 145* a | 60-130 |
| 108-88-3 | Toluene | 20 | 20.4 | 102 | 60-130 |
| 1330-20-7 | Xylene (total) | 60 | 61.7 | 103 | 60-130 |

| CAS No. | Surrogate Recoveries | BSP | Limits |
|-----------|----------------------|------|---------|
| 1868-53-7 | Dibromofluoromethane | 103% | 60-130% |
| 2037-26-5 | Toluene-D8 | 97% | 60-130% |
| 460-00-4 | 4-Bromofluorobenzene | 101% | 60-130% |

(a) High percent recovery; not detected in associated samples.

Matrix Spike/Matrix Spike Duplicate Summary

Job Number: C12230
 Account: GGTRCASF Golden Gate Tank Removal
 Project: 50 E.Lewelling Blvd - San Lorenzo, CA

| Sample | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|--------------|----------|----|----------|----|-----------|------------|------------------|
| C12196-29MS | W15192.D | 1 | 08/26/10 | XB | n/a | n/a | VW533 |
| C12196-29MSD | W15193.D | 1 | 08/26/10 | XB | n/a | n/a | VW533 |
| C12196-29 | W15191.D | 1 | 08/26/10 | XB | n/a | n/a | VW533 |

4.3.1
4

The QC reported here applies to the following samples:

Method: SW846 8260B

C12230-1

| CAS No. | Compound | C12196-29 ug/l | Spike Q ug/l | MS ug/l | MS % | MSD ug/l | MSD % | RPD | Limits Rec/RPD |
|-----------|-------------------------|-------------------|--------------------|------------|---------|-------------|----------|-----|-------------------|
| 71-43-2 | Benzene | ND | 20 | 22.5 | 113 | 22.4 | 112 | 0 | 60-130/25 |
| 106-93-4 | 1,2-Dibromoethane | ND | 20 | 22.1 | 111 | 21.8 | 109 | 1 | 60-130/25 |
| 107-06-2 | 1,2-Dichloroethane | 1.3 | 20 | 24.6 | 117 | 24.0 | 114 | 2 | 60-130/25 |
| 108-20-3 | Di-Isopropyl ether | ND | 20 | 22.9 | 115 | 22.8 | 114 | 0 | 60-130/25 |
| 100-41-4 | Ethylbenzene | ND | 20 | 22.1 | 111 | 22.7 | 114 | 3 | 60-130/25 |
| 64-17-5 | Ethyl Alcohol | ND | 400 | 402 | 101 | 423 | 106 | 5 | 60-130/25 |
| 637-92-3 | Ethyl Tert Butyl Ether | ND | 20 | 21.7 | 109 | 21.3 | 107 | 2 | 60-130/25 |
| 1634-04-4 | Methyl Tert Butyl Ether | ND | 20 | 21.8 | 109 | 21.0 | 105 | 4 | 60-130/25 |
| 994-05-8 | Tert-Amyl Methyl Ether | ND | 20 | 20.9 | 105 | 20.4 | 102 | 2 | 60-130/25 |
| 75-65-0 | Tert-Butyl Alcohol | ND | 100 | 117 | 117 | 108 | 108 | 8 | 60-130/25 |
| 108-88-3 | Toluene | ND | 20 | 21.8 | 109 | 22.2 | 111 | 2 | 60-130/25 |
| 1330-20-7 | Xylene (total) | ND | 60 | 64.9 | 108 | 66.6 | 111 | 3 | 60-130/25 |

| CAS No. | Surrogate Recoveries | MS | MSD | C12196-29 | Limits |
|-----------|----------------------|------|------|-----------|---------|
| 1868-53-7 | Dibromofluoromethane | 104% | 103% | 101% | 60-130% |
| 2037-26-5 | Toluene-D8 | 99% | 100% | 101% | 60-130% |
| 460-00-4 | 4-Bromofluorobenzene | 102% | 102% | 97% | 60-130% |



GC Semi-volatiles



QC Data Summaries

Includes the following where applicable:

- Method Blank Summaries
- Blank Spike Summaries
- Matrix Spike and Duplicate Summaries

Method Blank Summary

Job Number: C12230
Account: GGTRCASF Golden Gate Tank Removal
Project: 50 E.Lewelling Blvd - San Lorenzo, CA

| Sample | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|-----------|-----------|----|----------|----|-----------|------------|------------------|
| OP2579-MB | GG16772.D | 1 | 08/25/10 | JH | 08/24/10 | OP2579 | GGG499 |

The QC reported here applies to the following samples:

Method: SW846 8015B M

C12230-1

| CAS No. | Compound | Result | RL | MDL | Units | Q |
|---------|-----------------|--------|------|-------|-------|---|
| | TPH (Diesel) | ND | 0.10 | 0.050 | mg/l | |
| | TPH (Motor Oil) | ND | 0.20 | 0.10 | mg/l | |

| CAS No. | Surrogate Recoveries | Limits |
|----------|----------------------|-------------|
| 630-01-3 | Hexacosane | 85% 45-140% |

5.1.1
5

Blank Spike/Blank Spike Duplicate Summary

Job Number: C12230
 Account: GGTRCASF Golden Gate Tank Removal
 Project: 50 E.Lewelling Blvd - San Lorenzo, CA

| Sample | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|------------|-----------|----|----------|----|-----------|------------|------------------|
| OP2579-BS | GG16773.D | 1 | 08/25/10 | JH | 08/24/10 | OP2579 | GGG499 |
| OP2579-BSD | GG16774.D | 1 | 08/25/10 | JH | 08/24/10 | OP2579 | GGG499 |

The QC reported here applies to the following samples:

Method: SW846 8015B M

C12230-1

| CAS No. | Compound | Spike mg/l | BSP mg/l | BSP % | BSD mg/l | BSD % | RPD | Limits Rec/RPD |
|---------|-----------------|------------|----------|-------|----------|-------|-----|----------------|
| | TPH (Diesel) | 1 | 0.960 | 96 | 0.945 | 95 | 2 | 45-140/30 |
| | TPH (Motor Oil) | 1 | 0.817 | 82 | 0.800 | 80 | 2 | 45-140/30 |

| CAS No. | Surrogate Recoveries | BSP | BSD | Limits |
|----------|----------------------|-----|-----|---------|
| 630-01-3 | Hexacosane | 38% | 71% | 45-140% |

5.2.1
5

Matrix Spike/Matrix Spike Duplicate Summary

Job Number: C12230
 Account: GGTRCASF Golden Gate Tank Removal
 Project: 50 E.Lewelling Blvd - San Lorenzo, CA

| Sample | File ID | DF | Analyzed | By | Prep Date | Prep Batch | Analytical Batch |
|------------|-----------|----|----------|----|-----------|------------|------------------|
| OP2579-MS | GG16828.D | 1 | 08/26/10 | JH | 08/24/10 | OP2579 | GGG500 |
| OP2579-MSD | GG16829.D | 1 | 08/26/10 | JH | 08/24/10 | OP2579 | GGG500 |
| C12213-1 | GG16775.D | 1 | 08/25/10 | JH | 08/24/10 | OP2579 | GGG499 |

The QC reported here applies to the following samples:

Method: SW846 8015B M

C12230-1

| CAS No. | Compound | C12213-1 mg/l | Spike Q | MS mg/l | MS % | MSD mg/l | MSD % | RPD | Limits Rec/RPD |
|---------|-----------------|------------------|------------|------------|---------|-------------|----------|-----|-------------------|
| | TPH (Diesel) | ND | 2 | 1.88 | 94 | 1.90 | 95 | 1 | 45-140/25 |
| | TPH (Motor Oil) | ND | 2 | 1.66 | 83 | 1.77 | 89 | 6 | 45-140/25 |

| CAS No. | Surrogate Recoveries | MS | MSD | C12213-1 | Limits |
|----------|----------------------|-----|-----|----------|---------|
| 630-01-3 | Hexacosane | 86% | 89% | 85% | 45-140% |



CERTIFICATE OF DISPOSAL

DATE: August 18, 2010
PROJECT NUMBER: 9172
PROJECT ADDRESS: 50 E Lewelling Boulevard, San Lorenzo, CA 94580
TANK SIZE: 6000 gallons
ORIGINAL TANK CONTENTS: Diesel

Golden Gate Tank Removal, Inc. hereby issues CERTIFICATION that:

- This tank was cleaned by triple rinsing. The rinsate was sampled and analyzed for Total Petroleum Hydrocarbons and found to be below the County of Alameda limit of 100 parts per million allowable for disposal as scrap metal.
- The Oxygen content of the Tank was 20.9%
- The Lower Explosive Limit was 0%
- The above tank was rendered harmless by cutting and disposed of as scrap metal at Circosta Iron and Metal, Inc.
- The above method of tank destruction is suitable for the materials involved and is accepted by the County of Alameda as an appropriate disposal method.

Copies of the analytical certificate the chain-of-custody prepared for the rinsate sample and the scrap metal receipt are attached to this Certification. If there are any questions regarding this tank, please contact this office.

Golden Gate Tank Removal, Inc.

CIRCOSTA IRON AND METAL, INC.

1801 EVANS AVENUE • SAN FRANCISCO, CALIFORNIA 94124
PHONE (415) 282-8568 FAX (415) 641-7804

#9172

BUY NUMBER

335314

CUSTOMER GOLDEN GATE

ADDRESS TANK REMOVAL

LICENSE NO. _____

DRIVER'S LIC. NO. _____

JOB NO. _____ NAME _____

TIME IN _____ TIME OUT _____

DATE: 8/19/10.

| | |
|-----------------|----------------|
| 18440 LB | LBS. GROSS |
| 11940 LB | LBS. TARE |
| <u>6500</u> | LBS. NET |
| _____ | LBS. DEDUCTION |

- #1-HMS
- #2-HMS
- STRUCTURAL
- RE-BAR
- HMS and SHEET MIX
- CLEAN SHEET
- W/G
- CAST IRON
- M-BLOCKS
- BODIES
- NON FERROUS

PREPARED
UNPREPARED
AUG 19 2009

WEIGHER _____

| |
|---------------------------|
| UNIT PRICE \$ <u>1.20</u> |
| AMOUNT \$ <u>58.00</u> |

COMMENTS: _____

[Handwritten Signature]
CUSTOMER SIGNATURE

BILL OF SALE: I hereby state that I am the lawful owner of the material described hereon, that I have a right to sell same and that for payment received in full, hereby acknowledged, I sell and convey title of same of the CIRCOSTA IRON & METAL CO.

| | | | | |
|--------------------------------------|---|-------------------|--|--|
| FORM HAZARDOUS WASTE MANIFEST | 1. Generator ID Number C A L 0 0 0 0 3 5 8 3 2 | 2. Page 1 of 1 | 3. Emergency Response Phone (510)476-1740 | 4. Manifest Tracking Number 007267018 JJK |
|--------------------------------------|---|-------------------|--|--|

| | | | |
|---|--|---|--|
| 5. Generator's Name and Mailing Address SAN LORENZO USD-SLHS 15510 USHER STREET SAN LORENZO CA 94580 | | Generator's Site Address (if different than mailing address) 50 E LEWELLING BLVD SAN LORENZO CA | |
|---|--|---|--|

| | | |
|--|--------------|---|
| 6. Transporter 1 Company Name UNI WASTE | 510 347-4837 | U.S. EPA ID Number C A L 0 0 0 3 1 7 3 2 0 |
|--|--------------|---|

| | | |
|-------------------------------|--|--------------------|
| 7. Transporter 2 Company Name | | U.S. EPA ID Number |
|-------------------------------|--|--------------------|

| | | |
|--|--|---|
| 8. Designated Facility Name and Site Address CLEARWATER ENVIRONMENTAL 2430 ALMOND DRIVE SILVER SPRINGS NV 89429 | | U.S. EPA ID Number N V D 9 8 2 3 5 8 4 8 3 |
|--|--|---|

| 9a. HM | 9b. U.S. DOT Description (including Proper Shipping Name, Hazard Class, ID Number, and Packing Group (if any)) | 10. Containers | | 11. Total Quantity | 12. Unit Wt./Vol. | 13. Waste Codes | | |
|--------|--|----------------|------|--------------------|-------------------|-----------------|--|--|
| | | No. | Type | | | | | |
| 1. | NON RCRA HAZARDOUS WASTE LIQUID (OIL & WATER) | 001 | TT | 600 | G | 223 | | |
| 2. | | | | | | | | |
| 3. | | | | | | | | |
| 4. | | | | | | | | |

| |
|---|
| 14. Special Handling Instructions and Additional Information WEAR PPE, ERG # 171 |
|---|

15. GENERATOR'S/OFFEROR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by the proper shipping name, and are classified, packaged, marked and labeled/placarded, and are in all respects in proper condition for transport according to applicable international and national governmental regulations. If export shipment and I am the Primary Exporter, I certify that the contents of this consignment conform to the terms of the attached EPA Acknowledgment of Consent. I certify that the waste minimization statement identified in 40 CFR 262.27(a) (if I am a large quantity generator) or (b) (if I am a small quantity generator) is true.

| | | |
|---|---------------------------------|----------------------------|
| Generator's/Offoror's Printed/Typed Name Ruben Limon | Signature <i>[Signature]</i> | Month Day Year 05/12/00 |
|---|---------------------------------|----------------------------|

| | |
|--|---|
| 16. International Shipments <input type="checkbox"/> Import to U.S. <input type="checkbox"/> Export from U.S. | Port of entry/exit: Date leaving U.S.: |
|--|---|

| | | |
|--|---------------------------------|----------------------------|
| 17. Transporter Acknowledgment of Receipt of Materials | | |
| Transporter 1 Printed/Typed Name Tony Figueroa | Signature <i>[Signature]</i> | Month Day Year 05/17/00 |
| Transporter 2 Printed/Typed Name | Signature | Month Day Year |

| |
|--|
| 18. Discrepancy |
| 18a. Discrepancy Indication Space <input type="checkbox"/> Quantity <input type="checkbox"/> Type <input type="checkbox"/> Residue <input type="checkbox"/> Partial Rejection <input type="checkbox"/> Full Rejection |
| Manifest Reference Number: |

| | |
|--|--------------------|
| 18b. Alternate Facility (or Generator) | U.S. EPA ID Number |
| Facility's Phone: | |

| | |
|---|----------------|
| 18c. Signature of Alternate Facility (or Generator) | Month Day Year |
|---|----------------|

| | | | |
|---|----|----|----|
| 19. Hazardous Waste Report Management Method Codes (i.e., codes for hazardous waste treatment, disposal, and recycling systems) | | | |
| 1. | 2. | 3. | 4. |

| | | |
|--|-----------|----------------|
| 20. Designated Facility Owner or Operator: Certification of receipt of hazardous materials covered by the manifest except as noted in Item 18a | | |
| Printed/Typed Name | Signature | Month Day Year |

GENERATOR
TRANSPORTER INT'L
TRANSPORTER
DESIGNATED FACILITY

| | | | | | | |
|---|---|--|---------------------------------|---|---|----------------------------|
| UNIFORM HAZARDOUS WASTE MANIFEST | | 1. Generator ID Number CA I 0 0 0 0 3 5 8 3 2 | 2. Page 1 of 1 | 3. Emergency Response Phone (510) 476-1740 | 4. Manifest Tracking Number 007267036 JJK | |
| 5. Generator's Name and Mailing Address SAN LORENZO USD-SLHS 15510 USHER STREET SAN LORENZO CA 94580 | | | | | | |
| Generator's Site Address (if different than mailing address) 50 E LEWELLING BLVD SAN LORENZO CA | | | | | | |
| 6. Transporter 1 Company Name 510 317-4837 U.S. EPA ID Number | | | | | | |
| 7. Transporter 2 Company Name UNL WASTE U.S. EPA ID Number 0 0 3 1 7 3 2 0 | | | | | | |
| 8. Designated Facility Name and Site Address CLEARWATER ENVIRONMENTAL 2430 ALMOND DRIVE SILVER SPRINGS NV 89429 U.S. EPA ID Number | | | | | | |
| Facility's Phone: 7557-9001 | | | | | | |
| GENERATOR | 9a. HM | 9b. U.S. DOT Description (including Proper Shipping Name, Hazard Class, ID Number, and Packing Group (if any)) | | 10. Containers No. Type | | 11. Total Quantity |
| | 1. | NON RCRA HAZARDOUS WASTE LIQUID DIESEL & WATER) | | 001 | TT | 1000 |
| | 2. | | | | | 223 |
| | 3. | | | | | |
| | 4. | | | | | |
| 12. Unit Wt./Vol. G | | | | | | |
| 13. Waste Codes N V D 0 8 2 3 5 8 4 0 3 | | | | | | |
| 14. Special Handling Instructions and Additional Information WEAR PPE, ERG # 171 | | | | | | |
| 15. GENERATOR'S/OFFEROR'S CERTIFICATION: I hereby declare that the contents of this consignment are fully and accurately described above by the proper shipping name, and are classified, packaged, marked and labeled/placarded, and are in all respects in proper condition for transport according to applicable international and national governmental regulations. If export shipment and I am the Primary Exporter, I certify that the contents of this consignment conform to the terms of the attached EPA Acknowledgment of Consent. I certify that the waste minimization statement identified in 40 CFR 262.27(a) (if I am a large quantity generator) or 40 CFR 261.11 (if I am a small quantity generator) is true. | | | | | | |
| Generator's/Offoror's Printed/Typed Name <i>John Alexander</i> | | | | Signature <i>[Signature]</i> | | Month Day Year 18 23 10 |
| 16. International Shipments <input type="checkbox"/> Import to U.S. <input type="checkbox"/> Export from U.S. Port of entry/exit: Date leaving U.S.: | | | | | | |
| TRANSPORTER | 17. Transporter Acknowledgment of Receipt of Materials | | | | | |
| | Transporter 1 Printed/Typed Name <i>Anthony Williams</i> | | Signature <i>[Signature]</i> | | Month Day Year 18 23 10 | |
| Transporter 2 Printed/Typed Name | | Signature | | Month Day Year | | |
| DESIGNATED FACILITY | 18. Discrepancy | | | | | |
| | 18a. Discrepancy Indication Space <input type="checkbox"/> Quantity <input type="checkbox"/> Type <input type="checkbox"/> Residue <input type="checkbox"/> Partial Rejection <input type="checkbox"/> Full Rejection | | | | | |
| | 18b. Alternate Facility (or Generator) Manifest Reference Number: U.S. EPA ID Number | | | | | |
| Facility's Phone: | | | | | | |
| 18c. Signature of Alternate Facility (or Generator) Month Day Year | | | | | | |
| 19. Hazardous Waste Report Management Method Codes (i.e., codes for hazardous waste treatment, disposal, and recycling systems) | | | | | | |
| 1. | | 2. | | 3. | | 4. |
| 20. Designated Facility Owner or Operator: Certification of receipt of hazardous materials covered by the manifest except as noted in Item 18a | | | | | | |
| Printed/Typed Name | | | | Signature | | Month Day Year |

Keller Canyon
Sanitary Landfill
901 Bailey Road
Pittsburg, CA 94565
Phone (925) 458-9800
Fax (925) 458-9891

Coffin Butte
Landfill
28972 Coffin Butte Road
Corvallis, OR 97330
Phone (541) 745 2018
Fax (541) 745-3826

Ox Mountain
Sanitary Landfill
12310 San Mateo Road
Half Moon Bay, CA 94019
Phone (650) 726-1819
Fax (650) 726-9183

Newby Island
Sanitary Landfill
1601 Dixon Landing Road
Milpitas, CA 95035
Phone (408) 945 2800
Fax (408) 262 2871

Forward
Landfill
9999 S. Auslin Road
Manteca, CA 95336
Phone (209) 982 4298
Fax (209) 982 1009

NON-HAZARDOUS WASTE MANIFEST

GENERATOR
San Lorenzo Unified School District
MAILING ADDRESS
15510 Usher Street
CITY, STATE, ZIP
San Lorenzo, CA 94580
PHONE
(510) 317-4837

MANIFEST NUMBER
51271012937

CONTACT PERSON
Karen Langmaid
SIGNATURE OF AUTHORIZED AGENT / TITLE
[Signature]
DATE
8/24/10

REQUIRED PERSONAL PROTECTIVE EQUIPMENT
 GLOVES GOGGLES RESPIRATOR HARD HAT
 TY-VEK SAFETY VEST

GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR Part 261 or that it meets the applicable code of regulations, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations. AND, if the waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions, I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR Part 268 and is no longer a hazardous waste as defined by 40 CFR Part 261.

SPECIAL HANDLING PROCEDURES:

WASTE TYPE:
 DISPOSAL CONSTRUCTION DEBRIS SPECIAL WASTE
 SLUDGE WOOD OTHER *Soil*

RECEIVING FACILITY

GENERATING FACILITY
50 E Lewelling Blvd
SAN LORENZO

TRANSPORTER
Golden Gate Tank Removal
ADDRESS
3730 Mission Street
CITY, STATE, ZIP
San Francisco, CA 94110
PHONE

NOTES: VEHICLE LICENSE NUMBER **5J29490.501** TRUCK NUMBER

SIGNATURE OF AUTHORIZED AGENT OR DRIVER
[Signature]
DATE
8/25/10

END DUMP BOTTOM DUMP TRANSFER
ROLL-OFF(S) FLAT-BED VAN DRUMS

I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.

CUBIC YARDS **10**
DISPOSAL METHOD (TO BE COMPLETED BY LANDFILL)
DISPOSE OTHER

REMARKS
FACILITY TICKET NUMBER **058853**
SIGNATURE OF AUTHORIZED AGENT
[Signature]
DATE
8/25/10

SOIL
 CONSTRUCTION DEBRIS
 NON-FRIABLE ASBESTOS
 WOOD
 ASH
 SPECIAL OTHER

SCHEDULING MUST BE MADE PRIOR TO 3:00 P.M. THE DAY PRIOR TO EXPECTED ARRIVAL - ANY UNSCHEDULED LOADS ARE SUBJECT TO REFUSAL UPON ARRIVAL. ONGOING DAILY DELIVERIES MUST BE SCHEDULED WITH THE LANDFILL THE DAY BEFORE.

- Keller Canyon Sanitary Landfill
901 Bailey Road
Pittsburg, CA 94565
Phone (925) 458 9800
Fax (925) 458 9891
- Coffin Butte Landfill
28972 Coffin Butte Road
Corvallis, OR 97330
Phone (541) 745-2018
Fax (541) 745-3826
- Ox Mountain Sanitary Landfill
12310 San Mateo Road
Half Moon Bay, CA 94019
Phone (650) 726 1819
Fax (650) 726 9183
- Newby Island Sanitary Landfill
1601 Dixon Landing Road
Milpitas, CA 95035
Phone (408) 945 2800
Fax (408) 262 2871
- Forward Landfill
9999 S. Austin Road
Manteca, CA 95336
Phone (209) 982 4298
Fax (209) 982 1009

NON-HAZARDOUS WASTE MANIFEST

GENERATOR

San Lorenzo Unified School District

MAILING ADDRESS

15510 Usher Street

CITY, STATE, ZIP

San Lorenzo, CA 94580

PHONE

(510) 317-4837

CONTACT PERSON

Karen Langmaid

SIGNATURE OF AUTHORIZED AGENT / TITLE

DATE

[Signature]

8/24/10

GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR Part 261 or Title 26 of the California code of regulations, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if the waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions, I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR Part 268 and is no longer a hazardous waste as defined by 40 CFR Part 261.

51271012937

REQUIRED PERSONAL PROTECTIVE EQUIPMENT:

GLOVES GOGGLES RESPIRATOR HARD HAT

TY-VEK SAFETY VEST

SPECIAL HANDLING PROCEDURES:

WASTE TYPE:

DISPOSAL
 CONSTRUCTION
 DEBRIS
 SPECIAL WASTE

SLUDGE
 WOOD
 OTHER

Soil

GENERATING FACILITY

50 E Lewelling Blvd

SAN LORENZO

RECEIVING FACILITY

TRANSPORTER

Golden Gate Tank Removal

ADDRESS

3730 Mission Street

CITY, STATE, ZIP

San Francisco, CA 94110

PHONE

NOTES: VEHICLE LICENSE NUMBER TRUCK NUMBER

5J29490 501

END DUMP BOTTOM DUMP TRANSFER

SIGNATURE OF AUTHORIZED AGENT OR DRIVER

DATE

[Signature]

8/24/10

ROLL-OFF(S) FLAT-BED VAN DRUMS

I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.

CUBIC YARDS

10

DISPOSAL METHOD: (TO BE COMPLETED BY LANDFILL)

DISPOSE OTHER

REMARKS

FACILITY TICKET NUMBER

SIGNATURE OF AUTHORIZED AGENT

DATE

[Signature]

8/24/10

SOIL
 CONSTRUCTION DEBRIS
 NON-FRIABLE ASBESTOS
 WOOD
 ASH
 SPECIAL OTHER

SCHEDULING MUST BE MADE PRIOR TO 3:00 P.M. THE DAY PRIOR TO EXPECTED ARRIVAL. ANY UNSCHEDULED LOADS ARE SUBJECT TO REFUSAL UPON ARRIVAL. ONGOING DAILY DELIVERIES MUST BE SCHEDULED WITH THE LANDFILL THE DAY BEFORE.

- Keller Canyon Sanitary Landfill
401 Bay Road
Pittsburg, CA 94565
Phone (925) 458 9800
Fax (925) 458 9891
- Coffin Butte Landfill
28972 Coffin Butte Road
Corvallis, OR 97330
Phone (541) 745-2018
Fax (541) 745-3826
- Ox Mountain Sanitary Landfill
12310 San Mateo Road
Hall Moon Bay, CA 94019
Phone (650) 726 1819
Fax (650) 726-9183
- Newby Island Sanitary Landfill
1601 Dixon Landing Road
Milpitas, CA 95035
Phone (408) 945 2800
Fax (408) 262 2871
- Forward Landfill
9999 S. Austin Road
Manteca, CA 95336
Phone (209) 982 4298
Fax (209) 982 1009

NON-HAZARDOUS WASTE MANIFEST

GENERATOR
San Lorenzo Unified School District
MAILING ADDRESS
15510 Usher Street
CITY, STATE, ZIP
San Lorenzo, CA 94580
PHONE
(510) 317-4837
CONTACT PERSON
Karen Langmaid
SIGNATURE OF AUTHORIZED AGENT: TITLE _____ DATE: **8/24/10**

51271012937

REQUIRED PERSONAL PROTECTIVE EQUIPMENT:
 GLOVES GOGGLES RESPIRATOR HARD HAT
 TY-VEK SAFETY VEST
 SPECIAL HANDLING PROCEDURES:

GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR Part 261 or title 22 of the California code of regulations, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if the waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions, I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR Part 268 and is no longer a hazardous waste as defined by 40 CFR Part 261.

WASTE TYPE:
 DISPOSAL SLUDGE
 CONSTRUCTION WOOD
 DEBRIS OTHER **Soil**
 SPECIAL WASTE

RECEIVING FACILITY

GENERATING FACILITY
50 E Lewelling Blvd SAN LORENZO

TRANSPORTER
Golden Gate Tank Removal
ADDRESS
3730 Mission Street
CITY, STATE, ZIP
San Francisco, CA 94110
PHONE _____
SIGNATURE OF AUTHORIZED AGENT OR DRIVER: **Julie Mabank** DATE: **8/24/10**

NOTES: VEHICLE LICENSE NUMBER: **5J29490.501** TRUCK NUMBER _____

| | | |
|--------------------------|--------------------------|--------------------------|
| END DUMP | BOTTOM DUMP | TRANSFER |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| ROLL-OFF(S) | FLAT-BED | VAN |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | | DRUMS |
| | | <input type="checkbox"/> |

I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.

REMARKS _____
 FACILITY TICKET NUMBER _____
 SIGNATURE OF AUTHORIZED AGENT: _____ DATE: _____

CUBIC YARDS: **102**

DISPOSAL METHOD: (TO BE COMPLETED BY LANDFILL)

| | | |
|---|---------|-------|
| | DISPOSE | OTHER |
| <input type="checkbox"/> SOIL | | |
| <input type="checkbox"/> CONSTRUCTION DEBRIS | | |
| <input type="checkbox"/> NON-FRIABLE ASBESTOS | | |
| <input type="checkbox"/> WOOD | | |
| <input type="checkbox"/> ASH | | |
| <input type="checkbox"/> SPECIAL OTHER | | |

SCHEDULING MUST BE MADE PRIOR TO 3:00 P.M. THE DAY PRIOR TO EXPECTED ARRIVAL • ANY UNSCHEDULED LOADS ARE SUBJECT TO REFUSAL UPON ARRIVAL. ONGOING DAILY DELIVERIES MUST BE SCHEDULED WITH THE LANDFILL THE DAY BEFORE.

Keller Canyon Sanitary Landfill
 901 Bailey Road
 Pittsburg, CA 94565
 Phone (925) 458-9800
 Fax (925) 458-9891

Ox Mountain Sanitary Landfill
 12310 San Mateo Road
 Half Moon Bay, CA 94019
 Phone (650) 726-1819
 Fax (650) 726-9183

Newby Island Sanitary Landfill
 1601 Dixon Landing Road
 Milpitas, CA 95035
 Phone (408) 945-2800
 Fax (408) 262-2871


Forward Landfill
 9999 S. Austin Road
 Manteca, CA 95336
 Phone (209) 982-4298
 Fax (209) 982-1009


NON-HAZARDOUS WASTE MANIFEST


| | | | | | | | | | | | | | | | | | | | | | | | | |
|--|---------|--|--|--|---------|-------|-------------------------------|--|--|---|--|--|---|--|--|-------------------------------|--|--|------------------------------|--|--|--|--|--|
| GENERATOR <i>San Lorenzo 1970-92115</i> | | WASTE ACCEPTANCE NO. <i>5127101-2937</i> | | | | | | | | | | | | | | | | | | | | | | |
| MAILING ADDRESS <i>15510 Jeter St</i> | | | | | | | | | | | | | | | | | | | | | | | | |
| CITY, STATE, ZIP <i>San Lorenzo, CA</i> | | REQUIRED PERSONAL PROTECTIVE EQUIPMENT | | | | | | | | | | | | | | | | | | | | | | |
| PHONE <i>(510) 277-4957</i> | | <input checked="" type="checkbox"/> GLOVES <input type="checkbox"/> GOGGLES <input type="checkbox"/> RESPIRATOR <input checked="" type="checkbox"/> HARD HAT <input type="checkbox"/> TY-VEK <input type="checkbox"/> OTHER | | | | | | | | | | | | | | | | | | | | | | |
| CONTACT PERSON <i>Ramon Hernandez</i> | | SPECIAL HANDLING PROCEDURES: | | | | | | | | | | | | | | | | | | | | | | |
| SIGNATURE OF AUTHORIZED AGENT / TITLE <i>[Signature]</i> | | DATE <i>8/27/10</i> | | | | | | | | | | | | | | | | | | | | | | |
| * GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR Part 261 or title 22 of the California code of regulations, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if the waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions, I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR Part 268 and is no longer a hazardous waste as defined by 40 CFR Part 261. | | RECEIVING FACILITY | | | | | | | | | | | | | | | | | | | | | | |
| WASTE TYPE: <input checked="" type="checkbox"/> DISPOSAL <input type="checkbox"/> SLUDGE <input type="checkbox"/> CONSTRUCTION <input type="checkbox"/> WOOD <input type="checkbox"/> DEBRIS <input checked="" type="checkbox"/> OTHER <i>Soil</i> <input type="checkbox"/> SPECIAL WASTE | | | | | | | | | | | | | | | | | | | | | | | | |
| GENERATING FACILITY <i>San Lorenzo School District</i> | | | | | | | | | | | | | | | | | | | | | | | | |
| TRANSPORTER <i>Golden Gate Truck Rental</i> | | NOTES: | VEHICLE LICENSE NUMBER <i>5A29490</i> | | | | | | | | | | | | | | | | | | | | | |
| ADDRESS <i>2170 Mission St.</i> | | | TRUCK NUMBER <i>501</i> | | | | | | | | | | | | | | | | | | | | | |
| CITY, STATE, ZIP <i>San Francisco, CA 94102</i> | | | | | | | | | | | | | | | | | | | | | | | | |
| PHONE <i>(415) 521-1555</i> | | END DUMP BOTTOM DUMP TRANSFER <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> | | | | | | | | | | | | | | | | | | | | | | |
| SIGNATURE OF AUTHORIZED AGENT OR DRIVER <i>[Signature]</i> | | ROLL-OFF(S) FLAT-BED VAN DRUMS <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> | | | | | | | | | | | | | | | | | | | | | | |
| * I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate. | | CUBIC YARDS <i>111</i> | | | | | | | | | | | | | | | | | | | | | | |
| REMARKS | | DISPOSAL METHOD: (TO BE COMPLETED BY LANDFILL) | | | | | | | | | | | | | | | | | | | | | | |
| FACILITY TICKET NUMBER <i>058529</i> | | <table border="1"> <tr> <td></td> <td>DISPOSE</td> <td>OTHER</td> </tr> <tr> <td><input type="checkbox"/> SOIL</td> <td></td> <td></td> </tr> <tr> <td><input checked="" type="checkbox"/> CONSTRUCTION DEBRIS</td> <td></td> <td></td> </tr> <tr> <td><input type="checkbox"/> NON-FRIABLE ASBESTOS</td> <td></td> <td></td> </tr> <tr> <td><input type="checkbox"/> WOOD</td> <td></td> <td></td> </tr> <tr> <td><input type="checkbox"/> ASH</td> <td></td> <td></td> </tr> <tr> <td><input type="checkbox"/> SPECIAL OTHER</td> <td></td> <td></td> </tr> </table> | | | DISPOSE | OTHER | <input type="checkbox"/> SOIL | | | <input checked="" type="checkbox"/> CONSTRUCTION DEBRIS | | | <input type="checkbox"/> NON-FRIABLE ASBESTOS | | | <input type="checkbox"/> WOOD | | | <input type="checkbox"/> ASH | | | <input type="checkbox"/> SPECIAL OTHER | | |
| | DISPOSE | OTHER | | | | | | | | | | | | | | | | | | | | | | |
| <input type="checkbox"/> SOIL | | | | | | | | | | | | | | | | | | | | | | | | |
| <input checked="" type="checkbox"/> CONSTRUCTION DEBRIS | | | | | | | | | | | | | | | | | | | | | | | | |
| <input type="checkbox"/> NON-FRIABLE ASBESTOS | | | | | | | | | | | | | | | | | | | | | | | | |
| <input type="checkbox"/> WOOD | | | | | | | | | | | | | | | | | | | | | | | | |
| <input type="checkbox"/> ASH | | | | | | | | | | | | | | | | | | | | | | | | |
| <input type="checkbox"/> SPECIAL OTHER | | | | | | | | | | | | | | | | | | | | | | | | |
| SIGNATURE OF AUTHORIZED AGENT <i>[Signature]</i> | | DATE <i>8/27/10</i> | | | | | | | | | | | | | | | | | | | | | | |
| * SCHEDULING MUST BE MADE PRIOR TO 3:00 P.M. THE DAY PRIOR TO EXPECTED ARRIVAL • ANY UNSCHEDULED LOADS ARE SUBJECT TO REFUSAL UPON ARRIVAL. ONGOING DAILY DELIVERIES MUST BE SCHEDULED WITH THE LANDFILL THE DAY BEFORE. | | MANIFEST # <i>42102</i> | | | | | | | | | | | | | | | | | | | | | | |

- Kellner Canyon Sanitary Landfill
901 Bailey Road
Pittsburg, CA 94565
Phone (925) 458-9800
Fax (925) 458-9891
- Coffin Butte Landfill
28972 Coffin Butte Road
Corvallis, OR 97330
Phone (541) 745-2018
Fax (541) 745-3826
- Ox Mountain Sanitary Landfill
12310 San Mateo Road
Half Moon Bay, CA 94019
Phone (650) 726-1819
Fax (650) 726-9183
- Newby Island Sanitary Landfill
1601 Dixon Landing Road
Milpitas, CA 95035
Phone (408) 945-2800
Fax (408) 262-2871
- Forward Landfill
9999 S. Austin Road
Manteca, CA 95336
Phone (209) 982-4298
Fax (209) 982-1009

NON-HAZARDOUS WASTE MANIFEST

| | | | |
|--|-------------|---|--|
| GENERATOR San Lorenzo Unified School District | | WASTE ACCEPTANCE NO. 51274012937 | |
| MAILING ADDRESS 17510 Water St | | REQUIRED PERSONAL PROTECTIVE EQUIPMENT | |
| CITY, STATE, ZIP San Lorenzo, CA 94580 | | | |
| PHONE (510) 517-4837 | | <input checked="" type="checkbox"/> GLOVES <input type="checkbox"/> GOGGLES <input type="checkbox"/> RESPIRATOR <input checked="" type="checkbox"/> HARD HAT <input type="checkbox"/> TY-VEK <input checked="" type="checkbox"/> SAFETY VEST | |
| CONTACT PERSON Ramon Longoria | | SPECIAL HANDLING PROCEDURES: | |
| SIGNATURE OF AUTHORIZED AGENT/TITLE | DATE | | |
| *  | 2/25/10 | | |
| GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR Part 261 or title 22 of the California code of regulations, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if the waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions, I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR Part 268 and is no longer a hazardous waste as defined by 40 CFR Part 261. | | RECEIVING FACILITY | |
| WASTE TYPE: | | | |
| <input type="checkbox"/> DISPOSAL <input type="checkbox"/> SLUDGE <input type="checkbox"/> CONSTRUCTION <input type="checkbox"/> WOOD <input type="checkbox"/> DEBRIS <input checked="" type="checkbox"/> OTHER <i>Soil</i> <input type="checkbox"/> SPECIAL WASTE | | | |
| GENERATING FACILITY | | | |

| | | | |
|---|-------------|--|--|
| TRANSPORTER Golden Gate Tank Removal | | NOTES: | |
| ADDRESS 5750 Mission St. | | VEHICLE LICENSE NUMBER: 5J29490 | |
| CITY, STATE, ZIP San Francisco, CA 94110 | | TRUCK NUMBER: 501 | |
| PHONE (415) 512-1555 | | <input type="checkbox"/> END DUMP <input type="checkbox"/> BOTTOM DUMP <input type="checkbox"/> TRANSFER <input type="checkbox"/> ROLL-OFF(S) <input type="checkbox"/> FLAT-BED <input type="checkbox"/> VAN <input type="checkbox"/> DRUMS | |
| SIGNATURE OF AUTHORIZED AGENT OR DRIVER | DATE | | |
| *  | 2/25/10 | | |

| | | | |
|---|-------------|---|--------------------------------|
| I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate. | | CUBIC YARDS 100 | |
| REMARKS <i>933</i> | | DISPOSAL METHOD: (TO BE COMPLETED BY LANDFILL) | |
| | | <input type="checkbox"/> SOIL | <input type="checkbox"/> OTHER |
| FACILITY TICKET NUMBER | | <input type="checkbox"/> CONSTRUCTION DEBRIS | |
| | | <input type="checkbox"/> NON-FRIABLE ASBESTOS | |
| SIGNATURE OF AUTHORIZED AGENT | | <input type="checkbox"/> WOOD | |
| | | <input type="checkbox"/> ASH | |
| *  | DATE | <input type="checkbox"/> SPECIAL OTHER | |
| | 2/25/10 | | |

SCHEDULING MUST BE MADE PRIOR TO 3:00 P.M. THE DAY PRIOR TO EXPECTED ARRIVAL • ANY UNSCHEDULED LOADS ARE SUBJECT TO REFUSAL UPON ARRIVAL. ONGOING DAILY DELIVERIES MUST BE SCHEDULED WITH THE LANDFILL THE DAY BEFORE.

Keller Canyon
Sanitary Landfill
901 Bailey Road
Pittsburg, CA 94565
Phone (925) 458 9800
Fax (925) 458 9891

Coffin Butte
Landfill
2897 Coffin Butte Road
Corvallis, OR 97330
Phone (541) 745 2018
Fax (541) 745 3826

Ox Mountain
Sanitary Landfill
12310 San Mateo Road
Half Moon Bay, CA 94019
Phone (650) 726 1819
Fax (650) 726-9183

Newby Island
Sanitary Landfill
1601 Dixon Landing Road
Milpitas, CA 95035
Phone (408) 945-2800
Fax (408) 262-2871

Forward
Landfill
9999 S. Auslin Road
Manteca, CA 95336
Phone (209) 982 4298
Fax (209) 982 1009

NON-HAZARDOUS WASTE MANIFEST

GENERATOR
San Lorenzo Unified School District
MAILING ADDRESS
15510 Usher Street
CITY, STATE, ZIP
San Lorenzo, CA 94589
PHONE
(510) 317-4837
CONTACT PERSON
Karen Langmaid
SIGNATURE OF AUTHORIZED AGENT / TITLE
[Signature] DATE
8/25/10

WASTE IDENTIFICATION NUMBER
51271012937
REQUIRED PERSONAL PROTECTIVE EQUIPMENT
 GLOVES GOGGLES RESPIRATOR HARD HAT
 TY-VEK SAFETY VEST
SPECIAL HANDLING PROCEDURES:

GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR Part 261 or title 22 of the California code of regulations, has been properly described, classified and packaged and is in proper condition for transport on according to applicable regulations; AND, if the waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions, I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR Part 268 and is no longer a hazardous waste as defined by 40 CFR Part 261.

WASTE TYPE:
 DISPOSAL SLUDGE
 CONSTRUCTION WOOD
 DEBRIS OTHER *soil*
 SPECIAL WASTE
GENERATING FACILITY
50 E Lewelling Blvd SAN LORENZO

RECEIVING FACILITY

TRANSPORTER
Golden Gate Truck Removal - FA Poli
ADDRESS
1738 Mission Street - 124 So Maple Av
CITY, STATE, ZIP
San Francisco, CA 94110 - So San Francisco
PHONE
650 589 7529
SIGNATURE OF AUTHORIZED AGENT OR DRIVER
[Signature] DATE
8/25/10

NOTES: VEHICLE LICENSE NUMBER **9B 39783** TRUCK NUMBER **RRT 26**
END DUMP BOTTOM DUMP TRANSFER
ROLL-OFF(S) FLAT-BED VAN DRUMS

I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.
REMARKS
058721
FACILITY TICKET NUMBER
SIGNATURE OF AUTHORIZED AGENT
[Signature] DATE
8/25/10

CUBIC YARDS
2040
DISPOSAL METHOD (TO BE COMPLETED BY LANDFILL)
DISPOSE OTHER
 SOIL
 CONSTRUCTION DEBRIS
 NON-FRIABLE ASBESTOS
 WOOD
 ASH
 SPECIAL OTHER

SCHEDULING MUST BE MADE PRIOR TO 3:00 P.M. THE DAY PRIOR TO EXPECTED ARRIVAL. ANY UNSCHEDULED LOADS ARE SUBJECT TO REJECTION UPON ARRIVAL. ONGOING DAILY DELIVERIES MUST BE SCHEDULED WITH THE LANDFILL THE DAY BEFORE.

Keller Canyon
Sanitary Landfill
901 Bailey Road
Pittsburg, CA 94565
Phone (925) 458-9800
Fax (925) 458-9891




Coffin Butte
Landfill
28972 Coffin Butte Road
Corvallis, OR 97330
Phone (541) 745-1018
Fax (541) 745-3826

Ox Mountain
Sanitary Landfill
12310 San Mateo Road
Half Moon Bay, CA 94019
Phone (650) 726-1819
Fax (650) 726-9183

Newby Island
Sanitary Landfill
1601 Dixon Landing Road
Milpitas, CA 95035
Phone (408) 945-2800
Fax (408) 262-2871

Forward
Landfill
9999 S. Austin Road
Manteca, CA 95336
Phone (209) 982-4298
Fax (209) 982-1009

NON-HAZARDOUS WASTE MANIFEST

| | | | |
|--|--|--|--|
| GENERATOR San Lorenzo Unified School District MAILING ADDRESS 15510 Usher Street CITY, STATE, ZIP San Lorenzo, CA 94580 PHONE (510) 317-4837 CONTACT PERSON Karen Langmaid SIGNATURE OF AUTHORIZED AGENT / TITLE  DATE 8/24/10 | | 51271012937 REQUIRED PERSONAL PROTECTIVE EQUIPMENT: <input checked="" type="checkbox"/> GLOVES <input type="checkbox"/> GOGGLES <input type="checkbox"/> RESPIRATOR <input checked="" type="checkbox"/> HARD HAT <input type="checkbox"/> TY-VEK <input checked="" type="checkbox"/> SAFETY VEST SPECIAL HANDLING PROCEDURES: | |
| GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR Part 261 or title 22 of the California code of regulations, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations, AND, if the waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions, I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR Part 268 and is no longer a hazardous waste as defined by 40 CFR Part 261. | | RECEIVING FACILITY | |
| WASTE TYPE: <input type="checkbox"/> DISPOSAL <input type="checkbox"/> SLUDGE <input type="checkbox"/> CONSTRUCTION <input type="checkbox"/> WOOD <input type="checkbox"/> DEBRIS <input checked="" type="checkbox"/> OTHER <i>Soil</i> <input type="checkbox"/> SPECIAL WASTE | | | |
| GENERATING FACILITY 50 E Lewelling Blvd SAN LORENZO | | | |
| TRANSPORTER Golden Gate Tank Removal <i>F.A. Pol. Trading</i> ADDRESS 3720 Mission Street <i>124 S. Maple Ave</i> CITY, STATE, ZIP San Francisco CA 94110 <i>S. San Francisco, CA</i> PHONE (415) 774-1111 <i>(650) 589-7020</i> SIGNATURE OF AUTHORIZED AGENT OR DRIVER  DATE 8/24 | | NOTES: VEHICLE LICENSE NUMBER TRUCK NUMBER 9B39783 RRT 26 <input checked="" type="checkbox"/> END DUMP <input type="checkbox"/> BOTTOM DUMP <input type="checkbox"/> TRANSFER <input type="checkbox"/> ROLL-OFF(S) <input type="checkbox"/> FLAT-BED <input type="checkbox"/> VAN <input type="checkbox"/> DRUMS | |
| I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate. | | CUBIC YARDS <i>20</i> DISPOSAL METHOD. (TO BE COMPLETED BY LANDFILL) <input type="checkbox"/> DISPOSE <input type="checkbox"/> OTHER | |
| REMARKS <i>20552</i> | | <input type="checkbox"/> SOIL <input type="checkbox"/> CONSTRUCTION DEBRIS <input type="checkbox"/> NON-FRIABLE ASBESTOS <input type="checkbox"/> WOOD <input type="checkbox"/> ASH <input checked="" type="checkbox"/> SPECIAL OTHER | |
| FACILITY TICKET NUMBER SIGNATURE OF AUTHORIZED AGENT  DATE 8/24/10 | | | |

SCHEDULING MUST BE MADE PRIOR TO 3:00 P.M. THE DAY PRIOR TO EXPECTED ARRIVAL. ANY UNSCHEDULED LOADS ARE SUBJECT TO REFUSAL UPON ARRIVAL. ONGOING DAILY DELIVERIES MUST BE SCHEDULED WITH THE LANDFILL THE DAY BEFORE.

Keller Canyon
Sanitary Landfill
901 Bailey Road
Pittsburg, CA 94565
Phone (925) 458-9800
Fax (925) 458-9891

Coffin Butte
Landfill
28972 Coffin Butte Road
Corvallis, OR 97330
Phone (541) 745 2018
Fax (541) 745-3826

Ox Mountain
Sanitary Landfill
12310 San Mateo Road
Half Moon Bay, CA 94019
Phone (650) 726 1819
Fax (650) 726-9183

Newby Island
Sanitary Landfill
1601 Dixon Landing Road
Milpitas, CA 95035
Phone (408) 945-2800
Fax (408) 262-2871

Forward
Landfill
9999 S. Austin Road
Manteca, CA 95336
Phone (209) 982 4298
Fax (209) 982-1009

NON-HAZARDOUS WASTE MANIFEST

GENERATOR
San Lorenzo Unified School District
 MAILING ADDRESS
15510 Usher Street
 CITY, STATE, ZIP
San Lorenzo, CA 94580
 PHONE
(510) 317-4837
 CONTACT PERSON
Karen Langness
 SIGNATURE OF AUTHORIZED AGENT / TITLE
 DATE
8/24/10
 GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR Part 261 or title 22 of the California code of regulations, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations, AND, if the waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions, I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR Part 268 and is no longer a hazardous waste as defined by 40 CFR Part 261.
 WASTE TYPE:
 DISPOSAL
 CONSTRUCTION
 DEBRIS
 SPECIAL WASTE
 SLUDGE
 WOOD
 OTHER *Soil*
 GENERATING FACILITY
50 E Lewelling Blvd SAN LORENZO

WASTE ACCEPTANCE NO.
51271012937
 REQUIRED PERSONAL PROTECTIVE EQUIPMENT
 GLOVES GOGGLES RESPIRATOR HARD HAT
 TY-VEK SAFETY VEST
 SPECIAL HANDLING PROCEDURES:
 RECEIVING FACILITY

TRANSPORTER
Golden Gate Truck Removal
 ADDRESS
3730 Mission Street 124 S Maple Ave
 CITY, STATE, ZIP
San Francisco, CA 94110 5 San Francisco, CA 94108
 PHONE
(650) 589-7529
 SIGNATURE OF AUTHORIZED AGENT OR DRIVER
 DATE
M.E. Kelley 8/24/10

NOTES: VEHICLE LICENSE NUMBER TRUCK NUMBER
9C33159 SF49
 END DUMP BOTTOM DUMP TRANSFER

 ROLL-OFF(S) FLAT-BED VAN DRUMS

I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.
 REMARKS
 FACILITY TICKET NUMBER
 SIGNATURE OF AUTHORIZED AGENT
 DATE
8/24/10

CUBIC YARDS
20
 DISPOSAL METHOD: (TO BE COMPLETED BY LANDFILL)

| | | |
|---|---------|-------|
| | DISPOSE | OTHER |
| <input type="checkbox"/> SOIL | | |
| <input type="checkbox"/> CONSTRUCTION DEBRIS | | |
| <input type="checkbox"/> NON-FRIABLE ASBESTOS | | |
| <input type="checkbox"/> WOOD | | |
| <input type="checkbox"/> ASH | | |
| <input type="checkbox"/> SPECIAL OTHER | | |

SCHEDULING MUST BE MADE PRIOR TO 3:00 P.M. THE DAY PRIOR TO EXPECTED ARRIVAL • ANY UNSCHEDULED LOADS ARE SUBJECT TO REFUSAL UPON ARRIVAL. ONGOING DAILY DELIVERIES MUST BE SCHEDULED WITH THE LANDFILL THE DAY BEFORE.

- Keller Canyon Sanitary Landfill
901 Bailey Road
Pittsburg, CA 94565
Phone (925) 458-9800
Fax (925) 458-9891
- Coffin Butte Landfill
28972 Coffin Butte Road
Corvallis, OR 97330
Phone (541) 745-2018
Fax (541) 745-3826
- Ox Mountain Sanitary Landfill
12310 San Mateo Road
Half Moon Bay, CA 94019
Phone (650) 726-1819
Fax (650) 726-9183
- Newby Island Sanitary Landfill
1601 Dixon Landing Road
Milpitas, CA 95035
Phone (408) 945-2800
Fax (408) 262-2871
- Forward Landfill
9999 S. Austin Road
Manteca, CA 95336
Phone (209) 982-4298
Fax (209) 982-1009

NON-HAZARDOUS WASTE MANIFEST

GENERATOR
San Lorenzo Unified School District
 MAILING ADDRESS
15510 Usher Street
 CITY, STATE, ZIP
San Lorenzo, CA 94580
 PHONE
(510) 317-4837
 CONTACT PERSON
Karen Langmaid
 SIGNATURE OF AUTHORIZED AGENT / TITLE
 DATE
 8/24/10
 GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR Part 261 or title 22 of the California code of regulations, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if the waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions, I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR Part 268 and is no longer a hazardous waste as defined by 40 CFR Part 261.
 WASTE TYPE:
 DISPOSAL
 CONSTRUCTION
 DEBRIS
 SPECIAL WASTE
 SLUDGE
 WOOD
 OTHER *Soil*
 GENERATING FACILITY
50 R Lewelling Blvd SAN LORENZO

51271012937

REQUIRED PERSONAL PROTECTIVE EQUIPMENT:
 GLOVES GOGGLES RESPIRATOR HARD HAT
 TY-VEK SAFETY VEST
 SPECIAL HANDLING PROCEDURES:
 RECEIVING FACILITY

TRANSPORTER
Golden Gate Truck Removal F.A. Poli Trucking
 ADDRESS
3730 Mission Street 124 S Maple Ave
 CITY, STATE, ZIP
San Francisco, CA 94110 S. San Francisco, CA 94080
 PHONE
(650) 589-7529
 SIGNATURE OF AUTHORIZED AGENT OR DRIVER
 DATE
 8/24/10

NOTES: VEHICLE LICENSE NUMBER **9B39783** TRUCK NUMBER **RRT 26**

| | | |
|-------------------------------------|--------------------------|--------------------------|
| END DUMP | BOTTOM DUMP | TRANSFER |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| ROLL-OFF(S) | FLAT-BED | VAN |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| | | DRUMS |
| | | <input type="checkbox"/> |

I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.

REMARKS
 FACILITY TICKET NUMBER
 SIGNATURE OF AUTHORIZED AGENT
 DATE
 8/24/10

CUBIC YARDS
 DISPOSAL METHOD (TO BE COMPLETED BY LANDFILL)

| | | |
|---|---------|-------|
| | DISPOSE | OTHER |
| <input type="checkbox"/> SOIL | | |
| <input type="checkbox"/> CONSTRUCTION DEBRIS | | |
| <input type="checkbox"/> NON-FRIABLE ASBESTOS | | |
| <input type="checkbox"/> WOOD | | |
| <input type="checkbox"/> ASH | | |
| <input type="checkbox"/> SPECIAL OTHER | | |

SCHEDULING MUST BE MADE PRIOR TO 3:00 P.M. THE DAY PRIOR TO EXPECTED ARRIVAL. ANY UNSCHEDULED LOADS ARE SUBJECT TO REFUSAL UPON ARRIVAL. ONGOING DAILY DELIVERIES MUST BE SCHEDULED WITH THE LANDFILL THE DAY BEFORE.

Keller Canyon
Sanitary Landfill

901 Bailey Road
Pittsburg, CA 94565
Phone (925) 458-9800
Fax (925) 458-9891

Coffin Butte
Landfill

28972 Coffin Butte Road
Corvallis, OR 97330
Phone (541) 745-2018
Fax (541) 745-3826

Ox Mountain
Sanitary Landfill

12310 San Mateo Road
Half Moon Bay, CA 94019
Phone (650) 726-1819
Fax (650) 726-9183

Newby Island
Sanitary Landfill

1601 Dixon Landing Road
Milpitas, CA 95035
Phone (408) 945-2800
Fax (408) 262-2871

Forward
Landfill

9999 S. Austin Road
Manteca, CA 95336
Phone (209) 982-4298
Fax (209) 982-1009

NON-HAZARDOUS WASTE MANIFEST

GENERATOR
San Lorenzo USD-5413

MAILING ADDRESS
15510 Usher St.

CITY, STATE, ZIP
San Lorenzo, CA 94580

PHONE
(510) 317-4837

CONTACT PERSON
Karen Langmaid

SIGNATURE OF AUTHORIZED AGENT / TITLE
[Signature]

DATE
8/24/00

WASTE ACCEPTANCE NO.
512710-12937

REQUIRED PERSONAL PROTECTIVE EQUIPMENT

GLOVES GOGGLES RESPIRATOR HARD HAT

TY-VEK SAFETY VEST

SPECIAL HANDLING PROCEDURES:

GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR Part 261 or title 22 of the California code of regulations, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if the waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions, I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR Part 268 and is no longer a hazardous waste as defined by 40 CFR Part 261.

WASTE TYPE:

DISPOSAL SLUDGE

CONSTRUCTION WOOD

DEBRIS OTHER

SPECIAL WASTE

GENERATING FACILITY
San Lorenzo School District

RECEIVING FACILITY

TRANSPORTER
Ed. Pol. Trucking

ADDRESS
174 S Maple Avenue

CITY, STATE, ZIP
San Francisco, CA 94080

PHONE
(415) 399-7079

SIGNATURE OF AUTHORIZED AGENT OR DRIVER
[Signature]

DATE
8/24/00

NOTES: VEHICLE LICENSE NUMBER *94B39783* TRUCK NUMBER *RR206*

END DUMP BOTTOM DUMP TRANSFER

ROLL-OFF(S) FLAT-BED VAN DRUMS

I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate.

REMARKS
058376

FACILITY TICKET NUMBER

SIGNATURE OF AUTHORIZED AGENT
[Signature]

DATE
8/24/00

CUBIC YARDS
20

DISPOSAL METHOD: (TO BE COMPLETED BY LANDFILL)

| | DISPOSE | OTHER |
|---|---------|-------|
| <input type="checkbox"/> SOIL | | |
| <input type="checkbox"/> CONSTRUCTION DEBRIS | | |
| <input type="checkbox"/> NON-FRIABLE ASBESTOS | | |
| <input type="checkbox"/> WOOD | | |
| <input type="checkbox"/> ASH | | |
| <input type="checkbox"/> SPECIAL OTHER | | |

SCHEDULING MUST BE MADE PRIOR TO 3:00 P.M. THE DAY PRIOR TO EXPECTED ARRIVAL. ANY UNSCHEDULED LOADS ARE SUBJECT TO REFUSAL UPON ARRIVAL. ONGOING DAILY DELIVERIES MUST BE SCHEDULED WITH THE LANDFILL THE DAY BEFORE.

Keller Canyon Sanitary Landfill
 901 Bailey Road
 Pittsburg, CA 94565
 Phone (925) 458-9800
 Fax (925) 458-9891

Coffin Butte Landfill
 28972 Coffin Butte Road
 Corvallis, OR 97330
 Phone (541) 745-2018
 Fax (541) 745-3826

Ox Mountain Sanitary Landfill
 12310 San Mateo Road
 Half Moon Bay, CA 94019
 Phone (650) 726-1819
 Fax (650) 726-9183

Newby Island Sanitary Landfill
 1601 Dixon Landing Road
 Milpitas, CA 95035
 Phone (408) 945-2800
 Fax (408) 262-2871

Forward Landfill
 9999 S. Austin Road
 Manteca, CA 95336
 Phone (209) 982-4298
 Fax (209) 982-1009

NON-HAZARDOUS WASTE MANIFEST

| | | | |
|--|--|--|------------------------------|
| GENERATOR <i>San Lorenzo JSD - 4215</i> | | WASTE ACCEPTANCE NO. <i>512710-12937</i> | |
| MAILING ADDRESS <i>15510 12th St</i> | | REQUIRED PERSONAL PROTECTIVE EQUIPMENT | |
| CITY, STATE, ZIP <i>San Lorenzo, CA 94580</i> | | <input type="checkbox"/> GLOVES <input type="checkbox"/> GOGGLES <input type="checkbox"/> RESPIRATOR <input type="checkbox"/> HARD HAT | |
| PHONE <i>(510) 317-4277</i> | | <input type="checkbox"/> TY-VEK <input type="checkbox"/> SAFETY VEST | |
| CONTACT PERSON <i>Karen Compton</i> | | SPECIAL HANDLING PROCEDURES: | |
| SIGNATURE OF AUTHORIZED AGENT / TITLE <i>[Signature]</i> | | DATE <i>8/24/10</i> | |
| GENERATOR'S CERTIFICATION: I hereby certify that the above named material is not a hazardous waste as defined by 40 CFR Part 261 of title 22 of the California code of regulations, has been properly described, classified and packaged, and is in proper condition for transportation according to applicable regulations; AND, if the waste is a treatment residue of a previously restricted hazardous waste subject to the Land Disposal Restrictions, I certify and warrant that the waste has been treated in accordance with the requirements of 40 CFR Part 268 and is no longer a hazardous waste as defined by 40 CFR Part 261. | | RECEIVING FACILITY | |
| WASTE TYPE: <input type="checkbox"/> DISPOSAL <input type="checkbox"/> SLUDGE <input type="checkbox"/> CONSTRUCTION <input type="checkbox"/> WOOD <input type="checkbox"/> DEBRIS <input type="checkbox"/> OTHER <input type="checkbox"/> SPECIAL WASTE | | | |
| GENERATING FACILITY <i>San Lorenzo School District</i> | | | |
| TRANSPORTER <i>F.H. Kelly Trucking</i> | | NOTES: VEHICLE LICENSE NUMBER <i>N579C33159</i> | TRUCK NUMBER <i>SF 49</i> |
| ADDRESS <i>124 S. Maple Avenue</i> | | | |
| CITY, STATE, ZIP <i>San Francisco, CA 94102</i> | | | |
| PHONE <i>(650) 529-7529</i> | | | |
| SIGNATURE OF AUTHORIZED AGENT OR DRIVER <i>[Signature]</i> | | DATE <i>8-24-10</i> | |
| I hereby certify that the above named material has been accepted and to the best of my knowledge the foregoing is true and accurate. | | CUBIC YARDS <i>202</i> | |
| REMARKS | | DISPOSAL METHOD: (TO BE COMPLETED BY LANDFILL) | |
| FACILITY TICKET NUMBER <i>115837</i> | | DISPOSE | |
| SIGNATURE OF AUTHORIZED AGENT <i>[Signature]</i> | | OTHER | |
| DATE <i>8/24/10</i> | | <input type="checkbox"/> SOIL | |
| | | <input type="checkbox"/> CONSTRUCTION DEBRIS | |
| | | <input type="checkbox"/> NON-FRIABLE ASBESTOS | |
| | | <input type="checkbox"/> WOOD | |
| | | <input type="checkbox"/> ASH | |
| | | <input type="checkbox"/> SPECIAL OTHER | |

SCHEDULING MUST BE MADE PRIOR TO 3:00 P.M. THE DAY PRIOR TO EXPECTED ARRIVAL • ANY UNSCHEDULED LOADS ARE SUBJECT TO REFUSAL UPON ARRIVAL. ONGOING DAILY DELIVERIES MUST BE SCHEDULED WITH THE LANDFILL THE DAY BEFORE.

**INTERNATIONAL DISPOSAL CORP.
OF CALIFORNIA**

512770363

"Newby Island Resource Recovery Park
1601 Dixon Landing Road, Milpitas, CA 95035
Tel: (408) 262-1401 Fax: (408) 945-0667

FACILITY LOCATION
Off Interstate 880, Exit at
Dixon Landing Road West

008245
GOLDEN GATE TANK REMOVAL INC
3730 MISSION STREET
ATTN: ACCOUNTS PAYABLE
SAN FRANCISCO, CA 94110-5830
Contract: #51271012937

| | | |
|--------------------|-------------|----------|
| SITE | TICKET | GRID |
| Y1 | 058379 | |
| WEIGHMASTER | | |
| HF48221 HUMBERTO F | | |
| DATE IN | TIME IN | |
| 24 August 2010 | 9:55 am | |
| DATE OUT | TIME OUT | |
| 24 August 2010 | 10:19 am | |
| VEHICLE | | ROLL OFF |
| BF49 | | |
| REFERENCE | ORIGIN | |
| | San Lorenzo | |

02 Gross Weight 63,100.00 lb Inbound - SW-Outside
Stored Tare Weight 34,640.00 lb
Net Weight 28,460.00 lb 14.23 TN

| QTY. | UNIT | DESCRIPTION | RATE | EXTENSION | TAX | TOTAL |
|-------|------|--------------------------|------|-----------|-----|-------|
| 14.23 | TN | 06 C53S1W-CONT SOIL | | | | |
| 1.00 | LD | 03 C53E1NVIROMENTAL FEE | | | | |
| 1.00 | LD | 01 C53F1UEL RECOVERY FEE | | | | |

Route: 0000
Work Order: 000000

109366

ME Kelly **#50**

WARNING: Transporting any unauthorized hazardous waste to this facility for disposal is prohibited by law. Persons violating this prohibition are subject to civil and criminal prosecution.

IMPORTANT: Read site rules on back side of this ticket.
REV - 11/09

DRIVER'S SIGNATURE

NS - 023

| |
|------------|
| NET AMOUNT |
| TENDERED |
| CHANGE |
| CHECK NO. |

**INTERNATIONAL DISPOSAL CORP.
OF CALIFORNIA**

512770402

"Newby Island Resource Recovery Park
1601 Dixon Landing Road, Milpitas, CA 95035
Tel: (408) 262-1401 Fax: (408) 945-0667

FACILITY LOCATION
Off Interstate 880, Exit at
Dixon Landing Road West

008245
GOLDEN GATE TANK REMOVAL INC
3730 MISSION STREET
ATTN: ACCOUNTS PAYABLE
SAN FRANCISCO, CA 94110-5830
Contract: #51271012937

| | | |
|--------------------|-------------|----------|
| SITE | TICKET | GRID |
| Y1 | 058442 | |
| WEIGHMASTER | | |
| HF48221 HUMBERTO F | | |
| DATE IN | TIME IN | |
| 24 August 2010 | 10:51 am | |
| DATE OUT | TIME OUT | |
| 24 August 2010 | 11:28 am | |
| VEHICLE | | ROLL OFF |
| G0TR501 | | |
| REFERENCE | ORIGIN | |
| | San Lorenzo | |

02 Gross Weight 38,920.00 lb Inbound - SW-Outside
Stored Tare Weight 20,860.00 lb
Net Weight 18,060.00 lb 9.03 TN

| QTY. | UNIT | DESCRIPTION | RATE | EXTENSION | TAX | TOTAL |
|------|------|--------------------------|------|-----------|-----|-------|
| 9.03 | TN | 06 C53S1W-CONT SOIL | | | | |
| 1.00 | LD | 03 C53E1NVIROMENTAL FEE | | | | |
| 1.00 | LD | 01 C53F1UEL RECOVERY FEE | | | | |

Route: 0000
Work Order: 000000

22063

Richard Kelly

WARNING: Transporting any unauthorized hazardous waste to this facility for disposal is prohibited by law. Persons violating this prohibition are subject to civil and criminal prosecution.

IMPORTANT: Read site rules on back side of this ticket.
REV - 11/09

DRIVER'S SIGNATURE

NS - 023

| |
|------------|
| NET AMOUNT |
| TENDERED |
| CHANGE |
| CHECK NO. |

512770521

**INTERNATIONAL DISPOSAL CORP.
OF CALIFORNIA**

"Newby Island Resource Recovery Park
1601 Dixon Landing Road, Milpitas, CA 95035
Tel: (408) 262-1401 Fax: (408) 945-0667

FACILITY LOCATION
Off Interstate 880, Exit at
Dixon Landing Road West

008245
GOLDEN GATE TANK REMOVAL INC
3730 MISSION STREET
ATTN: ACCOUNTS PAYABLE
SAN FRANCISCO, CA 94110-5830
Contract: #51271012937

| | | |
|--------------------|-------------|----------|
| SITE | TICKET | GRID |
| Y1 | 058582 | |
| WEIGHMASTER | | |
| MP48221 HUMBERTO P | | |
| DATE IN | TIME IN | |
| 24 August 2010 | 3:26 pm | |
| DATE OUT | TIME OUT | |
| 24 August 2010 | 3:26 pm | |
| VEHICLE | | ROLL OFF |
| G0TR501 | | |
| REFERENCE | ORIGIN | |
| | San Lorenzo | |

| | | |
|--------------------|--------------|----------------------|
| Gross Weight | 40,760.00 lb | Inbound - SW-Outside |
| Stored Tare Weight | 20,860.00 lb | |
| Net Weight | 19,900.00 lb | 9.95 TN |

| QTY. | UNIT | DESCRIPTION | RATE | EXTENSION | TAX | TOTAL |
|------|------|-----------------------------|------|-----------|-----|-------|
| 9.95 | TN | 00 C53S1W--CONT SOIL | | | | |
| 1.00 | LD | 03 C53E1N ENVIRONMENTAL FEE | | | | |
| 1.00 | LD | 01 C53F1JUEL RECOVERY FEE | | | | |

| |
|------------|
| NET AMOUNT |
| TENDERED |
| CHANGE |
| CHECK NO. |

Route: 0000
Work Order: 000000

22063

WARNING: Transporting any unauthorized hazardous waste to this facility for disposal is prohibited by law. Persons violating this prohibition are subject to civil and criminal prosecution.

IMPORTANT: Read site rules on back side of this ticket.
REV - 11/09

DRIVER'S SIGNATURE *[Signature]*

NS - 023

512770469

**INTERNATIONAL DISPOSAL CORP.
OF CALIFORNIA**

"Newby Island Resource Recovery Park
1601 Dixon Landing Road, Milpitas, CA 95035
Tel: (408) 262-1401 Fax: (408) 945-0667

FACILITY LOCATION
Off Interstate 880, Exit at
Dixon Landing Road West

008245
GOLDEN GATE TANK REMOVAL INC
3730 MISSION STREET
ATTN: ACCOUNTS PAYABLE
SAN FRANCISCO, CA 94110-5830
Contract: #51271012937

| | | |
|-------------------|-------------|----------|
| SITE | TICKET | GRID |
| Y1 | 058529 | |
| WEIGHMASTER | | |
| EA00023 Estevan A | | |
| DATE IN | TIME IN | |
| 24 August 2010 | 1:27 pm | |
| DATE OUT | TIME OUT | |
| 24 August 2010 | 1:27 pm | |
| VEHICLE | | ROLL OFF |
| G0TR501 | | |
| REFERENCE | ORIGIN | |
| | San Lorenzo | |

| | | |
|--------------------|--------------|----------------------|
| 02 Gross Weight | 42,080.00 lb | Inbound - SW-Outside |
| Stored Tare Weight | 20,860.00 lb | |
| Net Weight | 21,220.00 lb | 10.61 TN |

| QTY. | UNIT | DESCRIPTION | RATE | EXTENSION | TAX | TOTAL |
|-------|------|-----------------------------|------|-----------|-----|-------|
| 10.61 | TN | 00 C53S1W--CONT SOIL | | | | |
| 1.00 | LD | 03 C53E1N ENVIRONMENTAL FEE | | | | |
| 1.00 | LD | 01 C53F1JUEL RECOVERY FEE | | | | |

| |
|------------|
| NET AMOUNT |
| TENDERED |
| CHANGE |
| CHECK NO. |

Route: 0000
Work Order: 000000

42102

WARNING: Transporting any unauthorized hazardous waste to this facility for disposal is prohibited by law. Persons violating this prohibition are subject to civil and criminal prosecution.

IMPORTANT: Read site rules on back side of this ticket.
REV - 11/09

DRIVER'S SIGNATURE *[Signature]*

NS - 023

**INTERNATIONAL DISPOSAL CORP.
OF CALIFORNIA**

512770718

"Newby Island Resource Recovery Park
1601 Dixon Landing Road, Milpitas, CA 95035
Tel: (408) 262-1401 Fax: (408) 945-0667

FACILITY LOCATION
Off Interstate 880, Exit at
Dixon Landing Road West

008245
GOLDEN GATE TANK REMOVAL INC
3730 MISSION STREET
ATTN: ACCOUNTS PAYABLE
SAN FRANCISCO, CA 94110-5830
Contract: #51271012937

| | | |
|-------------------|-------------|----------|
| SITE | TICKET | GRID |
| Y1 | 058853 | |
| WEIGHMASTER | | |
| EA00023 Estevan A | | |
| DATE IN | TIME IN | |
| 25 August 2010 | 12:00 pm | |
| DATE OUT | TIME OUT | |
| 25 August 2010 | 12:00 pm | |
| VEHICLE | | ROLL OFF |
| GGTR501 | | |
| REFERENCE | ORIGIN | |
| | San Lorenzo | |

02 Gross Weight 41,380.00 lb Inbound - SW-Outside
Stored Tare Weight 20,860.00 lb
Net Weight 20,520.00 lb 10.26 TN

| QTY. | UNIT | DESCRIPTION | RATE | EXTENSION | TAX | TOTAL |
|-------|------|-------------------------|------|-----------|-----|-------|
| 10.26 | TN | 06 C53SIW-CONT SOIL | | | | |
| 1.00 | LD | 03 C53EINVIROMENTAL FEE | | | | |
| 1.00 | LD | 01 C53FUEL RECOVERY FEE | | | | |


Route:0000
Work Order: 000000

22057

WARNING: Transporting any unauthorized hazardous waste to this facility for disposal is prohibited by law. Persons violating this prohibition are subject to civil and criminal prosecution.

IMPORTANT: Read site rules on back side of this ticket.
REV - 11/09

DRIVER'S SIGNATURE



NS - 023

| |
|------------|
| NET AMOUNT |
| TENDERED |
| CHANGE |
| CHECK NO. |

**INTERNATIONAL DISPOSAL CORP.
OF CALIFORNIA**

512770793

"Newby Island Resource Recovery Park
1601 Dixon Landing Road, Milpitas, CA 95035
Tel: (408) 262-1401 Fax: (408) 945-0667

FACILITY LOCATION
Off Interstate 880, Exit at
Dixon Landing Road West

008245
GOLDEN GATE TANK REMOVAL INC
3730 MISSION STREET
ATTN: ACCOUNTS PAYABLE
SAN FRANCISCO, CA 94110-5830
Contract: #51271012937

| | | |
|--------------------|-------------|----------|
| SITE | TICKET | GRID |
| Y1 | 058933 | |
| WEIGHMASTER | | |
| HP48221 HUMBERTO F | | |
| DATE IN | TIME IN | |
| 25 August 2010 | 2:36 pm | |
| DATE OUT | TIME OUT | |
| 25 August 2010 | 2:36 pm | |
| VEHICLE | | ROLL OFF |
| GGTR501 | | |
| REFERENCE | ORIGIN | |
| | San Lorenzo | |

Gross Weight 33,960.00 lb Inbound - SW-Outside
Stored Tare Weight 20,860.00 lb
Net Weight 13,100.00 lb 6.55 TN

| QTY. | UNIT | DESCRIPTION | RATE | EXTENSION | TAX | TOTAL |
|------|------|-------------------------|------|-----------|-----|-------|
| 6.55 | TN | 06 C53SIW-CONT SOIL | | | | |
| 1.00 | LD | 03 C53EINVIROMENTAL FEE | | | | |
| 1.00 | LD | 01 C53FUEL RECOVERY FEE | | | | |


Route:0000
Work Order: 000000

102973

WARNING: Transporting any unauthorized hazardous waste to this facility for disposal is prohibited by law. Persons violating this prohibition are subject to civil and criminal prosecution.

IMPORTANT: Read site rules on back side of this ticket.
REV - 11/09

DRIVER'S SIGNATURE



NS - 023

| |
|------------|
| NET AMOUNT |
| TENDERED |
| CHANGE |
| CHECK NO. |

**INTERNATIONAL DISPOSAL CORP.
OF CALIFORNIA**

512770507

"Newby Island Resource Recovery Park
1601 Dixon Landing Road, Milpitas, CA 95035
Tel: (408) 262-1401 Fax: (408) 945-0667

FACILITY LOCATION
Off Interstate 880, Exit at
Dixon Landing Road West

008245
GOLDEN GATE TANK REMOVAL INC
3730 MISSION STREET
ATTN: ACCOUNTS PAYABLE
SAN FRANCISCO, CA 94110-5830
Contract: #51271012937

| | | |
|-----------------------------------|-----------------------|----------|
| SITE Y1 | TICKET 058567 | GRID |
| WEIGHMASTER #P48221 HUMBERTO P | | |
| DATE IN 24 August 2010 | TIME IN 2:42 pm | |
| DATE OUT 24 August 2010 | TIME OUT 2:42 pm | |
| VEHICLE 5F49 | | ROLL OFF |
| REFERENCE | ORIGIN San Lorenzo | |

| | |
|----------------------------------|----------------------|
| Gross Weight 64,400.00 lb | Inbound - SW-Outside |
| Stored Tare Weight 34,640.00 lb | |
| Net Weight 29,760.00 lb 14.88 TN | |

| QTY. | UNIT | DESCRIPTION | RATE | EXTENSION | TAX | TOTAL |
|-------|------|---------------------------|------|-----------|-----|-------|
| 14.88 | TN | 06 C53S1W-COAT SOIL | | | | |
| 1.00 | LD | 00 C53E1NVIROMENTAL FEE | | | | |
| 1.00 | LD | 01 C53F1FUEL RECOVERY FEE | | | | |

Route: 0000
Work Order: 000000

22061

Handwritten: #50

WARNING: Transporting any unauthorized hazardous waste to this facility for disposal is prohibited by law. Persons violating this prohibition are subject to civil and criminal prosecution.

IMPORTANT: Read site rules on back side of this ticket.

DRIVER'S SIGNATURE

Handwritten Signature: M & Kelly

| |
|------------|
| NET AMOUNT |
| TENDERED |
| CHANGE |
| CHECK NO. |

NS - 023

**INTERNATIONAL DISPOSAL CORP.
OF CALIFORNIA**

512767724

"Newby Island Resource Recovery Park
1601 Dixon Landing Road, Milpitas, CA 95035
Tel: (408) 262-1401 Fax: (408) 945-0667

FACILITY LOCATION
Off Interstate 880, Exit at
Dixon Landing Road West

008245
GOLDEN GATE TANK REMOVAL INC
3730 MISSION STREET
ATTN: ACCOUNTS PAYABLE
SAN FRANCISCO, CA 94110-5830
Contract: #51271012937

| | | |
|-----------------------------------|-----------------------|----------|
| SITE Y1 | TICKET 058721 | GRID |
| WEIGHMASTER #T00071 Josefina M | | |
| DATE IN 25 August 2010 | TIME IN 9:30 am | |
| DATE OUT 25 August 2010 | TIME OUT 9:30 am | |
| VEHICLE RT24 | | ROLL OFF |
| REFERENCE | ORIGIN San Lorenzo | |

| | |
|----------------------------------|----------------------|
| 02 Gross Weight 57,060.00 lb | Inbound - SW-Outside |
| Stored Tare Weight 31,420.00 lb | |
| Net Weight 25,640.00 lb 12.82 TN | |

| QTY. | UNIT | DESCRIPTION | RATE | EXTENSION | TAX | TOTAL |
|-------|------|---------------------------|------|-----------|-----|-------|
| 12.82 | TN | 06 C53S1W-COAT SOIL | | | | |
| 1.00 | LD | 00 C53E1NVIROMENTAL FEE | | | | |
| 1.00 | LD | 01 C53F1FUEL RECOVERY FEE | | | | |

Route: 0000
Work Order: 000000

22058

Handwritten Signature

WARNING: Transporting any unauthorized hazardous waste to this facility for disposal is prohibited by law. Persons violating this prohibition are subject to civil and criminal prosecution.

IMPORTANT: Read site rules on back side of this ticket.

DRIVER'S SIGNATURE

| |
|------------|
| NET AMOUNT |
| TENDERED |
| CHANGE |
| CHECK NO. |

**INTERNATIONAL DISPOSAL CORP.
OF CALIFORNIA**

512770492

"Newby Island Resource Recovery Park
1601 Dixon Landing Road, Milpitas, CA 95035
Tel: (408) 262-1401 Fax: (408) 945-0667

FACILITY LOCATION
Off Interstate 880, Exit at
Dixon Landing Road West

008245
GOLDEN GATE TANK REMOVAL INC
3730 MISSION STREET
ATTN: ACCOUNTS PAYABLE
SAN FRANCISCO, CA 94110-5630
Contract: #51271012937


| | | |
|-----------------------------------|-----------------------|----------|
| SITE Y1 | TICKET 058552 | GRID |
| WEIGHMASTER HP48221 HUMBERTO F | | |
| DATE IN 24 August 2010 | TIME IN 2:13 pm | |
| DATE OUT 24 August 2010 | TIME OUT 2:13 pm | |
| VEHICLE RRT26 | | ROLL OFF |
| REFERENCE | ORIGIN San Lorenzo | |

| | |
|----------------------------------|----------------------|
| Gross Weight 59,940.00 lb | Inbound - SW-Outside |
| Stored Tare Weight 31,420.00 lb | |
| Net Weight 28,520.00 lb 14.26 TN | |

| QTY. | UNIT | DESCRIPTION | RATE | EXTENSION | TAX | TOTAL |
|-------|------|---------------------------|------|-----------|-----|-------|
| 14.26 | TN | 00 E33E1W-CONT SOIL | | | | |
| 1.00 | LD | 03 E33E1ENVIRONMENTAL FEE | | | | |
| 1.00 | LD | 01 E33E1FUEL RECOVERY FEE | | | | |

Route: 0000
Work Order: 000000

22060



WARNING: Transporting any unauthorized hazardous waste to this facility for disposal is prohibited by law. Persons violating this prohibition are subject to civil and criminal prosecution.

IMPORTANT: Read site rules on back side of this ticket.
REV - 11/09

DRIVER'S SIGNATURE _____

| |
|------------|
| NET AMOUNT |
| TENDERED |
| CHANGE |
| CHECK NO. |

NS - 023

**INTERNATIONAL DISPOSAL CORP.
OF CALIFORNIA**

512770426

"Newby Island Resource Recovery Park
1601 Dixon Landing Road, Milpitas, CA 95035
Tel: (408) 262-1401 Fax: (408) 945-0667

FACILITY LOCATION
Off Interstate 880, Exit at
Dixon Landing Road West

008245
GOLDEN GATE TANK REMOVAL INC
3730 MISSION STREET
ATTN: ACCOUNTS PAYABLE
SAN FRANCISCO, CA 94110-5630
Contract: #5127107431


| | | |
|-----------------------------------|-----------------------|----------|
| SITE Y1 | TICKET 058474 | GRID |
| WEIGHMASTER HP48221 HUMBERTO F | | |
| DATE IN 24 August 2010 | TIME IN 12:08 pm | |
| DATE OUT 24 August 2010 | TIME OUT 12:08 pm | |
| VEHICLE RRT26 | | ROLL OFF |
| REFERENCE | ORIGIN San Lorenzo | |

| | |
|----------------------------------|----------------------|
| Gross Weight 59,320.00 lb | Inbound - SW-Outside |
| Stored Tare Weight 31,420.00 lb | |
| Net Weight 27,900.00 lb 13.95 TN | |

| QTY. | UNIT | DESCRIPTION | RATE | EXTENSION | TAX | TOTAL |
|-------|------|---------------------------|------|-----------|-----|-------|
| 13.95 | TN | 00 E30E1W-CONT SOIL | | | | |
| 1.00 | LD | 03 E30E1ENVIRONMENTAL FEE | | | | |
| 1.00 | LD | 01 E30E1FUEL RECOVERY FEE | | | | |

Route: 0000
Work Order: 000000

22062



WARNING: Transporting any unauthorized hazardous waste to this facility for disposal is prohibited by law. Persons violating this prohibition are subject to civil and criminal prosecution.

IMPORTANT: Read site rules on back side of this ticket.

DRIVER'S SIGNATURE _____

| |
|------------|
| NET AMOUNT |
| TENDERED |
| CHANGE |
| CHECK NO. |

NS - 023

INTERNATIONAL DISPOSAL CORP.
OF CALIFORNIA

512770361

"Newby Island Resource Recovery Park
1601 Dixon Landing Road, Milpitas, CA 95035
Tel: (408) 262-1401 Fax: (408) 945-0667

FACILITY LOCATION
Off Interstate 880, Exit at
Dixon Landing Road West

008245
GOLDEN GATE TANK REMOVAL INC
3730 MISSION STREET
ATTN: ACCOUNTS PAYABLE
SAN FRANCISCO, CA 94110-5830
Contract: #51271012937


| | | |
|--------------------|-------------|----------|
| SITE | TICKET | GRID |
| Y1 | 058376 | |
| WEIGHMASTER | | |
| HF48221 HUMBERTO F | | |
| DATE IN | TIME IN | |
| 24 August 2010 | 9:59 am | |
| DATE OUT | TIME OUT | |
| 24 August 2010 | 10:17 am | |
| VEHICLE | | ROLL OFF |
| RRT24 | | |
| REFERENCE | ORIGIN | |
| | San Lorenzo | |

02 Gross Weight 54,640.00 lb Inbound - SW-Outside
Stored Tare Weight 31,420.00 lb
Net Weight 23,220.00 lb 11.61 TN

| QTY. | UNIT | DESCRIPTION | RATE | EXTENSION | TAX | TOTAL |
|-------|------|---------------------------|------|-----------|-----|-------|
| 11.61 | TN | UG [53S]W-COAT SOIL | | | | |
| 1.00 | LD | 03 [53E]ENVIRONMENTAL FEE | | | | |
| 1.00 | LD | 01 [53F]FUEL RECOVERY FEE | | | | |

Route: 0000
Work Order: 000000

109365



| |
|------------|
| NET AMOUNT |
| TENDERED |
| CHANGE |
| CHECK NO. |

WARNING: Transporting any unauthorized hazardous waste to this facility for disposal is prohibited by law. Persons violating this prohibition are subject to civil and criminal prosecution.

IMPORTANT: Read site rules on back side of this ticket.


DRIVER'S SIGNATURE

7 - 11/09

NS - 023

UNDERGROUND STORAGE TANK UNAUTHORIZED RELEASE IDENTIFICATION CONTAMINATION SITE REPORT

FAX ID

| | | | | | |
|--|--|---|---|--|--|
| EMERGENCY <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | HAS STATE OFFICE OF EMERGENCY SERVICES REPORT BEEN FILED? <input type="checkbox"/> Yes <input type="checkbox"/> No | | FOR LOCAL AGENCY USE ONLY I HEREBY CERTIFY THAT I AM A DESIGNATED GOVERNMENT EMPLOYEE AND THAT I HAVE REPORTED THIS INFORMATION TO LOCAL OFFICIALS PURSUANT TO SECTION 25180.7 OF THE HEALTH AND SAFETY CODE. | |
| REPORT DATE 8/19/10 | | CASE # | | SIGNED _____ DATE _____ | |
| REPORTED BY | NAME OF INDIVIDUAL FILING REPORT Annette Chen | | PHONE (415) 512-1555 | | SIGNATURE  |
| | REPRESENTING <input type="checkbox"/> LOCAL AGENCY <input type="checkbox"/> REGIONAL BOARD <input type="checkbox"/> OWNER/OPERATOR <input checked="" type="checkbox"/> OTHER... contractor | | COMPANY OR AGENCY NAME Golden Gate Tank Removal, Inc. | | |
| | ADDRESS 3730 Mission Street San Francisco CA 94110 | | | | |
| RESPONSIBLE PARTY | NAME SAN LORENZO UNIFIED SCHOOL DISTRICT <input type="checkbox"/> Unknown | | PHONE 510-317-4837 | | |
| | ADDRESS 15510 USHER ST. SAN LORENZO CA 94580 | | | | |
| SITE LOCATION | FACILITY NAME (IF APPLICABLE) | | OPERATOR | | PHONE |
| | ADDRESS 50 EAST LEWELLING BLVD SAN LORENZO ALAMEDA 94580 | | | | |
| | CROSS STREET ASHLAND AVE. | | | | |
| IMPLEMENTING AGENCIES | LOCAL AGENCY AGENCY NAME ALAMEDA COUNTY ENVIRONMENTAL HEALTH -ROBERT WESTON | | | PHONE (510)567-6781 | |
| | REGIONAL BOARD | | | PHONE | |
| SUBSTANCES INVOLVED | (1) NAME DIESEL | | | QUANTITY LOST (GALLONS) _____ <input checked="" type="checkbox"/> Unknown | |
| | (2) | | | _____ <input type="checkbox"/> Unknown | |
| DISCOVERY/ABATEMENT | DATE DISCOVERED 8/18/10 | | HOW DISCOVERED <input type="checkbox"/> Tank Test <input checked="" type="checkbox"/> Tank Removal <input type="checkbox"/> Nuisance Conditions <input type="checkbox"/> Inventory Control <input type="checkbox"/> Subsurface Monitoring <input type="checkbox"/> Other... | | |
| | DATE DISCHARGE BEGAN | | METHOD USED TO STOP DISCHARGE (CHECK ALL THAT APPLY) <input checked="" type="checkbox"/> Unknown <input checked="" type="checkbox"/> Remove Contents <input checked="" type="checkbox"/> Close Tank & Removed <input type="checkbox"/> Repair Tank <input type="checkbox"/> Change Procedure <input type="checkbox"/> Replace Tank <input type="checkbox"/> Other... <input type="checkbox"/> Repair Piping | | |
| | HAS DISCHARGE BEEN STOPPED? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No 8/18/10 <small>IF YES, DATE</small> | | | | |
| SOURCE/CAUSE | SOURCE OF DISCHARGE <input type="checkbox"/> Tank Leak <input type="checkbox"/> Piping Leak <input checked="" type="checkbox"/> Unknown <input type="checkbox"/> Other... | | CAUSE(S) <input type="checkbox"/> Overfill <input type="checkbox"/> Corrosion <input type="checkbox"/> Rupture/Failure <input checked="" type="checkbox"/> Unknown <input type="checkbox"/> Spill <input type="checkbox"/> Other... | | |
| | CASE TYPE CHECK ONE ONLY <input checked="" type="checkbox"/> Undetermined <input type="checkbox"/> Soil Only <input type="checkbox"/> Groundwater <input type="checkbox"/> Drinking Water - (CHECK ONLY IF WATER WELLS HAVE ACTUALLY BEEN AFFECTED) | | | | |
| CURRENT STATUS | CHECK ONE ONLY <input checked="" type="checkbox"/> No Action Taken <input type="checkbox"/> Case Closed (Cleanup Completed or Unnecessary) <input type="checkbox"/> Leak Being Confirmed <input type="checkbox"/> Pollution Characterization <input type="checkbox"/> Remediation Plan <input type="checkbox"/> Post Cleanup Monitoring in Progress <input type="checkbox"/> Preliminary Site Assessment Workplan Submitted <input type="checkbox"/> Cleanup Underway <input type="checkbox"/> Preliminary Site Assessment Underway | | | | |
| | REMEDIAL ACTION CHECK APPROPRIATE ACTION(S) <input type="checkbox"/> Cap Site (CD) <input type="checkbox"/> Excavate & Treat (ET) <input type="checkbox"/> Treatment at Hookup (HU) <input type="checkbox"/> Other... <input type="checkbox"/> Contamination Barrier (CB) <input type="checkbox"/> No Action Required (NA) <input type="checkbox"/> Enhanced Bio Degradation (IT) <input type="checkbox"/> Vacuum Extract (VE) <input type="checkbox"/> Remove Free Product (FP) <input type="checkbox"/> Replace Supply (RS) <input type="checkbox"/> Excavate & Dispose (ED) <input type="checkbox"/> Pump & Treat Groundwater (GT) <input type="checkbox"/> Vent Soil (VS) | | | | |
| COMMENTS | Holes found in the tank. | | | | |
| | | | | | |

UNIFIED PROGRAM CONSOLIDATED FORM HAZARDOUS WASTE HAZARDOUS WASTE TANK CLOSURE CERTIFICATION

Page ___ of ___

I. FACILITY IDENTIFICATION

BUSINESS NAME (Same as FACILITY NAME or DBA - Doing Business As) 3. FACILITY ID# 1.

TANK OWNER NAME 740.
SAN LORENZO UNIFIED SCHOOL DISTRICT

TANK OWNER ADDRESS 741.

TANK OWNER CITY *SAN LORENZO* 742. STATE *CA* 743. ZIP CODE *94580* 744.

II. TANK CLOSURE INFORMATION

| TANK INTERIOR ATMOSPHERE READINGS | Tank ID # (Attach additional copies of this page for more than three tanks) | Concentration of Flammable Vapor | | | Concentration of Oxygen | | |
|-----------------------------------|--|--|--|--|---|---|---|
| | | Top | Center | Bottom | Top | Center | Bottom |
| 1 | <i>9172</i> 745. | <i>0%</i> 746a. | <i>0%</i> 746b. | <i>0%</i> 746c. | <i>20.9%</i> 747a. | <i>20.9%</i> 747b. | <i>20.9%</i> 747c. |
| 2 | 748. | 749a. | 749b. | 749c. | 750a. | 750b. | 750c. |
| 3 | 751. | 752a. | 752b. | 752c. | 753a. | 753b. | 753c. |

III. CERTIFICATION

On examination of the tank, I certify the tank is visually free from product, sludge, scale (thin, flaky residual of tank contents), rinseate and debris. I further certify that the information provided herein is true and accurate to the best of my knowledge.

SIGNATURE OF CERTIFIER 754. STATUS OR AFFILIATION OF CERTIFYING PERSON 760.

NAME OF CERTIFIER (Print) 754. Certifier is a representative of the CUPA, authorized agency, or LIA: 760.

TITLE OF CERTIFIER 755. N/A 761.

ADDRESS 756. If certifier is other than CUPA / LIA check appropriate box below: 762.

CITY 757.

PHONE 758.


DATE 759. CERTIFICATION TIME

TANK PREVIOUSLY HELD FLAMMABLE OR COMBUSTIBLE MATERIALS 763.

(If yes, the tank interior atmosphere shall be re-checked with a combustible gas indicator prior to work being conducted on the tank.) Yes No 764.

CERTIFIER'S TANK MANAGEMENT INSTRUCTIONS FOR SCRAP DEALER, DISPOSAL FACILITY, ETC: 764.

A copy of this certificate shall accompany the tank to the recycling/disposal facility and be provided to the agency overseeing tank closure (i.e. CUPA or other authorized local agency); the owner and/or operator of the tank system; and the tank removal contractor.



PERMIT # _____

**Alameda County Fire Department
Bureau of Fire Prevention**

**FIRE CODE REGULATED ACTIVITY/USE
APPLICATION and PERMIT**

Dublin Newark San Leandro Unincorporated Alameda County Union City

Application Date: 8/11/10

Type of Permit Requested: Remove Underground Storage Tank

Activity Date(s): 8/16/10

Activity Location: 50 E Lewelling Blvd.

City: San Lorenzo

ORGANIZATION/INDIVIDUAL MAKING APPLICATION

Name: _____ Phone #: _____

Address/City/State/Zip: _____

Contact Person: _____ Phone #: _____ FAX #: _____

CONTRACTOR INFORMATION (if applicable) ATTACH COPY OF WORKER'S COMP AND BUSINESS LICENSE

Company Name: Golden Gate Tank Removal License Type/Number: 616521 (A C-8, HAZ)

Address/City/State/Zip: 3730 Mission Street

Contact Person: Joshua Alexander Phone #: 415-512-1555 FAX #: 415-512-0964

DESCRIPTION OF ACTIVITY TO BE PERFORMED: *Attach copies of required listings, certificates, licenses, property owner approval (if different from applicant), etc. to fully explain activity, project, or authorization.*

Remove one diesel underground storage tank.

All permits issued by the Fire Department shall be presumed to contain the proviso that the applicant, his agents and employees, shall carry out the proposed activity in compliance with all the requirements of the fire code and any other laws or regulations applicable thereto, whether specified or not, and in complete accordance with the approved plans, specifications, and conditions of approval.

This permit shall not be construed as authority to cancel, violate or set aside any provisions of the fire code, State and any other laws or regulations applicable thereto; nor shall this permit take the place of any license or other regulatory permits required by law. Permits are not transferable and any change in the use, occupancy, operation, activity, or ownership shall require a new permit. Permits may be suspended or revoked for cause at any time.

I have read the above and acknowledge and agree to abide by the requirements and conditions of this permit. I also affirm all information that is provided as a part of this permit application is true and correct.

[Signature]
Signature of Applicant

8/11/10

Date

- Fire Department Office Use Only -

APPROVALS:

Rejected Date/By: _____ Cont. Notified: _____ Rejected Date/By: _____ Cont. Notified: _____

TYPE PERMIT: Tank Pull APPROVAL CONDITIONS ATTACHED

APPROVED BY: Bob Sussler DATE: 8/17/2010 EXPIRATION: _____

PERMIT NOT VALID WITHOUT APPROVAL SIGNATURE

FEES DUE: \$80 Date Paid: AD Comments: _____

Plans Received: _____ Date Due: _____ Plans Received: _____ Date Due: _____

CONTRACTOR COPY

JOB SITE COPY

ACCEPTED

Underground Storage Tank Closure Permit Application
Alameda County Division of Hazardous Materials
1131 Harbor Bay Parkway, Suite 280
Alameda, CA 94602-6577

These closure/removal plans have been received and found to be acceptable and essentially meet the requirements of State and Local Health Laws. Changes to your closure plans indicated by this Department are to assure compliance with State and local laws. The project proposed herein is now retained for issuance of any required building permits for construction/destruction.

One copy of the accepted plans must be on the job and available to all contractors and craftsmen involved with the removal.

Any changes or alterations of these plans and specifications must be submitted to this Department and to the Fire and Building Inspections Department to determine if such changes meet the requirements of State and local laws. Notify this Department at least 72 hours prior to the following required inspections:

- Removal of Tank(s) and Piping
- Sampling
- Final Inspection

Issuance of a) permit to operate, b) permanent closure, is dependent on compliance with accepted plans and all applicable laws and regulations.

THERE IS A FINANCIAL PENALTY FOR NOT OBTAINING THESE INSPECTIONS:

Contact Specialist:

Robert Weston

See Table 2 for analytes

510 567-6781

AUG 12 2010

ALAMEDA COUNTY HEALTH CARE SERVICES
ENVIRONMENTAL HEALTH SERVICES
1131 HARBOR BAY PARKWAY, RM 25
ALAMEDA, CA 94602-6577
PHONE # 510/567-6700

UNDERGROUND TANK CLOSURE PLAN

* * * Complete plan according to attached instructions * * *

1. Name of Business Golden Gate Tank Removal, Inc.
Business Owner or Contact Person (PRINT) Joshua Alexander
2. Site Address 50 East Lewelling Blvd.
city San Lorenzo zip 94580 Phone (510) 317-4837
3. Mailing Address 3730 Mission Street
city San Francisco zip 94110 Phone (415) 512-1555
4. Property Owner San Lorenzo Unified School District
Business Name (if applicable) San Lorenzo High School
Address 15510 Usher Street
city, state San Lorenzo CA zip 94580
5. Generator name under which tank will be manifested
San Lorenzo Unified School District
EPA ID# under which tank will be manifested CAL000035832

August 9, 2010

SR0017477

6. Contractor Golden Gate Tank Removal, Inc.
Address 3730 Mission Street
city San Francisco Phone (415) 512-1555
License Type A C-8 HAZ ID# 616521

7. Consultant (if applicable) _____
Address _____
City, State _____ Phone _____

8. Main Contact Person for Investigation (if applicable)
Name Joshua Alexander Title Project Manager
Company Golden Gate Tank Removal, Inc.
Phone (415) 512-1555

9. Number of underground tanks being closed with this plan 1 (one)
Length of piping being removed under this plan up to 15 feet
Total number of underground tanks at this facility (**confirmed with owner or operator) 1 (to be removed)

10. State Registered Hazardous Waste Transporters/Facilities (see instructions).

**** Underground storage tanks must be handled as hazardous waste ****

a) Product/Residual Sludge/Rinsate Transporter
Name Uniwaste, Inc. EPA I.D. No. CAL000317320
Hauler License No. 4919 License Exp. Date _____
Address P.O. Box 2404
City Union City State CA Zip _____

b) Product/Residual Sludge/Rinsate Disposal Site
Name Clearwater Environmental EPA ID# NVD982358483
Address 2430 Almond Drive
City Silver Springs State NV Zip 89429

c) Tank and Piping Transporter

Name Golden Gate Tank Removal, Inc. (Dispose & Transport as Non Haz) EPA I.D. No. _____

Hauler License No. _____ License Exp. Date _____

Address 3730 Mission Street

city San Francisco State CA Zip 94110

d) Tank and Piping Disposal Site

Name Circosta Scrap Metal EPA I.D. No. CAD983650797

Address 1801 Evans Ave.

city San Francisco State CA Zip 94124

11. Sample Collector

Name Joshua Alexander

Company Golden Gate Tank Removal, Inc.

Address 3730 Mission Street

City San Francisco State CA Zip 94110 Phone (415) 512-1555

12. Laboratory

Name Accutest Laboratories

Address 3334 Victor court

City Santa Clara State CA Zip 95054

State Certification No. 2346

13. Have tanks or pipes leaked in the past? Yes [] No [] Unknown [X]

If yes, describe. _____

14. Describe methods to be used for rendering tank(s) inert:

removal of product, purge, introduce dry ice to reduce vapors

flush lines and triple rinse with water, if necessary

pump to vacuum truck, steam clean tank

Before tanks are pumped out and inerted, all associated piping must be flushed back into the tank(s). All accessible piping must then be removed. Inaccessible piping must be permanently plugged using grout.

The Bay Area Air Quality Management District, 415/771-6000, along with local Fire and Building Departments, must also be contacted for tank removal permits. Fire departments typically require the use of a combustible gas indicator to verify tank inertness. It is the contractor's responsibility to have a functional combustible gas indicator on-site to verify that the tank(s) is inerted.

15. Tank History and Sampling Information *** (see instructions) ***

| Tank | | Material to be sampled (tank contents, soil, groundwater) | Location and Depth of Samples |
|------------|--|---|-------------------------------|
| Capacity | Use History include date last used (estimated) | | |
| 5K Gallons | unknown | soil samples & water if present | 1. stockpile 2. 3. on |

One soil sample must be collected for every 20 linear feet of piping that is removed. A ground water sample must be collected if any ground water is present in the excavation.

| Excavated/Stockpiled Soil | |
|---|--|
| Stockpiled Soil Volume (estimated) <h1>10-20 yards</h1> | Sampling Plan 4 point composite for every 50 cubic yards or 4 point composite for every 20 cubic yards |

Stockpiled soil must be placed on bermed plastic and must be completely covered by plastic sheeting.


Will the excavated soil be returned to the excavation immediately after tank removal? yes no unknown

If yes, explain reasoning _____

If unknown at this point in time, please be aware that excavated soil may not be returned to the excavation without prior approval from this office. This means that the contractor, consultant, or responsible party must communicate with the Specialist IN ADVANCE of backfilling activities.

TABLE #2
REVISED 21 NOVEMBER 2003

RECOMMENDED MINIMUM VERIFICATION ANALYSES FOR
UNDERGROUND TANK LEAKS

| <u>HYDROCARBON LEAK</u> | <u>SOIL ANALYSIS</u> (SW-846 METHOD) | | <u>WATER ANALYSIS</u> (Water/Waste Water Method) | |
|--|---|---|---|---|
| Gasoline (Leaded and Unleaded) | TPHG | 8015M or 8260 | TPHG | 8015M or 524.2/624 (8260) |
| | BTEX | 8260 | BTEX | 524.2/624 (8260) |
| | EDB and EDC | 8260 | EDB and EDC | 524.2/624 (8260) |
| | MTBE, TAME, ETBE, DIPE, TBA, and EtOH by 8260 for soil and 524.2/624 (8260) for water | | | |
| | TOTAL LEAD | AA | TOTAL LEAD | AA |
| | | --Optional-- | | |
| | Organic Lead | DHS-LUFT | Organic Lead | DHS-LUFT |
| Unknown Fuel | TPHG | 8015M or 8260 | TPHG | 8015M or 524.2/624 (8260) |
| | TPHD | 8015M or 8260 | TPHD | 8015M or 524.2/624 (8260) |
| | BTEX | 8260 | BTEX | 524.2/624 (8260) |
| | EDB and EDC | 8260 | EDB and EDC | 524.2/624 (8260) |
| | MTBE, TAME, ETBE, DIPE, TBA, and EtOH by 8260 for soil and 524.2/624 (8260) for water | | | |
| | TOTAL LEAD | AA | TOTAL LEAD | AA |
| | --Optional-- | | | |
| | Organic Lead | DHS-LUFT | Organic Lead | DHS-LUFT |
|  Diesel, Jet Fuel, Kerosene, and Fuel/Heating Oil | TPHD | 8015M or 8260 | TPHD | 8015M or 524.2/624 (8260) |
| | BTEX | 8260 | BTEX | 524.2/624 (8260) |
| | EDB and EDC | 8260 | EDB and EDC | 524.2/624 (8260) |
| | MTBE, TAME, ETBE, DIPE, TBA, and EtOH by 8260 for soil and 524.2/624 (8260) for water | | | |
| | | | | |
| Chlorinated Solvents | CL HC | 8260 | CL HC | 524.2/624 (8260) |
| | BTEX | 8260 or 8021 | BTEX | 524.2/624 (8260) or 502.2/602 (8021) |
| | 1,4-Dioxane | 8270M | 1,4-Dioxane | 8270M |
| Non-chlorinated Solvents | TPHD | 8015M or 8260 | TPHD | 8015M or 524.2/624 (8260) |
| | BTEX | 8260 or 8021 | BTEX | 524.2/624 (8260) or 502.2/602 (8021) |
| Waste, Used, or Unknown Oil | TPHG | 8015M or 8260 | TPHG | 8015M or 524.2/624 (8260) |
| | TPHD | 8015M or 8260 | TPHD | 8015M or 524.2/624 (8260) |
| | O&G | 9070 | O&G | 418.1 |
| | BTEX | 8260 | BTEX | 524.2/624 (8260) |
| | CL HC | 8260 | CL HC | 524.2/624 (8260) |
| | 1,4-Dioxane | 8270M | 1,4-Dioxane | 8270M |
| | EDB and EDC | 8260 | EDB and EDC | 524.2/624 (8260) |
| | MTBE, TAME, ETBE, DIPE, TBA, and EtOH by 8260 for soil and 524.2/624 (8260) for water | | | |
| | METALS (Cd, Cr, Pb, Ni, Zn) by ICAP or AA for soil water | | | |
| | PCB*, PCP*, PNA, CREOSOTE by 8270 for soil and 524/625 (8270) for water | | | |
| | | If found, analyze for dibenzofurans (PCBs) or dioxins (PCP) | | |

NOTES:

1. 8021 replaces old methods 8020 and 8010
2. 8260 replaces old method 8240
3. Reference: Table B-1 in Appendix B of "Expedited Site Assessment Tools for Underground Storage Tank Sites: A Guide for Regulators" (EPA 510-B-97-001).