

Detterman, Karel, Env. Health

From: Detterman, Karel, Env. Health
Sent: Friday, February 03, 2017 12:17 PM
To: 'MarkHorne@chevron.com'
Cc: Roe, Dilan, Env. Health; 'Kiersten.Hoey@ghd.com'
Subject: Fuel Leak Case RO3098 - Ed's Liquor Store, Geotracker Global ID T10000004218, 2700 23rd Avenue, Oakland, CA 94606

Hello Mark:

Alameda County Department of Environmental Health (ACDEH) has reviewed the December 2, 2016 *Low Threat Case Closure Request* prepared on Chevron's behalf by GHD for the referenced case. ACDEH has evaluated the data in conjunction with the case files, and in reference to the State Water Resources Control Board's (SWRCBs) Low Threat Underground Storage Tank Case Closure Policy (LTCP). Based on ACDEH staff review, we have determined that the site does not meet the LTCP General Criteria f (Secondary Source Removal), Media-Specific Criteria for Groundwater, Media-Specific Criteria for Vapor Intrusion to Indoor Air, and the Media-Specific Criteria for Direct Contact. Consequently, ACDEH must deny closure. We will send a Directive Letter next week with supporting rationale.

Thank you,

Karel Detterman, PG
Hazardous Materials Specialist
Alameda County Environmental Health
1131 Harbor Bay Parkway
Alameda, CA 94502
Direct: 510.567.6708
Fax: 510.337.9335
Email: karel.detterman@acgov.org

PDF copies of case files can be downloaded at:

<http://www.acgov.org/aceh/lop/ust.htm>