


CITY OF OAKLAND



DALZIEL BUILDING • 250 FRANK H. OGAWA PLAZA, SUITE 3341 • OAKLAND, CALIFORNIA 94612-2032

Fire Prevention Bureau

(510) 238-3851
TDD (510) 238-3254

June 18, 2013

Mr. Chris Bledsoe
Caltrans District 4
111 Grand Avenue
Oakland, CA 94612

RE: Underground Storage Tank Referral

Bay Bridge Toll Plaza
Oakland, CA 94801

Mr. Bledsoe::

This letter confirms the completion of the removal of three underground storage tanks (USTs) at subject site. The USTs were of single walled construction. One tank had a capacity of 3,000 gallons and previously contained gasoline. Two other tanks had capacities of 2,000 gallons and previously contained diesel fuel. Geocon Consultants, Inc. performed and completed the UST Removal and provided a thorough report on this project.

The City Of Oakland Fire Department/Hazardous Material Management Program (OFD/HMMP) staff has reviewed the analytical results. Based on the available information, this site is considered contaminated and is being transferred to Alameda County Environmental Health for follow up. Attached is a copy of the transfer form.

If you have any questions, please contact me at (510) 238-7253

Sincerely,

Sheryl Skillern,
Senior Hazardous Material Inspector

Cc: Bob Kimball, Geocon Consultants, Inc
Donna Drogos, Alameda County Environmental Health