

UNDERGROUND STORAGE TANK (UST) SITE - UNAUTHORIZED RELEASE / CONTAMINATION REPORT

EMERGENCY Yes No HAS STATE OFFICE OF EMERGENCY SERVICES REPORT BEEN FILED? Yes No **FOR LOCAL AGENCY USE ONLY**
 I HEREBY CERTIFY THAT I AM A DESIGNATED GOVERNMENT EMPLOYEE AND THAT I HAVE REPORTED THIS INFORMATION TO LOCAL OFFICIALS PURSUANT TO SECTION 25180.7 OF THE HEALTH AND SAFETY CODE.

REPORT DATE: **March 18, 2013** CASE # _____
 SIGNED: *[Signature]* DATE: **03/08/13**

REPORTED BY: NAME OF INDIVIDUAL FILING REPORT: **Tim Cook** PHONE: **(925) 478-8390** SIGNATURE: *[Signature]*
 REPRESENTING: LOCAL AGENCY REGIONAL BOARD OWNER/OPERATOR OTHER COMPANY OR AGENCY NAME: **Cook Environmental Services, Inc.**
 ADDRESS: **1485 Treat Blvd., Ste 203A Walnut Creek, CA 94597**

RESPONSIBLE PARTY: NAME: **Keyle Milligan and Susan Casentini Trust** CONTACT PERSON: **Susan Casentini** PHONE: **((510) 891-8893**
 ADDRESS: **388 Belmont St. Oakland CA 94610**

SITE LOCATION: FACILITY NAME (IF APPLICABLE): **NA** OPERATOR: **NA** PHONE: **(NA)**
 ADDRESS: **385 26th Street, Oakland, Alameda County, CA 94612**
 CROSS STREET: **Telegraph Ave.**

IMPLEMENTING AGENCIES: LOCAL AGENCY: **City of Oakland Fire Department** PHONE: **((510) 238-7759**
 REGIONAL BOARD: **San Francisco Bay (Region 2)** PHONE: **((510) 622-2300**

SUBSTANCES INVOLVED: (1) **Heating Oil** NAME QUANTITY LOST (GALLONS) Unknown
 (2) _____ Unknown

DISCOVERY/ABATEMENT: DATE DISCOVERED: **February 14, 2013** HOW DISCOVERED: Tank Test Tank Removal Nuisance Conditions
 Inventory Control Subsurface Monitoring Other
 DATE DISCHARGE BEGAN: _____ METHOD USED TO STOP DISCHARGE (CHECK ALL THAT APPLY):
 Remove Contents Close Tank
 Repair Tank Change Procedure
 Replace Tank Other
 Repair Piping
 HAS DISCHARGE BEEN STOPPED? Yes No IF YES, DATE: _____

SOURCE/CAUSE: SOURCE OF DISCHARGE: Tank Piping Dispenser Delivery Problem Submersible Turbine Pump (STP) Other CAUSE(S): Spill Overfill Physical/Mechanical Damage Corrosion Installation Problem Unknown Other

CASE TYPE: CHECK ONE ONLY Undetermined Soil Only Groundwater Drinking Water - (CHECK ONLY IF WATER WELLS HAVE ACTUALLY BEEN AFFECTED)

CURRENT STATUS: CHECK ONE ONLY Open - Site Assessment Open - Verification Monitoring Open - Inactive Open - Assessment & Interim Remedial Action Closed - No Further Action Required Open - Remediation

REMEDIAL ACTION: CHECK APPROPRIATE ACTION(S)
 Human health exposure control? Yes No Unknown
 Groundwater migration control? Yes No Unknown
 No Action Required (NAR) Excavate & Treat (ET) Treatment at Hookup (TH) Other
 Excavate & Dispose (ED) Free Product Removal (FPR) Replace Supply (RS)

COMMENTS: **80 gals of heating oil and 60 tons of contaminated soil have been excavated and disposed of offsite. Verification soil samples were collected from the bottom of the excavation under the direction of the City of Oakland Fire Dept. Lab analysis pending.**