

Nowell, Keith, Env. Health

From: Tom Graf <tom@grafcon.us>
Sent: Wednesday, August 16, 2017 7:26 AM
To: Roe, Dilan, Env. Health; Nowell, Keith, Env. Health
Subject: Fwd: FW: OAK 2=Import Fill Submittal Data from Stevens Creek Quarry
Attachments: tempFileForShare_20170727-121523.jpg; DirtMovers CityVenturesOakland2Letter 7-27-17.pdf; SKM_454e17032210280.pdf

Dilan and Keith - forwarding the asbestos sample. I missed including it in the package.

Keith's question regarding arsenic:

1. Our site has 10 samples analyzed for arsenic. Three have concentrations above the reporting limit of 1.5 mg/kg. The three range from 1.7 to 3.4 mg/kg. Our import quarry has 6.3 and 6.6 mg/kg. Both are in the anticipated range of background concentrations; however, the borrow area concentration is greater than the receiving site. As a consultant I would not allow the import as the concentration is above the ESL. Please comment.

The Water Board is using generic background around the bay area of 11 mg/kg. We are comfortable bringing in fill with arsenic at 6 mg/kg. Trying to find fill below that is a random exercise.

Tom

From: Idemoto, Mark [mailto:MIidemoto@scqinc.com]
Sent: Thursday, July 27, 2017 2:15 PM
To: Lisa M. Rubinger <purchasing@dirtmoversca.com>
Cc: Schreiner, Dan <Dan.Schreiner@stantec.com>
Subject: RE: OAK 2=Import Fill Submittal Data from Stevens Creek Quarry

July 27, 2017

John, Lisa & Dan

See attached as requested. Let me know if I can be of any further assistance.

Sincerely,

Mark Idemoto

Stevens Creek Quarry

12100 Stevens Canyon Road

Cupertino, CA 95014

Cell [\(408\) 640-9378](tel:4086409378)

Office [\(408\) 253-2512](tel:4082532512)

Midemoto@scqinc.com

From: Schreiner, Dan [<mailto:Dan.Schreiner@stantec.com>]
Sent: Wednesday, July 26, 2017 11:02 AM
To: Idemoto, Mark
Cc: Lisa Rubinger
Subject: FW: OAK 2= Import Fill Submittal Data from Stevens Creek Quarry

Hi Mark. Thanks for talking with me about your Stevens Creek Quarry source for fill material that we would like to use on our City Ventures Oakland 2 project. See questions highlighted in emails below. Any information you have regarding the rock type/formation and if it has been tested for asbestos is appreciated. We would also be looking for a letter, similar to the attached (provided for example) indicating that the analytical that we received from you on the 21st is representative of what materials we would be using on our project now.

Thank you,

Dan Schreiner, P.G.

Senior Geologist
Stantec Consulting Services Inc.
3875 Atherton Road, Rocklin CA 95765-3716
Phone: [\(916\) 472-3915](tel:(916)472-3915)
Cell: [\(916\) 626-7882](tel:(916)626-7882)
Dan.Schreiner@stantec.com



The content of this email is the confidential property of Stantec and should not be copied, modified, retransmitted, or used for any purpose except with Stantec's written authorization. If you are not the intended recipient, please delete all copies and notify us immediately.

 Please consider the environment before printing this email.

From: Idemoto, Mark [<mailto:MIidemoto@scqinc.com>]
Sent: Thursday, July 21, 2017 9:37 AM
To: Lisa M. Rubinger <purchasing@dirtmoversca.com>
Subject: SCQ Sheridan Road Native Clean Fill

July 21, 2017

Lisa and John,

See attached McCampbell Analytical report recently run on our Sheridan Road Engineered Fill. Geotechnicals are also

included.

Sincerely,

Mark Idemoto

Stevens Creek Quarry

12100 Stevens Canyon Road

Cupertino, CA 95014

Cell [\(408\) 640-9378](tel:(408)640-9378)

Office [\(408\) 253-2512](tel:(408)253-2512)

Midemoto@scqinc.com