

175 KEVIN CT.

UNDERGROUND STORAGE TANK (UST) SITE - UNAUTHORIZED RELEASE / CONTAMINATION REPORT			
EMERGENCY <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		HAS STATE OFFICE OF EMERGENCY SERVICES REPORT BEEN FILED? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
REPORT DATE 12/31/14		CASE #	
<b>FOR LOCAL AGENCY USE ONLY</b> I HEREBY CERTIFY THAT I AM A DESIGNATED GOVERNMENT EMPLOYEE AND THAT I HAVE REPORTED THIS INFORMATION TO LOCAL OFFICIALS PURSUANT TO SECTION 25180.7 OF THE HEALTH AND SAFETY CODE. SIGNED: <i>Shyly S. Spill</i> DATE: 4/17/15			
REPORTED BY	NAME OF INDIVIDUAL FILING REPORT David Provance		PHONE (925) 746-6006
	<input type="checkbox"/> LOCAL AGENCY <input type="checkbox"/> REGIONAL BOARD <input checked="" type="checkbox"/> OWNER/OPERATOR <input type="checkbox"/> OTHER		SIGNATURE <i>David Provance</i> DATE: 12/31/14
ADDRESS 2500 Camino Diablo		COMPANY OR AGENCY NAME AEI Consultants	
STREET		CITY Walnut Creek CA	STATE ZIP CA 94597
RESPONSIBLE PARTY	NAME Robert Elliott		CONTACT PERSON Mark Elliott
	ADDRESS 408 Silver Chief Way		PHONE (510) 715-1643
STREET		CITY Danville CA	STATE ZIP CA 94526
SITE LOCATION	FACILITY NAME (IF APPLICABLE)		OPERATOR Robert Elliott
	ADDRESS 745 Kevin Ct.		PHONE (510) 715-1643
	STREET Coliseum Way		CITY COUNTY ZIP Oakland Alameda 94621
IMPLEMENTING AGENCIES	LOCAL AGENCY AGENCY NAME Oakland Fire Department		PHONE (510) 238-7253
	REGIONAL BOARD San Francisco Bay		PHONE (510) 622-2300
SUBSTANCES INVOLVED	(1) NAME Regular gasoline		QUANTITY LOST (GALLONS) <input checked="" type="checkbox"/> Unknown
	(2)		<input type="checkbox"/> Unknown
DISCOVERY/ABATEMENT	DATE DISCOVERED 11/10/2014	HOW DISCOVERED <input type="checkbox"/> Tank Test <input type="checkbox"/> Tank Removal <input type="checkbox"/> Nuisance Conditions <input type="checkbox"/> Inventory Control <input checked="" type="checkbox"/> Subsurface Monitoring <input type="checkbox"/> Other	
	DATE DISCHARGE BEGAN	METHOD USED TO STOP DISCHARGE (CHECK ALL THAT APPLY) <input type="checkbox"/> Remove Contents <input checked="" type="checkbox"/> Close Tank <input type="checkbox"/> Repair Tank <input type="checkbox"/> Change Procedure <input type="checkbox"/> Replace Tank <input type="checkbox"/> Other <input type="checkbox"/> Repair Piping	
	HAS DISCHARGE BEEN STOPPED? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No IF YES, DATE	<input checked="" type="checkbox"/> Unknown	
SOURCE/ CAUSE	SOURCE OF DISCHARGE <input checked="" type="checkbox"/> Tank <input type="checkbox"/> Piping <input type="checkbox"/> Dispenser <input type="checkbox"/> Delivery Problem <input type="checkbox"/> Submersible Turbine Pump (STP) <input type="checkbox"/> Other		CAUSE(S) <input type="checkbox"/> Spill <input type="checkbox"/> Overfill <input type="checkbox"/> Physical/Mechanical Damage <input type="checkbox"/> Corrosion <input type="checkbox"/> Installation Problem <input checked="" type="checkbox"/> Unknown <input type="checkbox"/> Other
	CHECK ONE ONLY <input checked="" type="checkbox"/> Undetermined <input type="checkbox"/> Soil Only <input type="checkbox"/> Groundwater <input type="checkbox"/> Drinking Water -- (CHECK ONLY IF WATER WELLS HAVE ACTUALLY BEEN AFFECTED)		
CURRENT STATUS	CHECK ONE ONLY <input checked="" type="checkbox"/> Open - Site Assessment <input type="checkbox"/> Open - Verification Monitoring <input type="checkbox"/> Open - Assessment & Interim Remedial Action <input type="checkbox"/> Open - Inactive <input type="checkbox"/> Open - Remediation <input type="checkbox"/> Closed - No Further Action Required		
	CHECK APPROPRIATE ACTION(S) Human health exposure control? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Unknown Groundwater migration control? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Unknown <input checked="" type="checkbox"/> No Action Required (NAR) <input type="checkbox"/> Excavate & Treat (ET) <input type="checkbox"/> Treatment at Hookup (TH) <input type="checkbox"/> Other <input checked="" type="checkbox"/> Excavate & Dispose (ED) <input type="checkbox"/> Free Product Removal (FPR) <input type="checkbox"/> Replace Supply (RS)		
COMMENTS	Former 1,000 gallon gasoline UST used for vehicle fueling was removed ~ March 1991. No closure documentation is on file with agencies. Owner seeking closure as part of sale of property		