

UNDERGROUND STORAGE TANK (UST) SITE - UNAUTHORIZED RELEASE / CONTAMINATION REPORT

EMERGENCY <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		HAS STATE OFFICE OF EMERGENCY SERVICES REPORT BEEN FILED? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		FOR LOCAL AGENCY USE ONLY I HEREBY CERTIFY THAT I AM A DESIGNATED GOVERNMENT EMPLOYEE AND THAT I HAVE REPORTED THIS INFORMATION TO LOCAL OFFICIALS PURSUANT TO SECTION 25180.7 OF THE HEALTH AND SAFETY CODE.		
REPORT DATE 12/8/15*		CASE # ACDEH # R003216		SIGNED: <i>[Signature]</i> DATE: 12-28-2016		
REPORTED BY	NAME OF INDIVIDUAL FILING REPORT TRENT MACRE		PHONE (415) 254-4638		SIGNATURE <i>[Signature]</i>	
	REPRESENTING <input type="checkbox"/> LOCAL AGENCY <input type="checkbox"/> REGIONAL BOARD <input checked="" type="checkbox"/> OWNER/OPERATOR <input type="checkbox"/> OTHER		COMPANY OR AGENCY NAME 1244 2ND AVENUE LLC			
	ADDRESS 2655 VANNESS AVE, SUITE 2 SAN FRANCISCO CA 94109					
RESPONSIBLE PARTY	NAME SAME AS ABOVE <input type="checkbox"/> Unknown		CONTACT PERSON ()		PHONE ()	
	ADDRESS OTHER RESPONSIBLE PARTIES LISTED ON AGENCY LETTER DATED OCT. 30, 2016					
SITE LOCATION	FACILITY NAME (IF APPLICABLE) NA		OPERATOR NA		PHONE () NA	
	ADDRESS 1244 2ND AVENUE OAKLAND ALAMEDA 94606					
	CROSS STREET INTERNATIONAL BLDG					
IMPLEMENTING AGENCIES	LOCAL AGENCY AGENCY NAME ACDEH CASERNORAL ANNE JURK				PHONE (510) 567-6721	
	REGIONAL BOARD NA				PHONE ()	
SUBSTANCES INVOLVED	(1)		NAME		QUANTITY LOST (GALLONS)	
			TPH d RANGE HYDROCARBONS		<input checked="" type="checkbox"/> Unknown	
(2)				TPH m " " <input checked="" type="checkbox"/> Unknown		
DISCOVERY/ABATEMENT	DATE DISCOVERED 12/8/15		HOW DISCOVERED <input type="checkbox"/> Tank Test <input checked="" type="checkbox"/> Tank Removal <input type="checkbox"/> Nuisance Conditions <input type="checkbox"/> Inventory Control <input type="checkbox"/> Subsurface Monitoring <input type="checkbox"/> Other			
	DATE DISCHARGE BEGAN Unknown		METHOD USED TO STOP DISCHARGE (CHECK ALL THAT APPLY) <input checked="" type="checkbox"/> Remove Contents <input type="checkbox"/> Close Tank <input type="checkbox"/> Repair Tank <input type="checkbox"/> Change Procedure <input type="checkbox"/> Replace Tank <input checked="" type="checkbox"/> Other REMOVE TANK + CONTENTS <input type="checkbox"/> Repair Piping			
	HAS DISCHARGE BEEN STOPPED? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No IF YES, DATE 12/8/15					
SOURCE/CAUSE	SOURCE OF DISCHARGE <input checked="" type="checkbox"/> Tank <input type="checkbox"/> Piping <input type="checkbox"/> Dispenser <input type="checkbox"/> Delivery Problem <input type="checkbox"/> Submersible Turbine Pump (STP) <input type="checkbox"/> Other			CAUSE(S) <input type="checkbox"/> Spill <input type="checkbox"/> Overfill <input type="checkbox"/> Physical/Mechanical Damage <input type="checkbox"/> Corrosion <input type="checkbox"/> Installation Problem <input checked="" type="checkbox"/> Unknown <input type="checkbox"/> Other		
	CHECK ONE ONLY <input type="checkbox"/> Undetermined <input type="checkbox"/> Soil Only <input checked="" type="checkbox"/> Groundwater <input type="checkbox"/> Drinking Water - (CHECK ONLY IF WATER WELLS HAVE ACTUALLY BEEN AFFECTED)					
CURRENT STATUS	CHECK ONE ONLY <input type="checkbox"/> Open - Site Assessment <input type="checkbox"/> Open - Verification Monitoring <input type="checkbox"/> Open - Assessment & Interim Remedial Action <input type="checkbox"/> Open - Inactive <input type="checkbox"/> Open - Remediation <input checked="" type="checkbox"/> Closed - No Further Action Required					NEED AGENCY CASE
	CHECK APPROPRIATE ACTION(S) Human health exposure control? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Unknown Groundwater migration control? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Unknown <input type="checkbox"/> No Action Required (NAR) <input type="checkbox"/> Excavate & Treat (ET) <input type="checkbox"/> Treatment at Hookup (TH) <input type="checkbox"/> Other <input checked="" type="checkbox"/> Excavate & Dispose (ED) <input type="checkbox"/> Free Product Removal (FPR) <input type="checkbox"/> Replace Supply (RS)					
REMEDIAL ACTION	APPROXIMATELY 50-90 TONS OF SOIL AND 2,800 GALLONS OF WATER WAS REMOVED					
	* RELEASE DISCOVERED DURING REMOVAL OF A 1,000 GALLON UST. URF REPORT PREPARED 12/28/16 PER AGENCY REQUEST					