

PES

6/2/00 Spoke to Kyle Flores @ 415-899-1600 concerning his proposed workplan. We agreed that three hydrogeologic should be advanced. One in the source area, one downgradient ~15' feet, and one upgradient near property line.

Spw/ Kyle Flores of PES

4/17/01 William Thomas: Executor of trust
Esther - still alive

- will send original & an addendum to wp plans to do a boring directly in the center of former tank pit for soil + gw sample. Told him to run samples for TPHd, g, BTEX + MTBE.
KF said PES had sent the original wp but it wasn't in files

5/10/01 William Thomas: do.
Poddesak Trust
1727 11th St.
Oak 94607
570-465-6985

DB's notes:

700 gal for tank

1530 used

TPH - Gasoline exceeding 1,000 ppm which is anticipated as leaking under street.

Data sheet currently 'misplaced'

Data sheet to be retrieved and submitted to Alca. Advised that further excavation required + verification samples need be collected.

Advised on possible need for Waste Discharge Permit from Regional Board.

Anticipate data sheet to be submitted by return on 2/14/90

7-14-93 JE spoke w/DB. He remembers RP as being not very aware of all this UST removal involves. They found the UST by accident. The contractor was "fly-by-night".

find RP:

none in Berkeley.

★ J. Podlesak 357-5584 S.L.

~~357-9294 John Podlesak 1689 Vista Grand Dr SL~~

sp w/ RP. He still owns site. Says he doesn't have lab data. (May be an old man. Hearing problem.)